



TECHNICAL SPECIFICATION

AIR HANDLING UNITS

SPECIFICATION NO.PES-553-02

VOLUME II B

SECTION D


REV. 02

DATE: 17.09.2012


SHEET 6 OF 6

5. DRAWINGS/DOCUMENT/DATA REQUIRED AFTER AWARD OF CONTRACT

- 5.1 GA drawing of AHU & data- sheet to be submitted along with technical schedules enclosed in Volume III.
- 5.2 Drawing including equipment layout, foundation & loading details etc. for civil works. These drawings must cover sufficient details so that design of civil works can be completed.
- 5.3 Inspection, operation & Maintenance Manuals.
- 5.4 Equipment description giving complete design calculations, basis of design, selection criteria etc.
- 5.5 Test Certificates.
- 5.6 Final as built documentation i.e. final-version of all drawings, data & information as per the requirement specified elsewhere.
- 5.7 Performance Test Certificates.


Varun Jain


S A Khan


Praveen Kishore

**AIR HANDLING UNIT****DATA SHEET - A**

VOLUME - II-B

SECTION - D

REV 00

DATE 17.09.2012

SHEET 1 OF 2

DESCRIPTION**DATA**

- | | |
|--|--|
| 1. Nos. required/working | : Refer to Section-C of Specific technical requirement. |
| 2. Location | : Refer to Section-C of Specific technical requirement. |
| 3. Service/type | : Air Conditioning /Double skin. |
| 4. Fan type | : Centrifugal (forward/backward curve Blade) limit load. |
| a) Capacity | : To Suit as per calculation. |
| b) Static pressure | : To suit but not less than 60 mm wc for AHU's Micro-V filters. |
| c) Discharge direction | : To suit layout. |
| d) Motor | : By Bidder, |
| e) Local push button station (Start/Stop) | : By Others |
| f) Motor location | : Inside AHU Casing. |
| g) Drive | : Belt, pulley, belt guard. |
| 5. Face and Bypass Damper | : Required (Opposed blade type) DX AHU's having |
| 6. Cooling coil | : Required (Opposed blade type) DX AHU's having |
| a) Duty sensible heat | : To suit as per calculations |
| b) Duty latent heat | : -do- |
| c) Type of coil | : Chilled Water/DX/Hot Water. |
| d) No. of rows | : To suit but not less than four (4) |
| e) Material of tube /Thickness | : Seamless Copper to ASTM E-75/Equivalent. |
| f) Material of fins | : Aluminium to SAE-1100-/1145-0 |
| g) Number of fins | : Not greater than 5 per cm (13 per inch). |
| h) Max. face velocity | : 2.5 m/sec. |
| i) Air flow quantity | : To suit as per tender drawings/documents. |
| 7. 3 - way motorised mixing valve with thermostat. | : Required with thermostat & actuator for chilled water system for each AHU. |

Varun Jain
S A Khan
Praveen Kishore



AIR HANDLING UNIT
DATA SHEET - A

VOLUME - II-B


SECTION - D

REV 00

DATE 17.09.2012

SHEET 2 OF 2

8. Damper at discharge : Manually operated at discharge of each AHU outlet.
a) Material of construction : Mild Steel, galvanised.
9. Filters (Pre-filters)
a) Type & thickness : Dry panel type/ 50 mm
b) Filter area. : To suit as per velocity requirements. "V" - Bank.
c) Filter efficiency : Average arrestance efficiency of 65-80 %
d) Press drop (Clean) : Not to exceed 2.5 mmwc when clean & 6.5 mmwc while dirty.
10. Humidification section : As per the System requirement.
a) Type : Pan type, unless otherwise specified.
b) Operation : Automatic with Humidification.
11. Fresh air arrangement : Required.
a) Fresh air fan : Tube axial flow fans with motor.
b) Accessories : i) Inlet cone with Bird screen.
: ii) Dry panel pre-filters,
: iii) High efficiency filters for control room areas.
: iv) Volume Control Dampers,
: v) Supports etc.
12. Vibration isolator required. : Yes
13. Type of vibration isolator. : Neoprene ribbed Rubber for AHU's.
14. Any other requirement : i) In addition to dry panel filters on AHU, High efficiency filters(average arrestance efficiency of 80-90 %) shall be provided in supply air duct side of AHU for all control room and allied areas.
: ii) Bidder to also provide suitable electrical strip heaters for winter heating & monsoon reheating with Contactor box etc. Heaters to be interlocked with airstat.
15. Instrument & controls : Lot.(including Control box for strip heaters, pan humidifiers etc. in each AHU room.)
16. Insulation of drain piping : Lot.


Varun Jain


S A Khan


Praveen Kishore



**STANDARD TECHNICAL
SPECIFICATION
FOR
COOLING TOWER**

SPECIFICATION NO.PES-553-03

VOLUME II B


SECTION D

REV. 02

DATE: 17.09.2012

SHEET 1 OF 5

**STANDARD TECHNICAL SPECIFICATION
FOR
COOLING TOWER**


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION

COOLING TOWER

SPECIFICATION NO.PES-553-03

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 2 OF 5

1. GENERAL

1.1 this standard specification covers the design, manufacture assembly, inspection & testing at manufacturer's works, suitable painting & packing, delivery, erection & commissioning at site of all materials and equipments for mechanical induced draught cooling tower complete with all accessories as specified hereinafter.

2. CODES & STANDARDS

2.1 the design, manufacture, inspection & testing and performance of the cooling tower as specified hereinafter shall comply with the requirements of all applicable latest Indian/British/American standards and codes of practice. the latest editions of the following standards & publications shall be followed in particular:

2.1.1 Cooling tower institute USA bulletin ATP-10S: Acceptance test procedure for industrial water-cooling tower.

2.1.2 PTC-23 ASME performance test code for Atmospheric water-cooling equipment.

2.1.3 In case of any conflict between the above codes & standards and-this specification, the later shall prevail.

3. DESIGN REQUIREMENTS

3.1 the cooling tower shall be designed for continuous operation to cool not less than design flow of water from specified inlet temperature to the outlet temperature at a design ambient wet bulb temperature as indicated under data sheet a.


3.2 all the components shall be capable of safe, proper and continuous operation at all cooling water flows upto & including those specified under data sheet a & shall be designed with regard to case of maintenance, repair, cleaning & inspection.

3.3 the cooling tower shall be of induced draught cross flow or counter flow type and with multiple cells (if specified in data sheet a.) the cooling tower shall be suitable for handling the fluid and also for achieving the specified parameter as per data sheet a. the cooling tower shall be designed such that the drift losses & evaporation losses are minimum.


4. CONSTRUCTIONAL FEATURES

4.1 CASING & LOUVERS

4.1.1 The cooling tower casing shall be made of FRP/as specified in data sheet A. The louvers shall be made of FRP/as specified. Louvers, if provided, shall be designed for air entry to the tower with low velocity for minimum pressure drop & less chance of recirculation of moist air. To eliminate splash out, louvers shall slope to shed water inwards. Air intake shall be all along the base circumference of the casing & hotdip galvanised expanded metal mesh shall be provided to protect the air intake.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION

COOLING TOWER

SPECIFICATION NO. PES-553-03

VOLUME II B


SECTION D

REV. 02

DATE: 17.09.2012

SHEET 3 OF 5

- 4.2 FILL
- 4.2.1 Cooling tower fills shall be made of noncombustible PVC/as specified in data sheet A. The design & arrangement of the fills shall be so as to expose maximum air/water surface with minimum pressure drop.
- 4.3 Drift Eliminators
- 4.3.1 Multi-pass drift eliminators with minimum two pass zig-zag path shall be provided so to minimise the drift losses.
- 4.3.2 In case of FRP cooling tower the drift eliminators shall be of multi-blade rotary type.
- 4.4 Fans & Accessories
- 4.4.1 The fans shall be multiple blade, low speed, high efficiency axial flow type located above the top deck level of the cooling tower. Fan rotating assembly shall be statically & dynamically balanced. The fan blades shall be preferably adjustable in stand still condition for propeller action. The fan shall be either directly mounted on the shaft of a totally enclosed weather proof motor or shall be suitable for V-belt drive.
- 4.4.2 The rating of drive motor shall have at least 15% margin over maximum fan power consumption. The design & construction of the drive motor shall be in accordance with enclosed specification for LVAC motors.
- 4.5 Water basin
- 4.5.1 The material of construction of water basin shall be FRP or RCC as specified in data sheet A. The basin shall be provided as a part of cooling tower in case of FRP construction. The sump shall have sufficient storage capacity for safe operation of AC plant.
- 4.6 Hot water distribution system
- 4.6.1 Manually operated flow control valves shall be provided in hot water distribution piping such that each cooling tower can be isolated without affecting the operation of other cells.
- 4.6.2 The nozzles shall be spaced to give even distribution of water over entire space occupied by top row of fills. The nozzles shall be made of brass /SS 304/316/316L (brass shall be as per manufacturer's standard) unless specified in data sheet A:
- 4.6.3 In case of FRP tower water shall be distributed over the fill by means of a multiple area fail safe rotary sprinkler made of PVC pipes fitted on a aluminium alloy (as per manufacturers standard) rotary head and mounted on sealed ball bearings (make) .
- 4.7 Access
- 4.7.1 A stair case paddle ladder (as per manufacturer's standard) shall be provided external to the cooling tower at one end of each tower along with stairways hand rails etc give safe & convenient access to the top deck from ground level.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION

COOLING TOWER

SPECIFICATION NO.PES-553-03

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 4 OF 5

4.8 Painting

4.8.1 The cooling towers shall be painted with suitable anti-corrosive paint as per approval of purchaser. All galvanized external surfaces shall be painted to match colouring scheme. Before painting galvanized surfaces -etch primer to be applied.

5. SHOP INSPECTION & TESTING

5.1 Compliance certificates for nozzles (Or rotary sprinkler), piping, fill material, drift eliminator, louvers components etc.

5.2 Certificate of conformance for all other material components.

5.3 Balancing report for Static & dynamic balancing of fan assembly.


6. TESTS AT SITE

6.1 Hydrostatic testing of complete hot water distribution piping at site.


7. PERFORMANCE GUARANTEE

7.1 The cooling tower shall be guaranteed to meet the performance requirements as specified & when tested in accordance with ATP-105.

7.2 The vendor shall furnish performance curves for the cooling tower showing variations in performance from design duty point with change in approach to wet bulb temperature, cooling range, water loading of cooling tower.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION

COOLING TOWER

SPECIFICATION NO.PES-553-03

VOLUME II B

SECTION D


REV. 02

DATE: 17.09.2012


SHEET 5 OF 5

8. DATA TO BE FURNISHED BY VENDOR AFTER THE AWARD OF CONTRACT

- 8.1 General arrangement drawing of complete cooling tower (showing plan, front elevation and side elevation) incorporating principal dimensions, limits of scope of supply of piping, limits of civil works included showing extent of platforms, walkways, handrails, access doors, staircase etc. and the limits of scope of supply of electrical works.
- 8.2 General arrangement and sectional assembly drawings pertaining to the following components of the cooling tower:
- i) Tower fill with supporting arrangement.
 - ii) Drift eliminator installation and details.
 - iii) Complete hot water distribution system including flow regulating valves, distribution basin/pipes and nozzles etc.
- 8.3 Cooling tower performance curves showing WBT Vs cold-water temperature for design cooling range, 90% cooling range and 110% cooling range at 100%, 90%, and 110% design flow.
- 8.4 Performance curves of cooling tower fans.
- 8.5 Test procedure along with details of tests to be conducted for the offered cooling tower.
- 8.6 Quality Plan along with complete details of the testing and inspection requirements of mechanical and electrical items of the cooling tower in BHEL format.
- 8.7 Operation and maintenance instructions.


Varun Jain


S A Khan


Praveen Kishore



COOLING TOWER
DATA SHEET - A

VOLUME II-B

SECTION D

REV 00

DATE 17.09.2012

SHEET 1 OF 2

A. GENERAL DATA

- 1) Service : Cooling of condenser water of AC plant.
- 2) Type : Fibreglass reinforced plastic construction induced draught.
- 3) Quantity : Refer to Section-C of Specific Technical Requirements.
- 4) Place of installation : Refer to Section-C of Specific Technical Requirements.

B. DESIGN DATA


- 1) Capacity at specified conditions. : To suit the system requirement.
- 2) Water flow rate : To suit the system requirement.
- 3) Design wet bulb temperature : 25 Deg. C.
- 4) Hot water inlet temperature : To suit requirement.
- 5) Cooled water temperature : To suit requirement.
- 6) Depth of sump Tank : As per manufacturer's standard.

C. MATERIAL

- 1) Sump tank & Casing : FRP
- 2) Louvers : FRP/PVC/Aluminium.
- 3) Type of fill : Non-combustible PVC/Eq.
- 4) Nozzles : Brass with chrome plating/polypropylene.
- 5) Ladder : Hot dip galvanized steel ladder for each tower.
- 6) Bird screen : 25 mm square made of GI/SS wire mesh of 16 gauge.
- 7) Fan impeller : Cast Aluminium Alloy/FRP propeller type and multi-blade aerofoil construction with adjustable pitch..
- 8) Supporting structure : MS with spray galvanization of epoxy painting.
- 9) Strainer : Plant strainer made of GI/SS wire mesh of 16 gauge.

D. ACCESSORIES

- 1) Make up connection : Yes.


Varun Jain


S A Khan


Praveen Kishore



COOLING TOWER
DATA SHEET - A

VOLUME II-B


SECTION D

REV 00

DATE 17.09.2012

SHEET 2 OF 2

- 2) Quick fill connection : Yes.
- 3) Overflow & drain & blow down connection : Yes.
- 4) Access door in louvers/fan deck : Yes (if applicable).
- 5) Supports & supporting structure for mounting : Yes.
- 6) Level switch : Yes.
- 7) Rain protection for motor : Yes (suitable Canopy by Bidder)
- E. ELECTRICAL DATA
- i) Power supply : 415 V \pm 10%/50 Hz \pm 3%/3 phase.
- ii) Motor : As per specification attached.
- F. INSPECTION & TESTING : As per approved quality plan.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION
LOW PRESSURE AIR DISTRIBUTION
SYSTEM

SPECIFICATION NO.PES-553-07

VOLUME II B


SECTION D

REV. 02

DATE: 17.09.2012

SHEET 1 OF 9

STANDARD TECHNICAL SPECIFICATION
FOR
LOW PRESSURE AIR DISTRIBUTION SYSTEM


Varun Jain


S.A. Khan


Praveen Kishore



TECHNICAL SPECIFICATION
LOW PRESSURE AIR DISTRIBUTION
SYSTEM

SPECIFICATION NO.PES-553-07

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 2 OF 9

1. GENERAL

1.1 This specification covers the design, manufacture, construction features, installation, inspection testing and air balancing of air distribution system upto a total pressure of 95mm w.g. The specification is intended to cover the air distribution for air conditioning system and ventilation system not involving localised exhaust.

2. CODES AND STANDARDS

2.1 The design, construction and performance of complete system shall conform to all currently applicable statutes, regulations, safety codes in the locality where the equipment are to be installed

2.2 Unless specified otherwise the equipments shall generally conform to latest applicable Indian Standards. Nothing in this specification shall be construed to relieve the vendor of this responsibility. In particular the equipment shall generally conform to latest editions by the following standards:-

- a) IS: 655 - Specifications for metal air ducts.
- b) IS:277 - Specifications for galvanised steel sheets.
- c) IS:737 - Specification for wrought aluminium and aluminium alloy sheet and strip.

3. MATERIAL

3.1 Metal air ducts shall be either of galvanised steel sheets or aluminium sheets, as indicated in data sheet-A.

3.2 The rolled steel sheets before galvanising shall be properly annealed or normalised so as to allow fabrication of ducts without developing cracks. Zinc coating on the steel shall be as per technical requirement refer to Section-C of Specific Technical Requirements.

3.3 The aluminium sheets shall be of grade S1C or NS3 and shall be suitable for duct fabrication work as per IS-737 latest

4. CONSTRUCTION/FABRICATION

4.1 The thickness of sheets, the type of bracing and other fabrication details shall generally conform to requirements given hereunder unless specified otherwise in data sheet A and/or indicated on drawings.

4.2 RECTANGULAR DUCTS

4.2.1

S.No.	Max Side	Sheet Thickness	Type of transverse	Bracings
-------	----------	-----------------	--------------------	----------

Varun Jain

S A Khan

Praveen Kishore



TECHNICAL SPECIFICATION
LOW PRESSURE AIR DISTRIBUTION SYSTEM

SPECIFICATION NO.PES-553-07

VOLUME II B

SECTION D


REV. 02

DATE: 17.09.2012


SHEET 3 OF 9

		(mm) GI	(mm) AI	Joint connections	
a)	Up to 600	0.63 (24G)	0.80	S-drive, pocket or bar slips or flanged joints on 2.5m centres	None
b)	601 to 750	0.63 (24G)	0.80	S-drive, 25mm pocket or 25mm bar slips or flanged joints on 2.5m centres	25x25x3 mm MS angles, 1.2m from joints
c)	751 to 1000	0.80 (22G)	1.00	S-drive, 25mm pocket or 25mm bar slips or flanged joints on 2.5m centres	25x25x3 mm MS angles, 1.2m from joints
d)	1001 to1500	0.80 (22G)	1.00	40x40x3mm MS angle, flanged connections or 40mm pocket or40mm bar slips with 35x3mm bar reinforcing on 2.5m centres	40x40x3 mm MS angles, 1.2m from joints
e)	1501 to2250	1.00 (20G)	1.50	40x40x3mm MS angle, flanged connections or 40mm pocket or40mm bar slips, 1M maximum centres, with 35x3mm bar reinforcing	40x40x3 mm diagonal angles or 40x40x3mm angles, 600mm from joints
f)	2251 & above	1.25 (18G)	1.80	50x50x3mm MS angles,connections or 40mm pocket or 40 mm bar slips, 1M maximum centres with 35x3mm bar reinforcing.	50x50x3mm diagonal angles or 50x50x3mm angles 600 mm from joints.
g)	No bracing is required if transverse joints are less than 600mm apart				
h)	For ducts larger than 2250mm, special handling and supporting methods shall be provided as per the approval of Purchaser				

- 4.2.2 All rectangular ducts having either dimension larger than 450mm shall be cross broken except these ducts which are insulated with sand cement plaster. Air outlet connections on ducts need not be cross broken.
- 4.2.3 The seams on duct cones shall be of Pittsburgh type. Longitudinal seams shall be smooth inside the ducts.
- 4.2.4 The flanges used for transverse joints shall be joined together with GI bolts (grade 4.6) and nuts spaced at 125mm centres as per following:
- Upto 1000mm - 6 mm dia GI bolts
 - 1001 to 1500 - 8 mm dia GI bolts
 - 1501 and above - 10mm dia GI bolts


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION
LOW PRESSURE AIR DISTRIBUTION SYSTEM

SPECIFICATION NO.PES-553-07

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 4 OF 9

- 4.2.5 The MS angle flanges shall be connected to ducts with rivets at approx. 100mm centres. The flanged joints shall have 6mm thick felt packing stuck to flanges with shellac varnish. The holes in the felt packing shall be burnt through. The ducts are to be tapped 6mm across the MS flanges.
- 4.2.6 MS angles used for bracings shall be tack welded to the ducts or rivetted at 125mm centres, as applicable.

4.3 ROUND DUCTS

4.3.1

S.No.	Duct dia-mm	Sheet Thickness		Reinforcing
		(mm)	(mm)	
		GI	Al	
a)	Up to 150	0.63 (24G)	0.80	None
b)	151 to 600	0.80 (22G)	1.00	None
c)	601 to 1000	1.00 (20G)	1.50	40x40x3mm girth MS
d)	1001 to 1250	1.00 (20G)	1.50	40x40x3mm girth MS angles at 2.0 meter centres
e)	1251 & above	1.25 (18G)	1.80	40x40x3mm girth MS angles at 1.2m centres

- 4.3.2 The seams on round ducts may be continuously welded or grooved longitudinal seam. In case of welding of GI sheet, zinc rich paint shall be applied on the welded zone.
- 4.3.3 Round ducts shall either be joined by welding or the ducts shall be swedged 40mm from the ends such that larger end will butt against the swedge and is held in place with sheet metal screws.

4.4 DUCT SUPPORTS

Unless specified otherwise on drawings, rectangular ducts with larger side of 2250mm or above shall be supported by 15mm MS rods and 50x50x3mm and MS angles while those below 2250 mm shall be supported by 10mm MS rods and all angles shall be given a coat of primer paint. The duct supports shall be at a distance not exceeding 1800mm. The MS rods shall be fixed to MS angle cleats, which in turn are fixed to ceiling slab by suitable anchor fasteners. All anchor fasteners, MS angle cleats, coach screws, hooks and other supporting material required shall be provided by vendor.

However, If ducts are thermally insulated, the MS angles and supports shall not be in

Varun Jain

S A Khan

Praveen Kishore



TECHNICAL SPECIFICATION
LOW PRESSURE AIR DISTRIBUTION
SYSTEM

SPECIFICATION NO.PES-553-07

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 5 OF 9

direct contact with ducts, for which purpose wooden pieces/ Resin bonded fibre glass sheets (50 mm thick) shall be used in between.

4.5 FLEXIBLE CONNECTIONS

Wherever the sheet metal ducts connects to intake or discharge of fan units a flexible connection of at least 150mm width made by closely woven double layer Fire resistant or canvas shall be provided. The same shall be attached to angle iron frames on equipment and to similar frame on duct or casing by means of a steel band 9r (or) collar fitting over the end of the flexible connection and bolted through angle iron frame so as to clamp securely between the band and the angle frame.

4.6 TRANSFORMATIONS AND BREACHES

All curves, bends, offsets and other transformations shall be made for easy and noiseless flow of air. The throat of every branch duct shall be sized to have a velocity not exceeding that in the main duct to which the branch is connected.

4.7 CAULKING

Wherever duct passes through wall, the opening between masonry and duct work shall be neatly caulked or sealed to prevent movement of air from one space to adjoin by space with a rated fire resistant material.

4.8 EASEMENT

Normally pipe hangers, light fitting rods etc. shall not be allowed to pass through the ducts. Wherever, It becomes absolutely essential to pass these hangers/rods etc. Through the ducts, prior approval of purchaser shall be taken and light streamlines easement around the same shall be provided to maintain smooth air flow.

4.9 ACCESS DOORS

Access doors shall be provided in ducts, plenums etc. on both sides to allow access and servicing of equipment viz. pipes, dampers, coils, valves, heaters etc.


All access doors shall be adequately sized and lined suitably with felt to prevent air leakage. The doors shall be of built-up construction, structurally strong and shall have at least two hinges each, and shall be with two rust proof window sash locks of approved type. All doors shall be so set as to flush with outer finish of duct insulation etc.

4.10 DAMPERS AND SPLITTERS


4.10.1 Dampers and splitters shall be provided at suitable points for proportional volume control of the system. Splitters and dampers shall be made of minimum 18 gauge GSS of quadrant type with locking device mounted outside the duct at accessible location.

4.10.2 FIRE DAMPERS

Fire dampers shall be provided as specified in Data Sheet -A and shall be installed at locations indicated on drawings and/or as required/approved by purchaser, including all openings in passage of duct work through fire walls and floors etc. The fire damper shall be of electrical type with damper motor actuated by thermal


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION
LOW PRESSURE AIR DISTRIBUTION SYSTEM

SPECIFICATION NO. PES-553-07

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 6 OF 9

sensor or fusible link type.

4.10.3 VANES

Unless otherwise shown in the drawings all elbows shall be such that the throat radius is 75% of the duct width. In case throat radius is smaller, suitable single thickness vanes of approved details shall be provided.

4.10.4 FLASHING

For the ducts penetrating roofs or outside walls, provision of flashing shall be made by the ducting vendor.

4.11 DIFFUSERS AND GRILLS

The type and quantity of diffusers and grills is indicated on enclosed drawings/data sheet A. The size/quantity of diffusers/ grills indicated in the drawing/data sheet is indicative and is for vendor's reference purpose only. Vendor shall ensure that the diffusers/grills offered are of requisite capacity, throw and terminal velocity. The pressure drop and noise levels shall be as per data sheet. A enclosed. The diffusers/grills shall be approved by purchaser.

Unless specified otherwise the diffusers/grills shall be of mild steel and painted with two coats of primer paint. Supply air grills shall be complete with volume control dampers. Supply air grills shall be double deflection type while Return Air grills can be single deflection type. Ceiling outlets/diffusers shall have volume control dampers, fixed grids and blanking baffles. All volume control dampers shall be operated by a key from the front of grills/diffusers.

Suitable vanes shall be provided in duct collars to have uniform air distribution. Blank-off baffles wherever required, shall also be provided.

4.12 PLENUMS AND RA BOXING

All plenum chambers and/or connections to fans, dampers etc. shall be constructed in 18 gauge GI sheet. supported on 40x40x6mm MS angle frames. All vertical angles shall be riveted at approx. 125mm. centres to the casing. Suitable caulking compound (Pecora or equivalent) shall be inserted between the base of the angle and all masonry construction to which angles are fastened.


Return air boxing requirements if any are indicated in data sheet-A and the same shall be provided by vendor. The return air box shall be fabricated out of GI sheets shall be insulated with 25mm thick fibre-glass.

4.13 ACCOUSTIC LINING


The ducts shall be lined acoustically from inside as given in data- sheet A and/or section C of the specification.

4.14 PAINTING

Wherever specified the ducts shall be painted or lined with suitable anti-corrosive paint/ lining as per approval of purchaser. In particular the ducts coming in contact with acid fumes shall be epoxy coated, inside and outside.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION
LOW PRESSURE AIR DISTRIBUTION SYSTEM

SPECIFICATION NO.PES-553-07

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 7 OF 9

4.15

THERMAL INSULATION

Thermal insulation shall be as per data sheet - A and the insulation shall conform to enclosed spec. no. PES-553-08.

5.

INSPECTION AND TESTING

5.1

INSPECTION & TESTING DURING FABRICATION

5.1.1

Visual inspection of GI sheets and angles, channels etc. – dents, black spots, chipping of zinc coating, white dust on galvanised sheets shall be avoided. Pitting, lamination in angles and channels shall be avoided.

5.1.2

Galvanised sheets - Test certificate shall be furnished for visual check, coating thickness, adhesion test, sheet thickness, uniformity of coating.

5.1.3

Check for dimensions & mass as per latest IS-277.

5.1.4

Check for defect, twists, ungalvanised spots as per IS-2629.

5.1.5

Bend test & wrapping test as per IS-277.

5.1.6

Zinc coating test on samples as per IS-6745.

5.2

INSPECTION & TESTING AT SITE.

5.2.1

The duct branches, elbows etc. shall be inspected and the joints and connections etc, are to be checked before they are assembled in position.

5.2.2

After completion, all duct systems shall be checked and tested for air leakage, tightness, velocity, pressure drop, vibration and noise etc.

6.


BALANCING

6.1.1


The entire air distribution system shall be balanced by vendor to supply the air quantities as required in various rooms so as to maintain the requisite temperature and air flow in the conditioned spaces. The final balance of air quantities through each grill/diffuser etc. shall be recorded and submitted to purchaser for approval. Proper steps shall be taken to have a uniform temperature in all enclosures, with utmost care for noise level to be within tolerance limit

6.1.2

All instruments required for testing/balancing etc. of the air distribution system shall be provided by vendor.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION
LOW PRESSURE AIR DISTRIBUTION
SYSTEM

SPECIFICATION NO.PES-553-07

VOLUME II B

SECTION D


REV. 02

DATE: 17.09.2012


SHEET 8 OF 9

7. DATA TO BE FURNISHED BY VENDOR AFTER THE AWARD OF CONTRACT

- 7.1 Fabrication drawings of ducts and grilles, louvers, dampers, etc, including typical details of grilles dampers etc.
- 7.2 Test certificates in line with scope of inspection.
- 7.3 Other dimensional drawings & documents as may be required by purchaser for better understanding of the system & for preparation of operation, maintenance & instruction manual.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION
LOW PRESSURE AIR DISTRIBUTION
SYSTEM

SPECIFICATION NO.PES-553-07


VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 9 OF 9


Varun Jain


S A Khan


Praveen Kishore



LOW PRESSURE AIR DISTRIBUTION SYSTEM

DATA SHEET - A

VOLUME II-B

SECTION D

REV 00

DATE 17.09.2012

SHEET 1 OF 2


Description

Data


- | | |
|--------------------------------|---|
| 1. General (List of areas) | : As per Specification/Tender drawing. |
| 2. GSS Duct Work | |
| a) Type | : GSS as per IS: 277
(Zinc coating as per Section-C of Specific Technical Requirements.) |
| b) Size | : As per Section-C of Specific Technical Requirements and bill of quantity. |
| 3. Acoustic lining | : Up to 5m length from AHU Outlet. |
| 4. Special painting | : Galvanised. |
| 5. Thermal Insulation | : Required in supply air duct in AC entire length. |
| 6. Diffusers (Circular/Square) | |
| 300 mm size | } : Bidder to estimate as per drawings./specification.
All grille frame and louvers shall be manufactured of at least 16 SWG Aluminium |
| 350 mm size | |
| 450 mm size | |
| 550 mm size | |
| 600 mm size | |
| Any other size | |
| 7. SA grilles (for each size) | : To suit air flow as per System requirements / Tender Drawings. |
| 8. RA grilles (for each size) | : -do- |

NOTE:

1. Duct sheet thickness shall be as per IS-655
2. Opposed blade type volume control damper shall be provided at each supply air diffusers/grilles.
3. Bidder to provide suitable gasketing at each duct flange.
4. Fire damper shall be motor operated type, when otherwise specified under Section-C.
5. Access door in ducting system shall be provided as required.
6. MS Angle (painted) shall be used for duct supports etc.
7. Velocity thru duct shall normally not exceed 9.0 M/sec for Air conditioning system. Maximum velocity (outlet) for supply air diffuser shall not exceed 2.5 m/sec.


Varun Jain


S A Khan


Praveen Kishore



LOW PRESSURE AIR DISTRIBUTION SYSTEM

DATA SHEET - A

VOLUME II-B


SECTION D

REV 00

DATE 17.09.2012

SHEET 2 OF 2

8. All Grilles & diffusers shall be supported with frame. Frame etc. shall be supplied by bidder.


Varun Jain


S.A. Khan


Praveen Kishore



TECHNICAL SPECIFICATION
CENTRIFUGAL PUMPS

SPECIFICATION NO.PES-553-04

VOLUME II B


SECTION D

REV. 02

DATE: 17.09.2012

SHEET 1 OF 10

STANDARD TECHNICAL SPECIFICATION
FOR
CENTRIFUGAL PUMPS


Varun Jain


S.A. Khan


Praveen Kishore



TECHNICAL SPECIFICATION

CENTRIFUGAL PUMPS

SPECIFICATION NO.PES-553-04

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 2 OF 10

1.

GENERAL

1.1

This specification covers the design, material, constructional features, manufacture, assembly, inspection and testing at manufacturer's or his subcontractor's works, suitable painting requirements of centrifugal pumps and drives complete with all accessories as specified hereinafter.

2.

CODES AND STANDARDS

2.1

The design, manufacture, inspection, testing & performance of the pumps as specified hereinafter, shall comply with the requirements of the latest revision of the following standards as indicated below (as applicable):

2.1.1

IS-1520 : Horizontal centrifugal pumps for clear, cold and fresh water.

2.1.2

IS-5120 : Technical requirements - Rotodynamic special purpose pump.

2.1.3

IS-1710 : Vertical turbine pumps for clear, cold and fresh water.

2.1.4

BS - 599 : Method of testing Pumps.

2.1.5

PTC - '6' : Centrifugal Pumps Power test code

2.1.6

API - 610


2.1.7

Hydraulic Institute Standards of USA


Wherever standards for certain aspects materials etc., not mentioned, the same shall be as per the applicable Indian or International standards.

2.2

In case of any conflict between the above codes/standards and this specification, the later shall prevail and in case of any further conflict in this matter, the decision of Purchaser's engineering shall be final and binding.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION

CENTRIFUGAL PUMPS

SPECIFICATION NO. PES-553-04

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 3 OF 10

3. DESIGN REQUIREMENTS

- 3.1 The pumps shall be of heavy duty suitable for long periods of uninterrupted service and shall be standard product of the manufacturer thoroughly proven for satisfactory performance and reliability.
- 3.2 The materials of construction of various components shall be as indicated under Data Sheet-A and where not specified to the applicable Indian/British/American standards..
- 3.3 All pressure containing components including the pump casing, nozzles and stuffing box housing shall be designed, fabricated and tested in accordance with applicable Indian standards if not specified otherwise.
- 3.4 The pump shall be suitable for handling the fluid as specified in Data Sheet-A.

4. CONSTRUCTION FEATURES:

4.1 PUMP CASING


- 4.1.1 Pump casing may be axially or radially split or barrel type construction as specified in the pump data specification sheet. The casing shall be designed to withstand 1.5 times the maximum pressure developed by the pump at the pumping temperature.
- 4.1.2 Pump casing shall be provided with adequate number of vent and priming connections with valves, unless the pump is made self venting & priming. Casing drain, as required, shall be provided complete with drain valves or plugged with threaded plugs as required.
- 4.1.3 Pump shall preferably be of such construction that it is possible to service the internals of the pump without disturbing suction and discharge piping connections.
- 4.1.4 Under certain conditions, the pump casing nozzles will be subjected to reactions from external piping. Pump design must ensure that the nozzles are capable of withstanding external reactions not less than those specified in API-610

4.2 IMPELLER


- 4.2.1 Unless specifically indicated under Data Sheet-A enclosed, the pump impellers shall be of closed vane type. The impellers shall be secured to the shaft and shall be retained against circumferential movement by keying, pinning or lock rings. Impellers shall be checked for eccentricity and statically and dynamically balanced individually. The assembled rotor shall be dynamically balanced and checked for eccentricity. Supplier shall ensure during balancing that wall thickness of impeller vane, shroud etc is maintained above the minimum thickness requirement as per design.

4.3 WEARING RING

- 4.3.1 Renewable wearing rings for the casing and/or the impellers and renewable shaft sleeves, shall be provided for all pumps. Length of the shaft sleeves must extend


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION

CENTRIFUGAL PUMPS

SPECIFICATION NO. PES-553-04

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 4 OF 10

beyond the outer faces of gland packing or seal and plate so as to distinguish between the leakage between shaft & shaft sleeve and that past the seals/gland.

4.4 SHAFT

4.4.1 Shaft size selected shall take into consideration the critical speed which shall be away from the operating speed as recommended in applicable Code/Standard. The critical speed shall also be at least 10% away from runaway speed.

4.5 BEARING

4.5.1 Bearings and hydraulic devices, of approved make, (if provided for balancing axial thrust) of adequate design shall be furnished for taking the entire pump load arising from all probable conditions of continuous operation throughout its Range of Operation and also at the shut off condition. The bearing shall be designed on the basis of 20,000 working hrs minimum for the load corresponding to the duty point. Proper lubricating arrangement for the bearings shall be provided. The design shall be such that the bearing lubricating element does not contaminate the liquid being pumped. Where there is a possibility of liquid entering the bearing, suitable arrangement in the form of deflectors or otherwise shall be provided ahead of bearing assembly. Bearings shall be easily accessible without disturbing the pump assembly.

4.6 STUFFING BOX


4.6.1 Packed type stuffing boxes of adequate depth with lantern rings shall be provided to minimize the leakage. In all cases where the pump suction is below atmospheric pressure, the shaft packing shall be sealed by the liquid pumped by tapping off from the pump discharge itself and all pipes, valves, fittings etc., required for this shall be furnished by the manufacturer. Tubings used for connections shall be flexible metallic type preferably SS-304/316. PVC/ rubber tubings are not acceptable.

4.7 SHAFT COUPLING


4.7.1 The pumps shall be directly coupled to their drives through heavy-duty flexible coupling. Suitable sturdy coupling guards of min. 1.5 mm MS sheet/ Aluminium sheet shall be provided along with the coupling. The pump and its drive motor shall be mounted on a common base plate.

4.8 BASE PLATE AND SOLE PLATE

4.8.1 Unless otherwise stated the data specification sheet, a common base plate mounting both for the pump and drive shall be furnished. The base plate shall be of rigid construction, suitably ribbed and reinforced. Base plate and pump supports shall be so constructed and the pumping unit so mounted as to minimize misalignment caused by mechanical forces such as normal piping strain, hydraulic piping thrust, etc. Suitable drain taps and drip lip shall be provided. The external corners of the base plate shall be rounded to avoid sharp corners. Drilled holes shall have sufficient space around for proper seating of washer with nut. If required in the data specification sheet, steel sole plates shall be provided, below the base plate.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION

CENTRIFUGAL PUMPS

SPECIFICATION NO. PES-553-04

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 5 OF 10

4.9 PRIME MOVER

4.9.1 The drive motor selected shall conform to the requirements of the enclosed motor specifications.

4.10 LIFTING ARRANGEMENT

4.10.1 Each pump and motor shall incorporate suitable lifting attachments e.g. lifting lugs or eye bolts etc., to facilitate erection and maintenance..

5. PERFORMANCE REQUIREMENTS

5.1 The pump shall be designed to have best efficiency at the specified duty point. The pump set shall be suitable for continuous operation at any point within the Range of Operation as stipulated in the data specification sheets.

5.2 Pump shall have a continuously rising head capacity characteristics from the specified duty point towards shut off point, the maximum being at shut off. Power capacity characteristic will be non-overloading type i.e. 110% of the design flow the power required to drive the pump will be practically the same as that at the design flow.

5.3 Wherever specified in data sheet, pumps of each category shall be suitable for parallel operation. The head vs capacity, input power vs. capacity characteristics, etc., shall match to ensure equal load sharing and trouble free operation throughout the range.

5.4 The pump motor set shall be designed in such a way that there is no damage due to the reverse flow through the pump which may occur due to any malfunction of the system.

6. DRIVE RATING

6.1 The power rating of the drive shall be selected such that a minimum margin of 15% is available over the pump input power required at the rated duty point. However, the drive rating shall not be less than the maximum power requirement at any point within the 'Range of Operation' specified.


6.2 In cases where parallel operation of the pumps are specified the actual drive rating is to be selected by the bidder considering overloading of the pumps in the event of tripping of one of the operating pumps.

6.3 The bidder under this specification shall assume full responsibility in the operation of the pump and the drive as one unit.


7. SCOPE OF INSPECTION AND TESTING

7.1 CASTING

7.1.1 The Witnessing pouring and thereafter physical testing of castings of 'Critical' nature such as casings, impellers, diffusers. Castings shall have 'as cast' heat numbers


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION

CENTRIFUGAL PUMPS

SPECIFICATION NO. PES-553-04

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 6 OF 10

unless they require overall machining. For partially machined components manufacturer shall ensure availability of as cast heat nos. on unmachined area.

- 7.1.2 Identification and correlation with test reports for all tests as per the relevant material specifications for castings of 'Major' nature such as suction bell, discharge elbow, stuffing box, gland, wearing rings, shaft sleeves etc.
- 7.1.3 Foundry's conformity certificate for castings of 'Minor' nature such as base plates, covers etc.
- 7.1.4 Verification of Heat treatment charts (as applicable)
- 7.1.5 Castings may be required to meet NDT requirements such as Radiography, Magnetic Particle Testing or Dye-penetrant testing prior to Hydro-test as per requirements specified in Quality Plan.
- 7.1.6 Surface finish of Steel castings shall meet MSS SP-55.

7.2 FORGING


- 7.2.1 Identification and correlation with mill test certificates for all tests as per the relevant specifications for important forgings like casings, stage bodies, diffusers, shaft material.
- 7.2.2 Verification of heat treatment charts (time temperature) (as applicable).
- 7.2.3 Forgings may be required to meet NDT requirements such as Radiography, Magnetic Particle Testing or Dye-penetrant testing prior to Hydro-test as per requirements specified in Quality Plan.

7.3 FABRICATED ITEMS

- 7.3.1 Identification and correlation with mill test certificates for material of items such as discharge bellows, column pipes etc.
- 7.3.2 Approval of welding procedure specifications and qualifications of weld procedures and personnel as per ASME Sec IX.
- 7.3.3 Dye penetrant tests of weldment as per ASTM E-165 and acceptance norm as per ASME Sec.VIII, Div.1, Appendix 8
- 7.3.4 Verification of heat treatment charts (time temperature), (as applicable)
- 7.3.5 **Note:** For para 7.1.2, 7.2.1 and 7.3.1 above; in case correlating original test certificates are not available, material shall be identified by Main Vendor and test conducted at NABL approved Laboratory.

7.4 IN PROCESS INSPECTION AND TESTING

- 7.4.1 Identification Dye penetrant testing after machining for impellers including vanes, pump shaft, diffusers as per applicable code; in absence of which, as per ASTM E - 165. Permissible defects and acceptance norms need to be specified. On static parts acceptance norms are as per ASME Sec.III NB 2546.
- 7.4.2 Ultrasonic testing of dynamic duty component, i.e. pump shafts (50mm dia and above) and static duty forgings i.e. Barrel, casting (15mm and above wall thickness)


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION

CENTRIFUGAL PUMPS

SPECIFICATION NO. PES-553-04

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 7 OF 10

as per applicable code, in absence of which as per ASTM E388 and acceptance norms as stipulated hereunder. Probe shall be of min. 2 MHz frequency.

7.4.3 Acceptance norms for UT for dynamic duty components. the following defects are unacceptable

- a) Cracks, flakes, seams and laps
- b) Defects giving indications longer than that from a 4mm equivalent flaw.
- c) Group of defects with maximum indications less than that from a 4mm equivalent flaw, which cannot be separated at testing sensitivity, if the back echo is reduced to less than 50%.
- d) Defects giving indications of 2 to 4mm dia. equivalent flaw separated by distance less than four times the size of the larger of the adjacent flaw.

7.4.4 For static duty components - as per NB 2542.2 of ASME Sec. III

7.4.5 Hydro tests of all pressure parts such as casings, column pipes, discharge elbows etc., at two times duty point pressure or 1.5 time shut off pressure, whichever is higher for 30 min., without any leakage.

Note : In case the pump is required to boost certain pressure, the inlet pressure head shall also be taken into consideration to compute test pressures

7.4.6 Static and dynamic balancing of individual impellers and also assembled rotors as per V.D.I. 2060 Q 6.3 or ISO 1940 G 6.3.

7.5 PERFORMANCE TEST

7.5.1 Pump testing with unit supply motor as per specifications and acceptance norms cited elsewhere, in absence of which as per IS 5120 latest edition. Performance shall be checked for minimum of 7 points (including shut off head and over load) following characteristics shall be checked.

- a) Capacity V/s Head
- b) Capacity V/s Power absorbed by pump
- c) Capacity V/s pump efficiency

Note : For pump of fire protection system, performance test shall be conducted up to 150% of rated capacity.


7.5.2 NPSH test in case specifically mentioned elsewhere.

7.5.3 Vibration, noise level and temperature rise measurement. Noise level shall be within 85dB(A) at 1 metre distance. Vibration within satisfactory zone of VDI 2056 Group G machines. Temperature shall not exceed ambient + 40 deg. C.


7.5.4 Overall dimensions as per GA drawings. One pump/type/size assembly with job motor shall be mounted on base plate, provided the components are ordered on the same manufacturer.

7.5.5 Examination after selective opening up after running for pumps operating at speed over 1800 rpm and capacity exceeding 68M³/hr.

7.5.6 Painting and packing as per technical specification.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION

CENTRIFUGAL PUMPS

SPECIFICATION NO.PES-553-04

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 8 OF 10

7.6

TEST AT SITE

7.6.1

The pumps will be tested at site by the purchaser to verify their performance. If the pumps fail to operate smoothly or within the required performance all such deficiencies shall be rectified by the manufacturer by making suitable alternatives in the pump set and additional tests required to show the effect of such alterations shall be performed by him.

7.7

PERFORMANCE GUARANTEE

7.7.1


The vendor shall guarantee the material and workmanship of all components as well as the operation of the pump as per requirement of this specification. The vendor shall also guarantee for each pump the total dynamic head at the specified rated capacity and also corresponding efficiency, brake horse power and shut off head

8.


CLEANING, PROTECTION , PAINTING & PACKING

8.1

Before shipment of the equipment to be supplied under this specification the necessary cleaning, flushing etc., as per manufacturers standard/ as specified for the contract in Data Sheet A/ elsewhere shall be done to remove all dirts, scales etc. Shop coats of rust inhibiting paints, lacquers etc., shall be applied to various parts as per manufacturers standard/ as specified for the contract in Data Sheet A/ elsewhere. Flanges, inlet and outlet pipe, etc shall be protected. Packing shall be done as per manufacturers standard/ as specified for the contract in Data Sheet A/ elsewhere.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION

CENTRIFUGAL PUMPS

SPECIFICATION NO.PES-553-04

VOLUME II B


SECTION D

REV. 02

DATE: 17.09.2012

SHEET 9 OF 10

- 9. DRAWINGS, TECHNICAL DOCUMENTS AND OTHER INFORMATION REQUIRED WITH THE PROPOSAL**
- 9.1 Fully dimensioned outline GA drawings of the pump motor assembly unit for each type and size offered. This drawing should include:
- Foundation base plate and sole plate details as applicable
 - Civil foundation and anchor bolts details and loading data
 - Minimum submergence required for the pump (if applicable)
- 9.2 Cross sectional drawing of the equipment showing the details of assembly of components and their material of construction and/ make with standard applicable codes.
- 9.3 Performance characteristics (Discharge capacity vs head, BHP and efficiency of the pumps.
- 9.4 Motor speed torque curve superimposed on pump speed torque curve. Required NPSH of pump.
- 9.5 Experience list about the supply and successful operation of similar pumps for similar application.
- 9.6 A comprehensive write up or brochure on the details of manufacturing and testing facilities in the shop of the manufacturer.
- 9.7 Quality plan for the equipment being offered, in BHEL format as practiced in the manufacturer's works and Field Quality Plan for receipt, storage erection, commissioning & testing at site.
- 9.8 Data sheet-B with all the particulars filled in.
- 10. MANUFACTURERS NAME AND TAG. PLATES**
- 10.1 Each pump shall have a permanently attached brass/ Stainless steel tag on the body indicating the following information both in Hindi and English:
- Manufacturer's name and trade mark.
 - Design Capacity and Head.
 - Design.
 - Purchaser's tag no. as furnished during the contract. The purchaser's tag no. will be indicated by the Purchaser on the drawing submitted for approval by the vendor.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION

CENTRIFUGAL PUMPS

SPECIFICATION NO.PES-553-04

VOLUME II B

SECTION D


REV. 02

DATE: 17.09.2012


SHEET 10 OF 10

11. DRAWINGS/DOCUMENT/DATA REQUIRED AFTER AWARD OF CONTRACT

- 11.1 Certified GA drawings of pump motor assembly weights, crane.
- 11.2 Detailed cross sectional drawings of the pump and motor assembly and all equipment & accessories supplied under the this specification along with details of material of construction with applicable standard codes.
- 11.3 Foundation drawings with details of foundation pocket indicating static as well as dynamic load and other data with dimensions.
- 11.4 Certified characteristics curves (discharge capacity vs. head, BHP and efficiency) of each type of pump and motor.
- 11.5 Material and other test certificates as required by the application clauses of this specification.
- 11.6 Motor speed torque curves super imposed on pump speed torque curves.
- 11.7 Quality plan along with complete details of testing and inspection requirements of centrifugal pumps in BHEL format. Vendor shall also furnish Field Quality Plan.
- 11.8 Installation , operation and maintenance manual.
- 11.9 Other drawings and data, if necessary.


Varun Jain


S A Khan


Praveen Kishore



CENTRIFUGAL PUMPS
DATA SHEET - A

VOLUME II-B

SECTION D

REV 00


DATE 17.09.2012

SHEET 1 OF 2


DESCRIPTION

DATA

- | | |
|------------------------------------|---|
| 1. Designation | : Condenser water and Chilled Water pumps for AC plant. |
| 2. Type | : Horizontal, Centrifugal pump or vertical split type casing pump . |
| 3. Quantity | : Refer to section-C of Specific Technical Requirements |
| 4. Installation | : On floating type foundation. |
| 5. Fluid to be handled | : Water |
| 6. Temperature of fluid | : To suit. |
| 7. Capacity M3/hr and TDH at rated | : To suit system requirements but head shall not be less than 25 MWC. |
| 8. Duty | : Continuous (24 hours / day) |
| 9. Suction condition | : Flooded |
| 10. Type of drive | : Direct |
| 11. Prime Mover | : LV AC motor |
| 12. Maximum speed | : 1500 RPM |
| 13. Type of lubrication | : Grease Lubrication |
| 14. Material | |
| a) Impeller | : Bronze to Grade IS: 318 Grade 2 |
| b) Pump shaft | : EN - 8 / Equivalent (Approved). |
| c) Casing | : CAST IRON TO IS: 210 Grade - 260. |
| d) Wearing ring | : Bronze to Grade IS:318 GR-2, Renewable type. |
| e) Shaft Sleeve | : -do- |
| f) Base plate | : Cast Iron to Grade FG-200 IS-210/M.S. fabricated. |
| g) Bolt and nuts. | : MS |
| h) Stuffing Box gland/bush case. | : Deep Bronze packing to be renewable with case. |


Varun Jain


S A Khan


Praveen Kishore



CENTRIFUGAL PUMPS

DATA SHEET - A

VOLUME II-B

SECTION D

REV 00

DATE 17.09.2012


SHEET 2 OF 2

- i) Stuffing box Packing. : Flexible Graphite or PTFE (Asbestos shall not be used)
- j) Pump motor coupling. : Flexible.

15. ACCESSORIES REQUIRED:-

The following accessories shall be provided by the bidder for each pump:

- a) Suction & Discharge pressure gauges. : Yes.
- b) Vent connection : Yes.
- c) Drain piping up to common drain point in plant room. : Yes
- d) Companion flanges. : Yes
- e) Common base plate. : Yes.
- f) Suction strainer. : Yes
- g) Isolating valve : Yes
- h) NRV at pump outlet at inlet/outlet : Yes
- i) Any special requirements : The Chilled Water pumps shall be suitably insulated as per spec.
- j) Inspection & Testing : As per specification enclosed elsewhere.


Varun Jain


S A Khan


Praveen Kishore



**TECHNICAL SPECIFICATION
FOR
PACKAGE CONDITIONING UNIT**

SPECIFICATION NO.PES-553-05

VOLUME II B


SECTION D

REV. 02

DATE:17.09.2012

SHEET 1 OF 6

**STANDARD TECHNICAL SPECIFICATION
FOR
PACKAGE CONDITIONING UNIT**


Varun Jain


S.A. Khan


Praveen Kishore



**TECHNICAL SPECIFICATION
FOR
PACKAGE CONDITIONING UNIT**

SPECIFICATION NO.PES-553-05

VOLUME II B

SECTION D

REV. 02

DATE:17.09.2012

SHEET 2 OF 6

1 **GENERAL**

1.1 This specification covers the design, manufacture, inspection and testing at the manufacturer's works and suitable packing delivery and testing of the packaged air conditioning unit.

2 **CODES AND STANDARDS**

2.1 The design, manufacture, inspection, testing and performance of the packaged type air conditioning unit shall comply with all statutes, regulations and safety codes currently applicable in the locality where the equipment will be installed. The equipment shall also conform to the latest editions of the codes and standards specified herein under. Nothing in this specification shall be construed to relieve the vendor of this responsibility.

In particular, the packaged air conditioning Unit (max 7.5 TR capacity, ductable or non ductable type) or cassette type (up to 5 TR) shall conform to the latest editions of the following standards:

- 2.1.1 I.S.660 : Safety code for Mechanical Refrigeration.
- 2.1.2 I.S.5111 : Code of practice for measurement, and testing of refrigerant compressor.
- 2.1.3 I.S.659 : Safety code for air conditioning.
- 2.1.4 I.S.2494 : V Belt for industrial purpose.
- 2.1.5 I.S.3142 : V grooved pulleys for V Belts.
- 2.1.6 I.S.4503 : Shell and tube type heat exchanger.
- 2.1.7 ARI 210 : Standard for/unitary air conditioning equipment
- 2.1.8 ARI 270 : Standard for application installation and servicing of unitary equipment.
- 2.1.9 ASHRAE-37 : Standard methods of testing for rating unitary air conditioning and heat pump / equipment.
- 2.1.10 ANSI-B9-1 : Safety code for mechanical refrigeration.


3 **DESIGN AND CONSTRUCTIONAL REQUIREMENTS**

3.1 Compressor

The compressor shall be hermetic or semi-hermetic or screw rotary type or scroll type. The same shall be suitable for R410A/R407C/R134A refrigerant. The compressor shall be mounted on anti-vibration spring/rubber pads and shall be positioned in such a way that it is freely accessible with sufficient space all around for easy maintenance. Safety controls like High and Low pressure cut-out overload and single phasing protection for the motors shall be provided. A crankcase heater shall also be provided, if considered necessary by the vendor.

3.2 **CONDENSING UNIT**

Shell and tube type water cooled condenser or air cooled condenser with adequate area shall be provided as specified in Data Sheet-A. The condensing unit shall be complete with


Varun Jain


S A Khan


Praveen Kishore



**TECHNICAL SPECIFICATION
FOR
PACKAGE CONDITIONING UNIT**

SPECIFICATION NO.PES-553-05

VOLUME II B

SECTION D

REV. 02

DATE:17.09.2012

SHEET 3 OF 6

multipass heads and shall be fitted with the following:

- 3.2.1 Hot gas inlet and liquid outlet connection with shut off valve for liquid.
- 3.2.2 Drain plug, air vent and test valve.
- 3.2.3 Water inlet and outlet connection with thermowell and suitable cocks respectively.
- 3.2.4 Relief valve and air purge valve (Fusible plug in place of relief valve not acceptable)
- 3.2.5 Any other accessory as recommended by the manufacturer for proper functioning of the equipment.

3.3 AIR HANDLING FAN

The air handling fan shall be of the centrifugal type and with forward curved blades. This shall be driven by means of a three phase induction motor through V belt drive. The fan static pressure shall be selected for passing air through high efficiency absolute filters, if specified in Data Sheet-A.

3.4 FILTERS

Filters shall be of dry panel type and shall be cleanable. The velocity of air across the filters shall not exceed 1.75m/sec (350FPM).

3.5 COOLING COIL

The cooling coil shall be of direct expansion type and shall be made of heavy gauge copper with aluminium fins. The fins shall be bonded to the copper tubes under hydraulic pressure. A distributor shall be provided for feeding the refrigerant to different sections of the coil. Rows shall be staggered in the directions of airflow. The velocity of air across coil shall not exceed 2.5M/Sec. (500 FPM).

3.6 CONTROLS

All necessary controls and accessories like thermostatic expansion valve, refrigerant solenoid valve, distributor, filter drier in the liquid lines, shut off valves, HP/LP cut out for compressor, thermostat with adjustable settings, overload and single phasing preventer for motor etc. are to be provided. The microprocessor based control panel shall be provided outside the packaged unit on one side. The control panel shall generally be in line with the specification for control panels given elsewhere.


The control shall be so interlocked that the fan shall be started independently first, and then only the compressor. Tripping of the compressor by the thermostat or compressor cut outs shall not trip the fan. The thermostat setting shall be adjustable

3.7 REFRIGERANT PIPING


The refrigerant piping shall be either heavy gauge copper as furnished in Data Sheet-A. The piping shall be completely factory assembled, pressure tested, dehydrated and initially charged with FREON gas and compressor oil. The line accessories shall include liquid line shutoff valve dehydrator, strainer, flow indicator and distributor etc.

3.8 CABINET

All the equipments, except control panel, mentioned above shall be provided within a heavy gauge sheet metal cabinet, of floor/ wall mounted type. This shall be given two coats of anti-corrosive and rust proof paint, finished with two coats of final paint . Painting shall be as per manufacturers std unless specified otherwise in data sheet 'A'. The interior of the cabinet shall be provided with thermal and acoustic insulation of minimum 25mm thick. The insulating material shall be fire proof.


Varun Jain


S A Khan


Praveen Kishore



**TECHNICAL SPECIFICATION
FOR
PACKAGE CONDITIONING UNIT**

SPECIFICATION NO.PES-553-05

VOLUME II B

SECTION D

REV. 02

DATE:17.09.2012

SHEET 4 OF 6

The front and back side of the cabinets shall be easily removable providing maintenance to all the interior parts.

All the electric wires within the cabinet shall run in flexible conduits and carry identification tags. The bottom side of the panel shall be specially ribbed to take care of the transportation.

3.9 OTHER ACCESSORIES

Each packaged air conditioner shall be provided with required number of neoprene rubber isolating pads.

4 CONTROL AND INTERLOCK REQUIREMENTS

The compressor shall have all protective devices like HP/LP cutouts, overload protection for the motor, single phasing preventor for motor etc.

The interlocking requirement shall be as indicated below:

4.1 The compressor shall not start, unless condenser water flow is achieved for water cooled condenser. The condenser flow shall be sensed by means of a flow switch.

4.2 The compressor shall not start unless the evaporator fan is started.

4.3 The tripping of compressor on HP/LP, overload or on thermostat shall not trip the fan.

4.4 Strip heater (if provided in the ducting system) shall not be switched on, unless the evaporator fan is started and airflow is established. For this purpose, an air stat on flow switch shall be used. The heater shall be separately controlled by humidistat/thermostat

4.5 A humidifying package, if specified in data sheet A, shall be controlled by humidistat.

5 TEST AND INSPECTION

5.1 Inspection and Testing at Manufacturer's Works

5.1.1 static and dynamic test for fans

5.1.2 Hydrostatic static test on condenser and cooling coil.

5.1.3 vacuum/pressure test for the complete refrigeration circuit.

5.1.4 Visual and Free running test of the packaged unit on test bed.

5.1.5 Free running test on compressor.

5.1.6 AIR CAPACITY WITH ANEMOMETER.

5.1.7 NOISE LEVEL- ≤ 85 dB(A).

5.1.8 Other tests as per approved qualities plan/scope of inspection.


5.2 Inspection and Testing at Site

5.2.1 Performance testing of the packaged unit for 72 hours in summer / monsoon & 24-hours in winter- Up-to 3 TR (individual M/c capacity) inside room temperature (Dry & wet bulb) will be checked with all machines in the room operating.


The actual days of testing shall be mutually agreed. During the above testing, the following readings shall be taken to compare the same with guaranteed performance data.

5.2.1.1 Condenser inlet and outlet pressure and temperature

5.2.1.2 Entering and leaving air temperature of the cooling coil air filters.


Varun Jain


S A Khan


Praveen Kishore



**TECHNICAL SPECIFICATION
FOR
PACKAGE CONDITIONING UNIT**

SPECIFICATION NO.PES-553-05

VOLUME II B

SECTION D

REV. 02

DATE:17.09.2012

SHEET 5 OF 6

- 5.2.1.3 Motor current for the compressor and blower.
- 5.2.1.4 Air quantity delivered by the fan. This shall be computed by adding air quantity leaving all the grilles entering the air filters.
Room temperature (Dry & wet bulb)
- 5.2.1.5 Test to ensure all controls and safety instruments are working properly.
During the above testing, noise level also will be checked to ensure that the same are within acceptable limits. Any undue vibration detected physically will be corrected.
All tools and instruments required for the above testing will be provided by the vendor.

6

PAINTING:

The packaged unit shall be given two coats of primer paint finished with two coats of finish paint as per Manufacturers std. unless specified otherwise elsewhere/ Data sheet 'A'. The colour of finish paint will be as specified in Data Sheet-A.

7

GUARANTEES


The package unit shall be guaranteed for performance measured in terms of the inside temperature maintained.

The packaged unit shall also be free from any manufacturing defects and shall be guaranteed as per contract after the first test as per 5.0 is successfully carried out, and the plant taken over by the purchaser.


8

NAME PLATES

Suitable Name plate as per Data Sheet 'A', depicting the equipment number as designated in Data Sheet A shall be provided for each packaged unit and screwed to a prominent position on the packaged unit.


Varun Jain


S A Khan


Praveen Kishore



**TECHNICAL SPECIFICATION
FOR
PACKAGE CONDITIONING UNIT**

SPECIFICATION NO.PES-553-05

VOLUME II B

SECTION D


REV. 02

DATE:17.09.2012

SHEET 6 OF 6

9. DATA TO BE FURNISHED AFTER AWARD OF CONTRACT

- 9.1 Final technical data as per Data Sheet-B
- 9.2 G.A. and interior view of packaged unit
- 9.3 Electrical wiring diagram
- 9.4 Catalogues for all controls
- 9.5 O & M Manual
- 9.6 Erection Manual


Varun Jain


S A Khan


Praveen Kishore



PACKAGE-CONDITIONING UNIT
DATA SHEET - A

VOLUME II-B

SECTION D

REV 00

DATE 17.09.2012

SHEET 1 OF 1

DESCRIPTION

DATA

- | | | |
|-----|--|---|
| 1) | Capacity of the unit at operating conditions. | : As specified |
| 2) | Numbers required | : Refer to Section-C of Specific Technical Requirements |
| 3) | Designation of the unit | : Package AC Unit |
| 4) | Whether air cooled/water cooled | : Refer to Section-C of Specific Technical Requirements |
| 5) | The plant shall be suitable for maximum-ambient temp. | : Refer outdoor design condition as specified. |
| 6) | Whether a plenum Chamber required | : Units shall be connected to fresh air ducts. |
| | OR | |
| | Whether to be connected duct system. | : Yes. |
| 7) | Whether Humidifier required for humidity-control. | : Refer to Section-C of Specific Technical Requirements |
| 8) | Whether strip heaters required for winter heating. | : Refer to Section-C of Specific Technical Requirements |
| 9) | Whether strip heater required for Humidity control. | : Refer to Section-C of Specific Technical Requirements |
| 10) | Final painting colour shade | : Subject to approval / during detail engineering stage. |
| 11) | Whether fan static pressure is to be designed for filters arrangement shown. | : Yes. |
| 12) | Installation supporting structure/drain piping, insulation. | : Required. Drain piping with insulation up to the nearest drain point. |
| 13) | Controls & Instruments | : Yes (Lot) |
| 14) | Isolation Switch | : Yes |

Varun Jain

S.A. Khan

Praveen Kishore



**STANDARD TECHNICAL SPECIFICATION
FOR
AIR FILTER**

SPECIFICATION NO.PES-553-06

VOLUME II B


SECTION D

REV. 02

DATE: 17.09.2012

SHEET 1 OF 4

**STANDARD TECHNICAL SPECIFICATION
FOR
AIR FILTER**


Varun Jain


S.A. Khan


Praveen Kishore



**STANDARD TECHNICAL SPECIFICATION
FOR
AIR FILTER**

SPECIFICATION NO.PES-553-06

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 2 OF 4

1. GENERAL

This specification covers the design, manufacture, inspection and testing at manufacturer's work or his sub-contractor's works of Air filters to be used for air-conditioning and ventilation system.

2. CODES AND STANDARDS

This design, manufacture and performance of AIR FILTERS shall comply with all currently applicable statutes, regulation and safety codes in the locality where the equipment will be installed. The equipment shall also conform to latest applicable Indian/British/USA standards. Nothing in this specification shall be construed to relieve the vendor of this responsibility. The following standards, in particular, shall be applicable for certified ratings of filters and for conducting performance test, if required.

a) BS EN - 779 -Methods of test for air filters used in air conditioning and general ventilation.

3. GENERAL

The enclosed Data sheet A gives the type and other particulars of filters required.

3.1 POLY FIBRE AIR FILTERS

Filtering media shall consist of a suitable fibrous material (e.g. polyethylene extruded sections coir etc.) packed into a 20 gauges GSS framework, complete with handles etc. The filter element shall be supported by galvanised steel wire mesh of 10mm. sq. on either side, Velocity across the filters shall not exceed 2.5 M/sec. Average efficiency E_m (%) shall be ≥ 80 as per BS EN - 779.


3.2 DRY FABRIC AIR FILTERS

Filter element shall be pressed felt filter fabric or suitable material recommended by the manufacturer, stitched on to galvanised wire gauge support and crimped to form deep folds. Suitable aluminium spacers shall be provided to ensure uniform distribution of air flow through filters. Filter casing shall be provided with neoprene sponge rubber sealing, The filter shall have Average efficiency E_m (%) of ≥ 95 as per BS EN - 779.


3.3 PANEL TYPE METALLIC FILTERS (DRY/VISCOUS)

Filter shall consist of V-fold galvanised wire mesh interspaced with flat layers of galvanised wire mesh. The density of media shall increase in the direction of air flow. Edges of wire mesh shall be suitably hemmed to prevent abrasion during handling. The media shall be supported on either side by galvanised expanded metal casing. The framework shall be at least 18 gauge GSS. Filter shall be either dry or wetted type as per data sheet=A. The oil shall be mineral oil of approved quality and make. As a the filter frame made of Aluminium alloy conforming to IS:737 can be considered unless use of aluminium is prohibited otherwise due to site conditions being saline/corrosive.

All filters shall be capable of being cleaned of their accumulated dust by tap water flushing. The dry metallic filter shall have Average arrestance A_m (%) shall be ≥ 90 .


Varun Jain


S A Khan


Praveen Kishore



**STANDARD TECHNICAL SPECIFICATION
FOR
AIR FILTER**

SPECIFICATION NO.PES-553-06

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 3 OF 4

However oil wetted air filters shall have Average Efficiency Em (%) \geq 90 as per BS EN - 779..

3.4 AUTOMATIC CLEANING FILTERS

This shall consist of a filter mat and drop eliminator, driven by a suitably rated geared motor unit being supported on a steel framework. The filter mat shall consist of an endless steel wire mat insets of steel mesh held between an upper & a lower shall drop eliminator shall consist of an endless steel wire without insets of steel mesh. The unit shall include a suitable oil pump, gludge raking mechanism and sludge container and tensioning device. Pressure drop shall be limited to 0.5 / mm WG when clean & 10 mm when dirty. Air velocity across filter shall not exceed 3 M/sec.

3.5 ABSOLUTE FILTERS

Filters shall be constructed by pleating a continuous sheet of filter medium into closely spaced pleats separated by heavy corrugated aluminium spacers. They shall be individually tested and certified to have an efficiency of not less than 99.97% when tested with 0.3 micron dioctylphalate smoke as per IS:2831. The clean filter initial static pressure drop shall not be greater than 25mm WC at rated capacity. A neoprene sponge rubber sealing shall be provided on either face of filter frame.

3.6 WATER REPELLANT NYLON FILTERS

This shall be constructed of water repellent nylon fabric with continuous water spraying on it from a header for keeping it clean. Efficiency of this filter shall be 85% down to 10 microns. This filter shall be used for unitary air filtration system only.

4. INSPECTION & TESTING


The scope of inspection for air filters shall be as below:

4.1 Dimensional inspection of frame & filter media.


4.2 Witnessing of type tests on one per type per size air filters for the following properties.

- a) Gravimetric efficiency.
- b) Pressure drop in clean & dirty (choked - %age to be specified) condition.
- c) Efficiency as per BS EN - 779.

4.3 Verification of type test certificates for similar type & size of filters for sodium flame test as per BS-3928 (if applicable- refer data sheet).


Varun Jain


S A Khan


Praveen Kishore



**STANDARD TECHNICAL SPECIFICATION
FOR
AIR FILTER**

SPECIFICATION NO.PES-553-06

VOLUME II B

SECTION D


REV. 02

DATE: 17.09.2012

SHEET 4 OF 4

5. DATA TO BE FURNISHED BY VENDOR AFTER AWARD OF CONTRACT

- 5.1 GA Drawing.
- 5.2 Drawing showing material/construction detail
- 5.3 Installation and service manual
- 5.4 Rating curves/charts
- 5.5 Test certificates
- 5.6 Elect. diagrams (when automatic cleaning type)


Varun Jain


S A Khan


Praveen Kishore



AIR FILTER
DATA SHEET - A

VOLUME II-B

SECTION D

REV 00

DATE 17.09.2012

SHEET 1 OF 1

DESCRIPTION


DATA

1) General


- | | |
|-----------------------------|--|
| 1.1 Service | : Air Conditioning. |
| 1.2 Location | : Central Air conditioning plant, & package AC plant, fresh air fan system. Also for split AC. |
| 1.3 Nos. | : Refer Section 'C' of Specification. |
| 1.4 Total air flow/type | : Refer Section 'C' of Specification. |
| 1.5 Temperature | : As per project information. |
| 1.6 Relative Humidity | : 100% |
| 1.7 Gas Composition | : Atmospheric Air (Dusty) as prevalent in power Station. |
| 1.8 Filter Media | : Synthetic non-woven |
| 1.9 Efficiency | : Average arrestance efficiency of 65-80 % for Dry Panel filter (pre-filters) and average arrestance Efficiency of 80-90 % for fine filters. |
| 1.10 Allowable pressue drop | : 2.5 mm & 6.5 mm in clean and dirty condition respectively for dry panel filters(prefilters).
12 mm in clean condition for fine filters. |
| 1.11 Frame Work | : 18 G, GSS. |
| 1.12 Mounting | : Ladder Type M.S Angles (galvanised) |
| 1.13 Size | : 600 x 600 mm |

Note:-

- 1) Face velocity of air across the filters shall not exceed 2.5 m/sec.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION
THERMAL INSULATION FOR COLD SURFACES

SPECIFICATION NO.PES-553-08

VOLUME II B


SECTION D

REV. 02

DATE: 17.09.2012

SHEET 1 OF 6

**STANDARD TECHNICAL SPECIFICATION
FOR
THERMAL INSULATION FOR COLD SURFACES**


Varun Jain


S.A. Khan


Praveen Kishore



TECHNICAL SPECIFICATION
THERMAL INSULATION FOR COLD SURFACES

SPECIFICATION NO.PES-553-08

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 2 OF 6

1.

SCOPE

This specification covers design, manufacture, testing at manufacturers works, supply, application & finishing of insulation for cold piping, air conditioning ducting & equipment for low temperature service.

2.

CODES & STANDARDS

The design, manufacture and performance of materials covered under this specification shall comply with all currently applicable statues, regulations & safety codes in the locality where the equipment/material are to be installed. The material shall also conform to the latest applicable Indian/British/American codes & standards. Nothing in this specification shall be construed to relieve the vendor of his responsibility. In particular, the material shall conform to the latest editions of the following standards :-

IS:3069: GLOSSARY OF TERMS & SYMBOLS & UNITS RELATING TO THERMAL INSULATION

materials.

2.1

IS:4671 : Expanded polystyrene for thermal insulation purposes.

2.2

IS:3677 : Mineral wool for thermal insulation.

2.3

IS:8183 : Resin bonded mineral wool.

3.

DESIGN REQUIREMENTS

3.1

The insulating material as well as protective covering shall be new & unused, non-corrosive, vermin/rodent proof and shall be guaranteed to withstand continuously & without deterioration the maximum/minimum temperatures to which they may be subjected to, under specified site conditions.

3.2

The insulation material must be light weight, strong, free from shots & coarse fibre & shall provide high insulation efficiency at low weight & coat. It should be non-hygroscopic & should not rot. It shall not settle or shake down even when subjected to prolonged vibrations.

3.3

The insulation material, density and thickness etc. Shall be as specified in DATA SHEET A.

4.

APPLICATION DETAILS

4.1

The surface to be insulated shall be thoroughly cleaned and allowed to dry. Pressure/hydrostatic tests, if any, shall be carried out before application of insulation.

4.2


A layer of solvent free, anticorrosive paint shall be applied & allowed to dry.

4.3


Hot industrial bitumen of grade 85/40 or 85/25 conforming to latest IS:702 shall be uniformly applied @ 1.5 kg/sq.m on the surface to be insulated. A similar layer shall also be applied on the inside surface & edges of the insulation. A suitable cold adhesive compound may also be used in place of bitumen.

4.4

Insulation in the form of pipe sections/rolls slabs of specified density & thickness shall be stuck to the coated surface with joints staggered & well butted & secured. The adjoining sections shall be tightly pressed together. All the joints shall be sealed with


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION
THERMAL INSULATION FOR COLD SURFACES

SPECIFICATION NO.PES-553-08

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 3 OF 6

bitumen/equivalent adhesive. Voids if any shall be packed with suitably cut pieces of insulation material.

4.5 In case of double layer application both circumferential & longitudinal joints shall be suitably staggered.

5. VAPOR SEALING & INSULATION FINISH

The insulation shall be treated for vapor sealing & weather proofing & finished as specified in DATA SHEET A The acceptable types of finishes are outlined below:-

5.1 FINISHING SYSTEM I: EXTERNAL INSULATION WITH PLASTER FINISH

5.1.1 A thick vapor seal of hot bitumen @ 2.5 kg/Sqm shall be applied on the outer surface of insulation & allowed to dry.

5.1.2 The surface shall then be wrapped with 20mm (3/4") hexagonal mesh of 24 SWG GI wire, butting all the joints & laced down with 22 SWG GI lacing wire.

5.1.3 12.5mm (1/2 inch) thick sand cement plaster in the ratio of (1:1) shall be applied in two layers, the second layer being brought to a smooth finish. A water proofing compound shall be added to the cement before its application.

5.2 FINISH SYSTEM II: EXTERNAL INSULATION WITH PLASTER FINISH OVER POLYTHENE.

5.2.1 The insulation shall be covered with 500 g polythene/polythene bonded Hessians (PBH) with 50mm overlap on longitudinal & circumferential joints. Overlaps shall be sealed with synthetic adhesive in case of polythene & liberal coat of bitumen in case of PBH:

5.2.2 The surface shall then be wrapped with 20mm (3/4") mesh of 24 SWG GI wire butting all the joints & laced down with 22 SWG GI lacing wire.

5.2.3 12.5mm thick (1/2 inch) sand cement plaster in ratio of(4:1) shall be applied in two layers, the second layer being brought to a smooth & even finish similarly as described above.

5.3 FINISH III:EXTERNAL INSULATION WITH SHEET METAL FINISH

5.3.1 The insulation shall be covered with 500g polythene with 50mm overlaps at joints which shall be sealed with synthetic adhesive or equivalent compound.

5.3.2 The polythene shall be covered with 24 gauge GI/aluminum sheet

5.3.3 25mm wide x 22 SWG GI/aluminum peripheral straps shall be fixed over the GI/aluminum sheet at 300mm centres to secure.


5.4 FINISH IV: EXTERNAL INSULATION WITH PLASTER & WATER PROOFING COMPOUND

For ducts & piping exposed to atmosphere, the finish shall be as follows:


5.4.1 A thick vapor seal of hot bitumen at 2.05 kg/sq.m shall be applied on the outer surface of insulation & allowed to dry.

5.4.2 The surface shall then be wrapped with 20mm (3/4") hexagonal mesh of 24 SWG GI Wire butting all the joints & laced down with 22 SWG GI lacing wire.

5.4.3 12.5mm thick (1/2 inch) sand cement plaster in ratio of (4:1) shall be applied in two layers, the second layer being brought to a smooth finish with water proofing compound added to the cement.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION
THERMAL INSULATION FOR COLD SURFACES

SPECIFICATION NO.PES-553-08

VOLUME II B

SECTION D


REV. 02

DATE: 17.09.2012

SHEET 4 OF 6

5.4.4

3 mm (1/8") thick coat of water proofing compound shall be applied & wrapped with fibre glass RP tissue. A final coat of 3mm thick water proofing compound shall then be applied over the fiberglass RP tissue & allowed to dry. Alternatively, in place of water proofing as desired above, tar felt type 3 grade 1 of IS 1322 with joints overlapped by 75mm shall be fixed & sealed with bitumen & over this 24 SWG. 25mm hexagonal GI mesh shall be fixed with 22 swig. GI lacing wire & finally bitumen paint shall be applied over wire netting.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION
THERMAL INSULATION FOR COLD SURFACES

SPECIFICATION NO.PES-553-08

VOLUME II B

SECTION D

REV. 02

DATE: 17.09.2012

SHEET 5 OF 6

6. INSULATION OF PUMPS & VALVES

6.1 For all inspection covers & hatches on equipment, pump casing & valve bodies, flanges etc. the insulation shall be applied such as to facilitate removal with minimum damage to the insulation. This shall be achieved by encasing the insulation in 22 gauge aluminum sheet metal boxes, which shall be bolted together around the equipment to permit easy removal & replacement. Proper care shall be taken to maintain continuity of vapor seal between the static & removable partitions of the insulation.

6.2 The tenderer may offer thickness of insulation & finishes other than that specified in DATA SHEET A. However, calculations/reasons in support of alternative proposal shall be furnished for purchaser's approval.

7. INSPECTION & TESTING (REFER SPEC. NO - PES-553.00)


7.1 All necessary tests, as required to ensure that the material supplied conform to the requirements of applicable codes & standards, shall be carried out at manufacturer's works & test certificates including these for material/accessories shall be furnished for purchaser's approval.

8. PAINING


8.1 Pipe work having insulation & cladding shall be provided with color identification for the fluids handled and for indicating direction of flow.

8.2 Equipment surfaces having insulation and cladding shall also have identification numbers and any other relevant data provided on the insulated surface.

8.3 All painting for insulated surfaces shall conform to the requirement specified elsewhere.


Varun Jain


S A Khan


Praveen Kishore



TECHNICAL SPECIFICATION
THERMAL INSULATION FOR COLD SURFACES

SPECIFICATION NO.PES-553-08

VOLUME II B

SECTION D


REV. 02

DATE: 17.09.2012


SHEET 6 OF 6

9. DATA TO BE FURNISHED AFTER AWARD OF CONTRACT

- 9.1 Final version of data sheet 'B' incorporating changes if any along with design data.
- 9.2 Test certificates/reports giving result of insulation to ensure conformance to applicable codes & standards & in particular the following:-
- a) Thermal conductivity test.
 - b) Sound absorption coefficient test.
 - c) Corrosion test.
 - d) Sulphur content, moisture content, shot content, moisture absorption etc.
 - e) Compressive strength & cross breaking strength test.
- 9.3 Sketches/technical literature/sectional drgs. indicating insulation materials finish and method of application etc.
- 9.4 Manual dealing with safety aspects & instructions for combating fire arising out of insulation work.
- 9.5 Instructions on maintenance of insulation work.


Varun Jain


S A Khan


Praveen Kishore



THERMAL INSULATION
FOR COLD SURFACE
DATA SHEET - A

VOLUME II-B

SECTION D

REV 00

DATE 17.09.2012


SHEET 1 OF 1

Insulation Material

Insulation	Code	Thermal Conductivity MW/cm ⁰ C	Density Kg/m ³
Resin bonded mineral wool / glass wool	IS:8183	0.49 at 50 ⁰ C	At least 24 for duct insulation and 48 for acoustic lining.
Mineral Wool Pipe Section (min. Gr.2)	IS:9842	0.43 at 50 ⁰ C	At least 81
Expanded Polystyrene	IS:4671	0.37 at 10 ⁰ C	At least 15

Type of Insulation

S.No.	Surface	Insulation Material	Insulation Form	Thickness (mm)
i)	Supply & Return air duct for air-conditioning system	Resin bonded roll Mineral Wool (IS:8183)		25
ii)	Refrigerant Piping	a) Expanded Polystyrene or b) Mineral Wool	Pipe Section Pipe Section	75 75
iii)	AHU drain pipe	a) Expanded Polystyrene or b) Mineral Wool	Pipe Section Pipe Section	25 25
iv)	AHU drain pan coil section and fan section	a) Expanded Polystyrene or b) Mineral Wool	Slabs Slabs	25 25
v)	Chilled water piping, valves & specialties	a) Expanded Polystyrene or b) Mineral Wool	Pipe Section Pipe Section	75 75
vi)	Chiller	a) Expanded Polystyrene or b) Mineral Wool	Slabs Slabs	100 100
vii)	Chilled Water Pumps	a) Expanded Polystyrene or b) Mineral Wool	Slabs Slabs	50 50
viii)	Expansion tank with pipe	a) Expanded Polystyrene or b) Mineral Wool	Slabs/Pipe Section Slabs/Pipe Section	50 50


Varun Jain


S.A. Khan


Praveen Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM**

LIST OF MAKES OF SUB-VENDOR ITEMS

SPECIFICATION NO. PE-TS-400-553-A001

VOLUME : II B

SECTION : E


REV 02

DATE: JUNE 2016

SHEET 1 OF 4

ANNEXURE-I

LIST OF MAKES OF SUB-VENDOR ITEMS


Varun Jain


S A Khan


Praveen Kishore



2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM

LIST OF MAKES OF SUB-VENDOR ITEMS

SPECIFICATION NO. PE-TS-400-553-A001

VOLUME : II B


SECTION : E

REV 02


DATE: JUNE 2016

SHEET 2 OF 4

Sl. NO.	ITEM / EQUIPMENT	SUB SUPPLIER
1	SCREW/SCROLL CHILLER	YORK / TRANE / CARRIER / KIRLOSKAR / DUNHAM BUSH / MCQUAY (DAIKIN) / BLUE STAR / VOLTAS
2	VAPOUR ABSORBTION MACHINE	VOLTAS / THERMAX
3	PRECISION PACKAGE UNITS	STULZ / UNIFLAIR / EMERSON / BLUEBOX / CLIMADENTA
4	PACKAGE UNIT	VOLTAS / BLUE STAR / CARRIER
5	SPLIT AIR CONDITIONER	VOLTAS / BLUE STAR / CARRIER / HITACHI / LG
6	AIR HANDLING UNITS	VOLTAS / BLUE STAR / ZECO / CARRYAIRE(FLAKT) / EDGETECH / ETHOS / SYSTEM AIR / WAVES AIRCON
7	AHU FAN (CENTRIFUGAL FAN)	CB.DOCTOR / FLAKT / KRUGER / NICOTRA / COMEFRI / MARATHON / PATEL AIR
8	CHILLED & CONDENSER WATER PUMP	BEST & CROMPTON / JYOTI / SAM TURBO / KBL / KSB / M&P / VOLTAS / BEACON-WEIR / WORTHINGTON / FLOWMORE / SULZER / BHARAT PUMPS & COMPRESSORS LTD / FLOWSERVE INDIA CONTROL PVT LTD / V-FLOW PUMPS & SYSTEMS CO
9	COOLING TOWER	PAHARPUR / MIHIR / PCT / FLOWTECH / BELL
10	INDUCTION MOTORS (LT)	SIEMENS / ABB / CGL / MARATHON / KEC / BHARAT BIJLEE / NGEF / JYOTI / LHP
11	AIR FILTER	PUROLATOR / FMI / ANFILCO / TENACITY / JOHN FOWLER / SPECTRUM / AIR TECH / PUROMATIC
12	AXIAL FANS / F.A. FANS	FLAKT / KHAITAN / PATEL / NICOTRA / SARLA / KRUGER / MARATHON / C DOCTOR
13	INSULTATION MATERIAL	BEARDSHELL / K-FLEX / PARAMONT/ ARMAFLEX / SUPREME / LLOYDS / UP TWIGA
14	BALANCING VALVE	ADVANCE
15	BUTTERFLY VALVE	AUDCO / FOURESS / INTER VALVE / BDK / WEIR BDK / TYCO / CRANE PROCESS / KEYSTONE
16	NON RETURN VALVE	LEADER / H.SARKAR / FLUID LINE / HI -TECH / CRESENT / A V VALVES / BANKIM & COMPANY / SHIVADURGA
17	GATE/GLOBE VALVES	CRESENT / BDK / AUDCO / FOURESS / KIRLOSKAR / SANT / BOMBAY METAL & ALLOYS / BANKIM / LEADER / H SARKAR / AV VALVES / VENUS PUMPS AND ENGG
18	3 WAY MIXING VALVE WITH ACTUATING MOTOR	SIEMENS BUILDING TECHNOLOGY /JOHNSON / BELIMO / HONEYWELL / RAPID CONTROL / ALC
19	MOTORIZED BUTTERFLY VALVE	ANERGY / ADVANCE / BELIMO / JOHNSON / HONEYWELL / SIEMENS
20	Y / POT STRAINER	MULTITEX / GREAVES COTTON / JAYPEE / SANT / OTOKLIN / GRAND PRIX / GUJARAT OTOLIFT / DS ENGG / SAROJINI ENTERPRISE / BHATIA ENGINEERING / FILTRATION ENGINEERS INDIA PVT LTD / SUNGOV ENGINEERING


Varun Jain


S.A. Khan


Praveen Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM**

LIST OF MAKES OF SUB-VENDOR ITEMS

SPECIFICATION NO. PE-TS-400-553-A001

VOLUME : II B


SECTION : E

REV 02


DATE: JUNE 2016

SHEET 3 OF 4

21	PIPING - ERW	SURYA ROSHNI / TISCO / DADU PIPES / INDUS TUBE / WELSPUN / TATA / BST / JINDAL / SAIL
22	PIPING - CS SEAMLESS (ASTM A 106)	ISMT / MAHARASHTRA SEAMLESS
23	GI SHEETS FOR DUCTING	TISCO / INDIAN IRON & STEEL CO LTD. / RASHITRYA ISPAT NIGAM LTD. / ESSAR/ ISPAT INDUSTRIES / JSW STEEL / LLOYDS STEEL / BHUSHAN / TATA / SAIL / JINDAL
24	FIRE DAMPER	TSC / CARRYAIRE / RAVISTAR (SYSTEM AIR)
25	GRILL/DIFFUSER/VOLUME CONTROL DAMPER	AIR FLOW/ TSC /AIR MASTER/ CARYAIRE/RAVI STAR (SYSTEM AIR)
26	STRIP HEATER	ESCORTS / RACOLD / DASPASS/ ALCO/ HEATCO / HOTSET
27	PAN HUMIDIFIER	RAPID COOL/ HOTSET /ALCO
28	RELIEF / PURGE VALVE	BRASSOMATIC
29	THERMOSTATS	HONEYWELL / RANCO / PENN / DANFOSS / INDFOSS / JHONSON CONTROL /RANUTROL
30	HUMID STAT	JHONSON CONTROL / HONEYWELL / PENN
31	ANTI FREEZE THERMOSTAT	RANCO / HONEYWELL / PENN / DANFOSS / INDFOSS
32	PRESSURE GAUGE	GENERAL INST CONSORTIUM / BELL / H.GURU INST P. Ltd. / WAAREE INSTRUMENTS / H. GURU IND / FORBES MARSHALL / MANOMETER / A.N. INST / GAUGES BOURDON / GLUCK / WIKA / ASHCROFT / BAUMER TECHNOLOGIES/ Precision Mass Products Pvt. Ltd. / Bose Panda Instt. Pvt. Ltd.
33	TEMPERATURE GAUGE	H. GURU IND/ H.GURU INST/ FORBES MARSHALL/DETRIVE INST & ELECTRONICS / PYRO ELECTRIC /TOSHNIWAL BROSS / WAREE INSTRUMENTS / A.N.INST / GOA INSTRUMENTS / WIKA/ ASHCROFT / H GURU (SI)/ Baumer Technologies/ Goa Thermostatic/ Gauge Bourdon/ Budenberg Gauge/ Precision Mass Products
34	LEVEL GAUGE	GENERAL INSTRUMENTS / CHEMTROLS / SBEM, PUNE/ AUTOMAT MUMBAI /SIGMA / TOSHNIWAL / TECHNOMATIC / TELACO /LEVCON / D K INSTRUMENTS / PUNE TECHTROL / FLOW STAR/ Bliss Anand
35	PRESSURE SWITCH / DP SWITCHES	BELLS / DANFOSS / DK INSTRUMENTS/ DRESSER / SOR INC / VASU / SWITZER / INDFOSS / TRAFAG / GIC / ASHCROFT/ Kasturba Udyog/ Barksdale/ Precision Mass Products/ Mittal Refrigeration
36	TEMPERATURE SWITCH	INDFOSS/ SEIMENS / DANFOSS/ DK INSTRUMENTS/ SOR INC / VASU / DRESSER / TOSHNIWAL / SWITZER
37	FLOW SWITCH	SWITZER / LEVCON / DK INSTRUMENT / SBEM / V. AUTOMATE/ SIEMENS
38	LEVEL SWITCH	SBEM / BLISS ANAND / HI TECH / RAMAN INST / SIGMA / SOR INC / WAREE INST / LEVCON / DK INSTURMENT / V ATUOMATE /CHEMTROLS / SIMENS / FLOW STAR / TRAC/ Flow Tech/ Nivo Controls/ Pune Techtrol/ SAPCON/ Baumer Technologies/ GIC/ SBEM


Varun Jain


S A Khan


Praveen Kishore



2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM

SPECIFICATION NO. PE-TS-400-553-A001

VOLUME : II B

SECTION : E

REV 02

DATE: JUNE 2016


SHEET 4 OF 4

LIST OF MAKES OF SUB-VENDOR ITEMS


39	TRANSMITTERS	TAYLOR / ABB/BRISTOL BABCOCK / BIRLA KENT TAYLOR / BLISS ANAND /SBEM/ SMART INST / V AUTOMATION & INST / FISHER-ROSEMOUNT/ SIEMENS/ TATA HONEYWELL/ Pune Techtrol/ Nivo Controls/ Panam Engineers/ Emerson/ Moore Industries/ Toshniwal Industries/ Yokogawa/ E&H/ ABB
40	SIGHT FLOW INDICATORS	SIGMA / LEVCON /V AUTOMAT / TELLACE /EUREKA / TATA HONEYWELL/BLISS ANAND/ Scientific devices/ BK Equipments/ Instrumentation Engineers
41	FLOW ELEMENT	BRISTOL BABCOCK / BALIGA /LIGHTING EQUIP /ENGINEERING SPECIALITIES /IL / MINCO/ MICRO PRECISION / STAR MECH
42	TEMPERATURE ELEMENT	GENERAL INST CONSORTIUM/ PYRO ELECTRIC /WAAREE INSTRUMENTS/ DETRIVE INST & ELECTRONICS / TOSHNIWAL/ Goa Instruments/ Gauge Bourdon/ Techno Instruments/ Tempsens Instruments/ Thermal Instruments/ TM Technomatic/ Baumer Technologies
43	FLOW METER	EUREKA / INSTRUMENTATION ENGINEERS PVT LTD / PLACKA /TRAC / FLOW STAR/ SCIENTIFIC DEVICE
44	RH SENSOR/TEMP SENSOR	HONEY WELL /JOHNSON /SIEMENS / GENERAL INSTRUMENTS
45	PLC BASED PANEL	SIEMENS / SCHENIEDER / ROCKWELL / GE INTELLIGENT / HONEYWELL AUTOMATION / ABB/ Mitsubishi Electric
46	OWS / PC	HP / COMPAQ / DELL / HCL / IBM / LENOVO
47	PRINTER	HP / CANON / EPSON / XEROX / IBM / LEXMARK
48	UPS	HITACHI-HIREL / APC / DELTA / EMERSON / DB POWER / APLAB
49	FIBRE OPTIC CABLE	BIRLA ERICSON / FINOLEX / AKSH FIBRE
50	ANNUNCIATOR FOR PANEL	ICC / PECON/ PROCON
51	LT ADAPTER BOX FOR AL TO CU CABLE CONVERTOR	CONTROL DEVICE / SYSTEM POWER CONTROL / JACKSON / UNILEC / ELECTRIC ALLIED PRODUCT
52	METERING PUMP	SHAPO TOOLS / VK PUMPS
53	WATER SOFTENING PLANT	THERMAX / ION EXCHANGE / DOSI ION
54	PRESSURE TRANSMITTER	ABB / ENDRESS + HAUSER (INDIA) / MOORE / SIEMENS / SMART INSTRUMENT BRAZIL / SBEM / TOSHNIWAL / V. AUTOMAT / EMERSON / YOKOGAWA / HONEYWELL / FUJI
55	TEMPERATURE TRANSMITTER	ABB / ENDRESS + HAUSER (INDIA) / MOORE / SIEMENS / SMART INSTRUMENT BRAZIL / SBEM / TOSHNIWAL / V. AUTOMAT / EMERSON / YOKOGAWA / HONEYWELL
56	ROTAMETER	CHEMTROLS SAMIL / EUREKA IND / IL / TRANSDUCERS AND CONTROL
57	BATTERY CHARGER	AMARARAJA/ CHHABI ELECTRICAL / DUBAS ENGG. / HBL POWER SYSTEM / STATCON / CALDYNE
58	BATTERY (NI -Cd)	HBL POWER / AMCO SAFT / SAFT

NOTE

Above sub-vendor are also subjected to Customer approval during detailed engineering.


Varun Jain


S A Khan


Praveen Kishore



**2x500 MW NTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
MANDATORY SPARE LIST**

SPECIFICATION NO. PE-TS-400-553-A001

VOLUME : II B


SECTION : E

REV 02

DATE: JUNE 2016

SHEET 1 OF 2

**ANNEXURE-II
MANDATORY SPARE LIST**


Varun Jain


S A Khan


Praveen Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
MANDATORY SPARE LIST**

SPECIFICATION NO. PE-TS-400-553-A001

VOLUME : II B

SECTION : E

REV 02

DATE: JUNE 2016

SHEET 2 OF 2

LIST OF MANDATORY SPARES:-

S.No.	Description	Unit	Qty	Remarks
1	Contractor (For each type and rating)	No.	Minimum 1 no. of each type	Applicable items considered. Applicable items are those which are installed in the system.
2	Over load relay (For each type and rating)	No.	2 no. of each type	
3	Relay/Timer (For each type and rating)	No.	3 no. of each type	
4	Fan motor (For each type and rating)	No.	30% of each rating	
5	Electronics cards (For each type and rating)	No.	20% of each rating	
6	Switch fuse unit/MCCB/ELCB (For each type and rating)	No.	2 no. of each rating	
7	Blower motor (For each type and rating)	No.	30% of each rating	
8	Pumps (For each type and size)			
8.1	Impeller (For each type and size)	No.	2	
8.2	Shafts (For each type and size)	No.	1	
8.3	Shaft sleeve (For each type and size)	Set	3	
8.4	Casing wear ring (For each type and size)	Set	6	
8.5	Impeller bearing (For each type and size)	Set	2	
8.6	Motor bearing (For each type and size)	Set	2	
8.7	Thrust bearing (For each type and size)	Set	2	
8.8	Radial bearing (For each type and size)	Set	2	
8.9	Gland packing (For each type and size)	Set	2	
8.10	Fasteners (For each type and size)	Set	1	
8.11	Complete coupling (pump & motor) (For each type and size)	Set	1	
8.12	Motor (For each type and rating)	No.	1	

Varun Jain

S.A. Khan

Pritveer Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
LIST OF TOOLS & TACKLES**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B


SECTION : E

REV 02

DATE: JUNE 2016

SHEET 1 OF 2

**ANNEXURE-IV
LIST OF TOOLS & TACKLES**


Varun Jain


S A Khan


Praveen Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
LIST OF TOOLS & TACKLES**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B

SECTION : E

REV 02

DATE: JUNE 2016


SHEET 2 OF 2

LIST OF TOOLS & TACKLES


SL NO	ITEM DESCRIPTION	UNIT	QTY
1	FLAT D WRENCH - 6 MM TO 32 MM (12 Pcs)	SET	1
2	BOX WRENCHES - 6 MM TO 22 MM (14 Pcs)	SET	1
3	RING SPANNER - 6 MM TO 32 MM (12 Pcs)	SET	1
4	ALLEN KEYS - 2 MM TO 10 MM	SET	1
5	CRESCENT SCREW SPANNER	NO.	1
6	SCREW DRIVER	NO.	1
7	OFFSET SCREW DRIVER	NO.	1
8	INSULATED PLIER	NO.	1
9	TORCH LIGHT(2 CELL)	NO.	1
10	HAMMER 1 LB	NO.	1
11	OIL CAN	NO.	1
12	POCKET THERMOMETER - 0 TO 50 DEG. C	NO.	1
13	INSULATION TAPE ROLL	NO.	1
14	STEEL FOOT RULE - 12"	NO.	1
15	FEELER GAUGE 9 BLADES	NO.	1
16	PIPE WRENCH	NO.	1
17	FLARE NUT (1/4")	NOS.	6
18	FLARING TOOL	NO.	1
19	TUBE CUTTER	NO.	1
20	GAS CHARGING PIPE	NO.	1
21	NITROGEN CHARGING ADAPTER	NO.	1
22	FREON PRESSURE GAUGE (2 1/2" DIA DIAL)) 0 - 300 MM PSI	NO.	1
23	FREON PRESSURE GAUGE (2 1/2" DIA DIAL)) 30 - 150 MM PSI	NO.	1
24	PSYCHRO METER	NO.	1
25	LOCK WITH KEY FOR TOOL BOX	NO.	1
26	RATCHET 1/4"	NO.	1
27	MS TOOL BOX	NO.	1

NOTE:-

The above mentioned list is tentative only, same shall be finalized during detailed engineering, as per system / customer requirement.


Varun Jain


S.A. Khan


Praveen Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
LIST OF COMMISSIONING SPARES**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B


SECTION : E

REV 02

DATE: JUNE 2016

SHEET 1 OF 2

**ANNEXURE-V
LIST OF COMMISSIONING SPARES**


Varun Jain


S A Khan


Praveen Kishore



2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
LIST OF COMMISSIONING SPARES

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B

SECTION : E

REV 02

DATE: JUNE 2016


SHEET 2 OF 2

LIST OF COMMISSIONING SPARES


SL NO	ITEM DESCRIPTION	UNIT	QTY
1	AHU FAN BELTS	SET	1
2	PRESSURE GAUGE	NO.	1
3	TEMPERATURE GAUGE	NO.	1
4	FILTER	SET	1
5	COMPRESSOR OIL	Ltr.	1 Lot
6	REFRIGERANT	Kg	1 Lot

NOTE:-

The above mentioned list is tentative only, same shall be finalized during detailed engineering, as per system / customer requirement.


Varun Jain


S A Khan


Praveen Kishore



2x500 MW NTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
CLARIFIED WATER ANALYSIS REPORT

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B

SECTION : E


REV 02

DATE: JUNE 2016

SHEET 1 OF 1

CLARIFIED WATER ANALYSIS REPORT

S.No.	DESCRIPTION	Unit	Tentative Values
1.0	Total dissolved solids	mg/l	425
2.0	Suspended solids /Turbidity	mg/l	20
3.0	Calcium hardness as CaCO ₃	mg/l	120
4.0	Magnesium hardness as CaCO ₃	mg/l	78
5.0	Sodium + Potassium as CaCO ₃	mg/l	95.35
6.0	Chloride as CaCO ₃	mg/l	84.6
7.0	Sulphate as CaCO ₃	mg/l	84.7
8.0	M alkalinity as CaCO ₃	mg/l	160
9.0	P alkalinity as CaCO ₃	mg/l	Nil
10.0	Iron as CaCO ₃	mg/l	1.25
11.0	Silica as SiO ₂	mg/l	36.4
12.0	Aluminium as CaCO ₃	mg/l	2.0
13.0	Conductivity at 30 °C	m-mho/cm	705
14.0	pH at 30 °C		7.0
15.0	Free CO ₂		19.36
16.0	Total hardness (as CaCO ₃)	mg/l	198


Varun Jain


S.A. Khan


Praveen Kishore



**2x500MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
DRAWINGS / DOCUMENTS SUBMISSION
PROCEDURE**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B


SECTION : E

REV 02


DATE: JUNE 2016

SHEET 1 OF 2

**ANNEXURE-VII
DRAWINGS / DOCUMENTS SUBMISSION PROCEDURE**


Varun Jain


S A Khan


Praveen Kishore



**2x500MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
DRAWINGS / DOCUMENTS SUBMISSION
PROCEDURE**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B

SECTION : E

REV 02

DATE: JUNE 2016

SHEET 2 OF 2

DRAWING/DOCUMENT DISTRIBUTION LIST

All documents & drawings shall be in English and in metric units

SI		LII	NLC (HQ)	NLC-SITE	BHEL SITE	PMG BHEL	PEM/ UNITS/ PSSR	REMARKS
1	Master list of drawings / document (duly indicating schedule of submission)	Soft copy	Soft copy	Soft copy		Soft copy	Soft copy (S)	
2	Drawings / document for Approval/Information (First Submission)	Soft copy + 2 prints	Soft copy + 3 prints	Soft copy + 1 print		Soft copy	Soft copy (S)	
3	Return with comments/approval	Soft copy (S)	Soft copy	Soft copy		Soft copy	Soft copy	
4	Drawings / Documents for approval (second & subsequent submissions till approval)	Soft copy	Soft copy	Soft copy		Soft copy	Soft copy (S)	
5	Drawings / documents for distribution (Approved by NLC, in cat. 1 or Received for Information)	Soft copy + 2 print (HQ+ Site)	Soft copy + 3 prints	Soft copy + 3 prints	Soft copy + 5 prints	Soft copy	Soft copy (S)	
6	Erection Drawings / documents	-	Soft copy + 1 print	Soft copy + 3 prints	Soft copy + 5 prints	Soft copy	Soft copy (S)	
7	As built Drawings / documents	Soft copy + 1 print	Soft copy + 1 print	Soft copy + 3 prints	Soft copy + 5 prints	Soft copy	Soft copy (S)	
8	Operation & Maintenance Manual	-	Soft copy + 1 print	Soft copy + 10 prints	Soft copy + 5 prints	Soft copy	Soft copy (S)	
9	Type Test Certificate	Soft copy	Soft copy + 1 print	Soft copy + 3 prints	Soft copy + 5 prints	Soft copy	Soft copy (S)	

NOTES:

1. The above schedule of submission does not include Docs/Drgs. of quality assurance/inspection and delivery/dispatches. QAP documents to be submitted as per distribution schedule.
2. Date of submitting soft copy is to be taken as date of submission.
3. S – Source for generation of document.

Varun Jain

S.A. Khan

Priti Kishore



**2x500 MW NTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
INSPECTION AND TESTING**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B


SECTION : E

REV 02

DATE: JUNE 2016


SHEET 1 OF 4

**ANNEXURE-VIII
INSPECTION AND TESTING**



Varun Jain


S A Khan



Praveen Kishore

	2x500 MW NNTPP SG PACKAGE AIR CONDITIONING SYSTEM INSPECTION AND TESTING	SPECIFICATION No: PE-TS-400-553-A001	
		VOLUME : II B	
		SECTION : E	
		REV 02	DATE: JUNE 2016
		SHEET 2 OF 4	

- 1.01.00 Inspection and Tests during Manufacture.
- 1.01.01 The method and techniques to be used by the Bidder for the control of quality during manufacture of all plant and equipment shall be agreed with the Owner.
- 1.01.02 The Owner's general requirements with respect to quality control and the required shop tests are set out elsewhere in this specification.
- 1.01.03 Before any item of plant or equipment leaves its place of manufacture the Owner shall be given the option of witnessing inspections and tests for compliance with the specification and related standards.
- 1.01.04 Advance notice shall be given to the Owner as agreed in the Contract, prior to the stage of manufacture being reached, and the piece of plant must be held at this stage until the Owner has inspected the piece, or has advised in writing that inspection is waived. If having consulted the Owner and given reasonable notice in writing of the date on which the piece of plant will be available for inspection, the Owner does not attend the Bidder may proceed with manufacture having forwarded to the Owner duly certified copies of his own inspection and test results.
- The owner's representative shall have at all reasonable times access to bidder's or his sub-vendor's premises and shall have power to inspect/ examine materials and workmanship or equipment under manufacture.
- The Bidder shall forthwith forward to the engineer duly certified copies of the Test Certificates in six copies (one to the Purchaser and five to the Consulting Engineer) for approval. Further nine (9) copies of Shop Test Certificates shall be bound with Instruction Manuals referred to elsewhere.
- For electrical equipment, routine tests as per relevant IS spec are to be carried out on all equipment. Type tests are also to be carried out on selected equipment as detailed in the specs of concerned electrical equipment.
- 1.01.05 Under no circumstances any repair or welding of castings be carried out without the consent of the Engineer. Proof of the effectiveness of each repair by radiographic and/or other non-destructive testing technique, shall be provided to the Engineer.
- 1.01.06 All the individual and assembled rotating parts shall be statically and dynamically balanced in the works.
Where accurate alignment is necessary for component parts of machinery normally assembled on site, the Bidder shall allow for trial assembly prior to despatch from place of manufacture.
- 1.01.07 All materials used for the manufacture of equipment covered under this specification shall be of tested quality. Relevant test certificates shall be made available to the Purchaser. The certificates shall include tests for mechanical properties and chemical analysis of representative material. Equipment or parts coming under any statutory


Varun Jain


S.A. Khan


Praveen Kishore



**2x500 MW NNTTP
SG PACKAGE
AIR CONDITIONING SYSTEM
INSPECTION AND TESTING**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B

SECTION : E

REV 02

DATE: JUNE 2016

SHEET 3 OF 4

Regulations shall be certified by a Competent Authority under the regulations in the specified format.

1.01.08 All pressure parts connected to pumping main shall be subjected to hydraulic testing at a pressure of 150% of shut-off head for a period not less than one hour. Other parts shall be tested for one and half times the maximum operating pressure, for a period not less than one hour.

1.01.09 All necessary non-destructive examinations shall be performed to meet the applicable code requirements.

1.01.10 All welding procedures adopted for performing welding work shall be qualified in accordance with the requirements of Section-IX of ASME code or IBR as applicable. All welded joints for pressure parts shall be tested by liquid penetrant examination according to the method outlined in ASME Boiler and Pressure Vessel code. Radiography, magnetic particle examination magnflux and ultrasonic testing shall be employed wherever necessary/ recommended by the applicable code. At least 10% of all major but welding joints shall be radiographed unless otherwise stipulated.

Statutory payments in respect of IBR approvals including inspection shall be made by the bidder. Bidder's scope shall include to preparation of all necessary documents, co-ordination and follow-up for above approval. Owner shall only forward assistance/endorsement of documents /design /drawings /reports/records to be submitted for approval as stipulated/ required by Statutory Authorities till registration of the unit and clearance for commercial operation.

1.02.00 Performance Tests at Site


1.02.01 The full requirements for testing the system shall be agreed between the Owner and the Bidder prior to Award of Contract. The completely erected System shall be tested by the Bidder on site under normal operating conditions. The Bidder shall also ensure the correct performance of the System under abnormal conditions, i.e. the correct working of the various emergency and safety devices, interlocks, etc.

1.02.02 The Bidder shall provide complete details of his normal procedures for testing, for the quality of erection and for the performance of the erected plant. These tests shall include site pressure test on all erected pipe work to demonstrate the quality of the piping and the adequacy of joints made at site.


1.02.03 The Bidder shall furnish the quality procedures to be adopted for assuring quality from the receipt of material at site, during storage, erection, pre-commissioning to tests on completion and commissioning of the complete system/equipment.

1.03.00 For details of specific tests required on individual equipment refer to respective section of this specification.

All Statutory testing / clearance is in Bidder's scope including payment of all fees, etc. as required


Varun Jain


S.A. Khan


Praveen Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
MASTER DRAWING LIST WITH SCHEDULE
OF SUBMISSION**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B


SECTION : E

REV 02


DATE: JUNE 2016

SHEET 1 OF 3

**ANNEXURE-IX
MASTER DRAWING LIST WITH SCHEDULE OF
SUBMISSION**


Varun Jain


S A Khan


Praveen Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
MASTER DRAWING LIST WITH SCHEDULE
OF SUBMISSION**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B


SECTION : E

REV 02


DATE: JUNE 2016

SHEET 2 OF 3

S. NO.	DRAWING NO	DRG./ DOC. TITLE	SCH. WEEK (FROM DATE OF LOI)
1	PE-V0-402-553-A001	INSPECTION CATEGORISATION PLAN	4
2	PE-V0-402-553-A002	QAP OF SCREW CHILLER	14
4	PE-V0-402-553-A003	QAP OF AIR HANDLING UNIT	14
5	PE-V0-402-553-A004	QAP OF PUMPS	15
6	PE-V0-402-553-A005	QAP OF COOLING TOWER	15
7	PE-V0-402-553-A006	QAP OF MOTORS	15
9	PE-V0-402-553-A101	HEAT LOAD CALCULATION FOR MAIN PLANT, ESP / VFD CONTROL ROOMS AND SERVICE BUILDING ETC	4
10	PE-V0-402-553-A102	OPERATION & CONTROL PHILOSOPHY FOR AIR CONDITIONING SYSTEM	12
11	PE-V0-402-553-A103	PRESSURE DROP CALCULATIONS FOR CHILLED AND CONDENSER WATER PIPING	10
13	PE-V0-402-553-A201	TDS AND GA OF SCREW CHILLER ALONG WITH FOUNDATION DETAILS	16
14	PE-V0-402-553-A202	TDS AND GA OF COOLING TOWER ALONG WITH FOUNDATION DETAILS	15
15	PE-V0-402-553-A203	TDS AND GA OF AIR HANDLING UNITS ALONG WITH FOUNDATION DETAILS	14
16	PE-V0-402-553-A204	TDS AND GA OF AHU FAN	14
17	PE-V0-402-553-A205	TDS AND GA OF CONDENSER AND CHILLED WATER PUMPS ALONG WITH FOUNDATION DETAILS	15
18	PE-V0-402-553-A206	TDS AND GA OF PAC / SPLIT AIR CONDITIONER	12
19	PE-V0-402-553-A207	TDS AND GA OF MOTOR (PUMP, COOLING TOWER, AHU, FRESH AIR FAN)	15
20	PE-V0-402-553-A208	TDS OF INSULATION MATERIAL (DUCT INSULATION, DUCT LINING, PIPE INSULATION)	12
21	PE-V0-402-553-A209	TDS AND GA OF FRESH AIR FANS	12
23	PE-V0-402-553-A210	TDS AND GA OF WATER SOFTENING PLANT	16
24	PE-V0-402-553-A211	TDS AND GA OF HEATERS AND HUMIDIFIER	7
25	PE-V0-402-553-A212	TDS AND GA OF FIRE DAMPER WITH ACTUATOR	10
26	PE-V0-402-553-A213	TDS AND GA OF FOR 3-WAY MIXING VALVE	8
27	PE-V0-402-553-A214	TDS AND GA OF VALVEES (BALANCING VALVE, GATE VALVE, CHECK VALVE , Y STRAINER)	9
28	PE-V0-402-553-A215	TDS AND GA OF SUPPLY / RETURN AIR DIFFUSER/GRILL	8
29	PE-V0-402-553-A216	TDS OF GI SHEET	5
30	PE-V0-402-553-A217	TDS OF PIPES	5
31	PE-V0-402-553-A218	TDS AND GA OF EXPANSION TANK, MAKEUP WATER AND SOFT WATER TANK	5
32	PE-V0-402-553-A219	TDS AND GA OF FILTERS	10


Varun Jain


S.A. Khan


Pritesh Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
MASTER DRAWING LIST WITH SCHEDULE
OF SUBMISSION**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B

SECTION : E

REV 02

DATE: JUNE 2016

SHEET 3 OF 3

S. NO.	DRAWING NO	DRG./ DOC. TITLE	SCH. WEEK (FROM DATE OF LOI)
33	PE-V0-402-553-A220	TDS FOR INSTRUMENTS (PRESSURE GAUGE, TEMPERATURE GAUGE, LEVEL GAUGE, PRESSURE SWITCH, TEMPERATURE SWITCH, LEVEL SWITCH, DP SWITCH, TEMPERATURE AND HUMIDITY SENSORS ETC)	12
34	PE-V0-402-553-A221	INSTRUMENT SCHEDULE	14
35	PE-V0-402-553-A222	INSTRUMENT HOOK UP	14
38	PE-V0-402-553-A223	LIST OF SIGNAL EXCHANGE WITH DCS (BOTH HARDWIRED & SERIAL INTERFACE IN BHEL FORMAT)	
39	PE-V0-402-553-A224	ANNUNCIATION LIST	
40	PE-V0-402-553-A225	JB GROUPING DOCUMENT	14
41	PE-V0-402-553-A226	CONTROL SCHEME/ LOGIC DIAGRAM (TO BE IMPLEMENTED)	16
43	PE-V0-402-553-A227	LIST OF DRIVES (SOLENOID VALVES ETC.).	16
44	PE-V0-402-553-A228	HMI PICTURES/PLANT SCHEMATICS	18
45	PE-V0-402-553-A501	PID FOR AC PLANT FOR ESP CONTROL ROOM BUILDING UNIT-1 & 2.	8
46	PE-V0-402-553-A502	TYPICAL Details DUCT FABRICATION DRAWING / SUPPORT / ERECTION. INSULATION OF DUCTING / PIPING & EQUIPMENTS CHILLED AND CONDENSER WATER PIPE ERECTION	7
47	PE-V0-402-553-A503	AC DUCT LAYOUT DRAWING FOR CONTROL ROOM BUILDING WITH AHU ROOM LAYOUT AND FOUNDATION DETAILS FOR BOTH THE UNITS (UNIT-1 & 2)	18
48	PE-V0-402-553-A504	AC PLANT ROOM LAYOUT & COOLING TOWER AREA LAYOUT WITH COMPLETE FOUNDATION DETAIL OF ALL EQUIPMENT	15
49	PE-V0-402-553-A505	CHILLED & CONDENSER WATER PIPING LAYOUT WITHIN PLANT ROOM & UPTO VARIOUS AHU ROOMS, & COOLING TOWER AREA.	20
50	PE-V0-402-553-A506	SPLIT AC SCHEDULE ALONGWITH HEAT LOAD CALCULATION FOR AUXILIARY BUILDING	22
51	PE-V0-402-553-A701	I/O LIST FOR AC SYSTEM	20
52	PE-V0-402-553-A751	ELECTRICAL FEEDER LIST	18
53	PE-V0-402-553-A752	CONTROL CABLE SCHEDULE AND CABLE INTERCONNECTION DRAWING	22
54	PE-V0-402-553-A901	PG TEST PROCEDURE	12
55	PE-V0-402-553-A902	O&M MANUAL	25

Note:

The above is not the complete list and may change during detail engineering.

Varun Jain

S A Khan

Praveen Kishore



**2x500 MW NTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
FORMAT FOR OPERATION AND
MAINTENANCE MANUAL**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B

SECTION : E


REV 02

DATE: JUNE 2016


SHEET 1 OF 4

ANNEXURE-X

**FORMAT FOR OPERATION AND MAINTENANCE
MANUAL**


Varun Jain


S A Khan


Praveen Kishore



**2x500 MW NNTTP
SG PACKAGE
AIR CONDITIONING SYSTEM
FORMAT FOR OPERATION AND
MAINTENANCE MANUAL**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B

SECTION : E

REV 02

DATE: JUNE 2016

SHEET 2 OF 4

Project name :
Project number :
Package Name :
PO reference :
Document number :
Revision number :

Sl.no. & Sections	Description	Tick (√)if included in Manual			Remarks
		Yes	No	Not Applicable	
1.	COVER PAGE				
1.1	Project Name				
1.2	Customer/consultant Name				
1.3	Name of Package				
1.4	Supplier details with phone, FAX ,email address , Emergency Contact number				
1.5	Name and sign of prepared by , checked by & approved by				
1.6	Revision history with approval Details				
2.0	INDEX				
2.1	showing the sections & related page nos All the pages should be numbered section wise				
3.0	DESCRIPTION OF PLANT/SYSTEM				
3.1	Description /write up of operating principle of system equipment/ associated sub-systems & accessories/controls system , operating conditions, performance parameters under normal , start up and special cases				
3.2	Equipment list and basic parameter with Tag numbers				
3.3	Data sheets approved by Customer/for information and catalogues provided by original manufacturer				
3.4	Associated other packages and Interface /terminal points				
3.5	P&ID & Process Diagrams				
3.6	GA Layout drawings, As-built drawings , Actual photograph of items/system (Drawings of A2 & bigger sizes are to be attached in the last)				
3.7	Single line/wiring diagrams				
3.8	Control philosophy /control write-ups				

Varun Jain

S A Khan

Pritveer Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
FORMAT FOR OPERATION AND
MAINTENANCE MANUAL**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B

SECTION : E

REV 02

DATE: JUNE 2016

SHEET 3 OF 4

Sl.no. & Sections	Description	Tick (√)if included in Manual			Remarks
		Yes	No	Not Applicable	
4.0	COMMISSIONING ACTIVITIES (IF NOT COVERED IN SEPARATE DOCUMENT I.E. ERECTION MANUAL, COMMISSIONING MANUAL)				
4.1	Pre-Commissioning Checks				
4.2	handling of items at site				
4.3	Storage at site				
4.4	Unpacking & Installation procedure				
5.0	OPERATION GUIDELINES FOR PLANT PERSONAL/USER/OPERATOR				
5.1	Interlock & Protection logic along with the limiting values of protection settings for the equipment along with brief philosophy behind the logic, drawings etc. to be provided.				
5.2	Start up, normal operation and shut down procedure for equipments along with the associated systems in step by step mode. Valve sequence chart, step list, interlocks etc. with Equipment isolating procedures to be mentioned.				
5.3	Do's & Don't of the equipments.				
5.4	Safety precautions to be taken during normal operation. Safety symbols, Emergency instructions on total power failure condition/lubrication failure/any other condition				
5.5	Parameters to be monitored with normal values and limiting values				
5.6	Trouble shooting with causes and remedial measures				
5.7	Routine operational checks, recommended logs & records				
5.8	Changeover schedule if more than one auxiliary for the same purpose is given				
5.9	Painting requirement and schedule				
5.10	Inspection, repair , Testing and calibration procedures				
6.0	MAINTENANCE GUIDELINES FOR PLANT PERSONAL				

Varun Jain

S.A. Khan

Pritesh Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
FORMAT FOR OPERATION AND
MAINTENANCE MANUAL**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B

SECTION : E

REV 02

DATE: JUNE 2016

SHEET 4 OF 4

Sl.no. & Sections	Description	Tick (√)if included in Manual			Remarks
		Yes	No	Not Applicable	
6.1	List of Special Tools and Tackles required for Overhaul/Trouble shooting including special testing equipment required for calibration etc.				
6.2	Stepwise dismantling and re-assembly procedure clearly specifying the tools to be used, checks to be made, records to be maintained, clearances etc. to be mentioned. Tolerances for fitment of various components to be given.				
6.3	Preventive Maintenance & Overhauling schedules linked with running hours/calendar period along with checks to be given				
6.4	Long term maintenance schedules especially for structural, foundations etc.				
6.5	Consumable list along with the estimated quantity required during commissioning, normal running and during maintenance like Preventive Maintenances and Overhaul. Storage/handling requirement of consumables/self-life.				
6.6	List of lubricants with their Indian equivalent, Lubrication Schedule, Quantity required for each equipment for complete replacement is to be given				
6.7	List of vendors & Sub-vendors with their latest addresses, service centres ,Telephone Nos., Fax Nos., Mobile Nos., e-mail IDs etc.				
6.8	List of mandatory and recommended spare parts list				
6.9	Tentative Lead time required for ordering of spares from the equipment supplier				
6.10	Guarantee and warranty clauses				
7.0	Statutory and other specific requirements considerations.				
8.0	List of reference documents				
9.0	Binding as per requirement				

Varun Jain

S.A. Khan

Praveen Kishore



**2x500 MW NTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
SITE STORAGE AND PRESERVATION**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : II B

SECTION : E


REV 02

DATE: JUNE 2016


SHEET 1 OF 16

ANNEXURE-XI

SITE STORAGE AND PRESERVATION


Varun Jain


S A Khan


Praveen Kishore

SITE STORAGE AND PRESERVATION GUIDELINES


FOR

MECHNANICAL BOPs

(Doc No: PE-DC-SSG-A001 REV.00)



**PROJECT ENGINEERING MANAGEMENT, POWER SECTOR
BHARAT HEAVY ELECTRICALS LIMITED-NOIDA**



Varun Jain


S A Khan


Praveen Kohore

CONTENT

- 1 SCOPE OF THE DOCUMENT
- 2 PURPOSE OF STORAGE & PRESERVATION
- 3 MEASURES TO BE TAKEN FOR STORAGE AND PRESERVATION
 - a) GENERAL STORAGE REQUIREMENTS
 - b) GENERAL PRESERVATION REQUIREMENTS
 - c) GENERAL INSPECTION REQUIREMENTS
- 4 TYPE OF STORAGE FOR VARIOUS EQUIPMENT
5. CONCLUSION
6. STACKING ARRANGEMENT FOR PLATES AND STRUCTURAL STEEL


Varun Jain


S A Khan


Praveen Kohore

1. SCOPE OF THE DOCUMENT

This guideline is prepared in intent to provide proper site storage and preservation of the Mechanical, Electrical and C & I items / equipment supplied under various bought out packages/items. This storage procedure shall be followed at different power plant sites by concerned agency for storage and preservation from the date of equipment received at site until the same are erected and handed over to the customer.


2. PURPOSE OF STORAGE & PRESERVATION

Many of the items may be required to be kept in stores for long period. It shall therefore be essential that proper methods of storage and preservation be applied so that items do not deteriorate, loose some of their properties and become unusable due to atmospheric conditions and biological elements.

3. MEASURES TO BE TAKEN FOR STORAGE, HANDLING & PRESERVATION

a) GENERAL STORAGE REQUIREMENTS

1. To the extent feasible, materials should be stored near the point of erection. The storage areas should have adequate unloading and handling facilities with adequate passage space for movement of material handling equipment such as cranes, fork lift trucks, etc. The storage of materials shall be properly planned to minimise time loss during retrieval of items required for erection.
2. The outdoor storage areas as well as semi-closed stores shall be provided with adequate drainage facilities to prevent water logging. Adequacy of these facilities shall be checked prior to monsoon.
3. The storage sheds shall be built in conformity with fire safety requirements. The stores shall be provided with adequate lights and fire extinguishers. 'No smoking' signs shall be placed at strategic locations. Safety precautions shall be strictly enforced.
4. Adequate lighting facility shall be provided in storage areas and storage sheds and security personnel positioned to ensure enforcement of security measures to prevent theft and loss of materials.
5. Adequate number of competent stores personnel and security staff shall be deployed to efficiently store and maintain the equipment / material.
7. The equipment shall be stored in an orderly manner, preserving their identification slips, tags and instruction booklets, etc., required during erection. The storage of materials shall be equipment-wise. Loose parts shall be stored in sheds on racks,


Varun Jain


S A Khan



Praveen Kishore

preserving the identification marks and tags in good condition. The group codes shall be displayed on the racks

6. At no time shall any materials be stored directly on ground. All materials shall be stored minimum 200 mm above the ground preferably on wooden sleepers

b) GENERAL PRESERVATION REQUIREMENTS

1. All special measures to prevent corrosion shall be taken like keeping material in dry condition, avoiding the equipment coming in contact with corrosive fluid like water, acid etc.
2. Materials which carry protective coating shall not be wrapped in paper, cloth, etc., as these are liable to absorb and retain moisture. The material shall be inspected and in case of signs of wear or damages to protective coating, that portion shall be cleaned with approved solution and coated with an approved protective paint. Complete record of all such observations and protective measures taken shall be maintained.
3. Generally equipment supplied at site are properly greased or rust protective oil is applied on machined/ fabricated components. However periodic inspection shall be carried out to ensure that protection offered is intact.
4. While handling the equipment, no dragging on the ground is permitted. Avoid using wire rope for lifting coated components. Use polyester slings (if possible) otherwise protective material (e.g. clothes, wood block etc.) should be used while handling the components with rope / slings
5. For Equipment supplied with finished paint, touch paint shall be done in case any surface paint gets peeled off during handling. Otherwise such surfaces shall necessarily be wrapped with polythene to avoid any corrosion. Further for equipment wherein finish coat is to be applied at site, site to ensure that equipment is received with primer coat applied.
6. It shall be ensured by periodic inspection that plastic inserts are intact in tapped holes, wherever applicable.
7. Pipes shall be blown with air periodically and it shall be ensured that there is no obstruction.
8. Silica gel or approved equivalent moisture absorbing material in small cotton bags shall be placed and tied at various points on the equipment, wherever necessary.
9. Heavy rotating parts in assembled conditions shall be periodically rotated to prevent corrosion/jamming due to prolonged storage.


Varun Jain


S A Khan


Praveen Kishore

10. All the electrical equipment such as motors, generators, etc. shall be tested for insulation resistance at least once in three months and a record of such measured insulation values shall be maintained.
11. Following preservatives/preservation methods can be used depending upon type of equipment
 - a. Rust preventive fluid (RPF)
 - b. Rust protective paints
 - c. Tarpaulin covers, in case of outdoor storage
 - d. De-oxy aluminate for weld-ments

c) GENERAL INSPECTION REQUIREMENTS

1. Period inspection of materials with specific reference to –
 - Ingress of moisture and corrosion damages.
 - Damage to protective coating.
 - Open ends in pipes, vessels and equipment -
 - In case any open ends are noticed, same shall be capped.
2. Any damages to equipment / materials.
 - In case of any damages, these shall be promptly notified and in all cases, the repairs / rectification shall be carried out.
 - Any items found damaged or not suitable as per project requirements shall be removed from site. If required to store temporarily, they shall be clearly marked and stored separately to prevent any inadvertent use.


Varun Jain


S A Khan


Praveen Kohore

4. TYPE OF STORAGE FOR VARIOUS EQUIPMENT

The types of storage are broadly classified under the following heads:

i **Closed storage with dry and dust free atmosphere. (C)**


The closed shed can be constructed by using cold-rolled / tubular components for structure and corrugated asbestos sheets / galvanised iron sheets for roofing. Brick walls / asbestos sheets can be used to cover all the sides. The floor of the shed can be finished with plain cement concrete suitably glazed. The shed shall be provided with proper ventilation and illumination.



ii **Semi-closed storage. (S)**

The semi closed shed can be constructed by using cold-rolled / tubular components for structure and corrugated / asbestos sheets for roofing. The floor shall be brick paved. If required a small portion of sides can be covered to protect components from rainwater splashing onto the components.




Varun Jain


S A Khan


Praveen Kohore



iii Open storage (O)

The open yard shall be levelled, well consolidated to achieve raised ground with the provision of feeder roads for crane approach along with access roads running all sides. One part of the open yard shall be stone pitched, levelled and consolidated with raised ground suitable for storing / stacking heavier and critical components with due space to handle them by cranes etc . Adequate number of sleepers, concrete block etc. to be provided to make raised platforms to stack critical materials.


A separate yard to be identified as “scrap yard” slightly away from main open yard to store wooden/steel scraps, which are to be disposed off. This is required to avoid mix up with regular components as well as to avoid fire hazard.

Some of the components, which are having both machined & un-machined surfaces and are bulky, shall be stored in open storage area on a raised ground and suitably covered with water proof / fire retardant tarpaulin.



The equipment listed below shall be stored and inspected as per requirement mentioned in the table below.


Sl. No.	Description of the equipment	Type of Storage	Check for	Remarks
Raw material /mechanical items like pipes, plates, structure sections etc.)				
1.	Steel pipes (lined/unlined)	S	Damage , paint, corrosion, rubber lining peeling	Provide end cap
2.	MS Plates	S	Damage, paint, corrosion	
3.	SS Plates	S	Damage	
4.	Non-metallic pipes	S	Damage, cracks	Provide end cap
5.	Stainless steel pipes	S	Damage ,	Provide end cap
6.	MS sections, beams	S	Damage, paint, corrosion	
7.	Cable trays	S	Damage, condition of preservations	
8.	Insulation sheets	S	Damage	
9.	Insulation	C	Damage, packing	
10.	Hangers Rods	S	Damage, paint, packing	
11.	Tubes	S	Damage, paint , packing	Provide end cap
12.	Hume pipes	O	Damage	
13.	Castings	O	Damage, paint, corrosion	
Fabricated mechanical items (pressure vessels, tanks etc.)				
14.	Pressure vessels (unlined)	O	Damage, paint, corrosion,	Covered nozzles
15.	Atmospheric storage tanks (unlined)	O	Damage, paint, corrosion	Covered nozzles


Varun Jain


S A Khan


Praveen Kishore


Sl. No.	Description of the equipment	Type of Storage	Check for	Remarks
16.	Pressure vessels (lined)	S	Damage, paint, corrosion, rubber lining	
17.	Atmospheric storage tanks(lined)	S	Damage, paint, corrosion, rubber lining	
18.	Support structures	O	Damage , paint, corrosion	
19.	Flanges	C	Damage , paint, corrosion	
20.	Fabricated pipes	S	Damage , paint, corrosion	Provide end cap
21.	Vessels internals	C	Damage , paint, corrosion ,packing	
22.	Grills	S	Damage , paint, corrosion	
23.	Angles	S	Damage , paint, corrosion	
24.	Bridge mechanism/clarifier mechanism	O	Damage , paint, corrosion	
25.	Cranes, rails	S	Damage , paint, corrosion	
26.	Stair cases	O	Damage , paint, corrosion	
27.	Ladders/handrails	O	Damage , paint, corrosion	
28.	Fabricated ducts	S	Damage , paint, corrosion	
29.	Isolation Gates	O	Damage , paint, corrosion	
30.	Fabricated boxes/panels	S	Damage , paint, corrosion	
Mechanical components like valves, fittings, cables glands, spares etc.)				
31.	Valves	S	Damage , packing	


Varun Jain


S A Khan


Praveen Kishore


Sl. No.	Description of the equipment	Type of Storage	Check for	Remarks
32.	Fittings	S	Damage , packing	Provide end cap
33.	Cable glands	C	Damage , packing	
34.	Tools & tackles	C	Damage , packing	
35.	Nut , bolts, washers,	C	Damage , packing	
36.	Gasket & Packings	C	Damage , packing	
37.	Copper tubes	C	Damage , packing, corrosion	Provide end cap
38.	SS tubing	C	Damage , packing	Provide end cap
Rotating assemblies (pumps, blowers, stirrers, fans, compressors etc.)				
39.	Pumps	S	Damage , packing, corrosion	Shaft rotation
40.	Blowers/Compressors	S	Damage , packing, corrosion	Shaft rotation
41.	Agitators/stirrers/radial launders	C	Damage , packing, corrosion	Shaft rotation
42.	Rollers for chlorine tonner mounting	C	Damage , packing, corrosion	
43.	Centrifuge	S	Damage , packing,	
44.	Gear box	C	Damage , packing, corrosion	
45.	Bearings	C	Damage , packing, corrosion	
46.	Fans	S	Damage , packing, corrosion	
47.	Dosing skids	S	Damage , packing, corrosion	
48.	Pump assemblies	S	Damage , packing, corrosion	
49.	Air washers(INTERNALS)	S	Damage , packing	
50.	Air conditioners (split)	C	Damage , packing	


Varun Jain


S A Khan


Praveen Kishore


Sl. No.	Description of the equipment	Type of Storage	Check for	Remarks
51.	Elevators(CONTAINERIZED)	O	Damage , packing, corrosion	
52.	Chillers/VA machines	S	Damage , packing	
53.	Air handling Unit/Package unit	S	Damage , packing	
54.	Chlorinators & Evaporators	C	Damage , packing	
55.	Ejectors	C	Damage , packing	
56.	Electrolyser	C	Damage , packing	
Miscellaneous items like chain pulley blocks, hoists etc.				
57.	Chain pulley blocks	S	Damage, Packing	
58.	Electric hoists	S	Damage, Packing	
59.	Fire extinguishers	C	Damage, expiry date	
60.	Fork Lift Truck	S	Damage, Packing	
61.	Hydraulic Mobile Crane	O	Damage, Packing	
62.	Mobile Pick Up & Carry Crane	O	Damage, Packing	
63.	Motor boats	O	Damage, Packing	
64.	Safety showers	S	Damage, Packing	
65.	Diffusers/dampers	S	Damage, Packing	
Chemicals and consumables (acid, alkali, paints, oils, reagents and special chemicals)				
66.	Hydro Chloric Acid (HCl)	Store in canes/ storage tank in dyke area	Date of production/ leakage/fumes	hazardous chemical
67.	Sulphuric acid (H ₂ SO ₄)	Store in canes/ storage tank in dyke area	Date of production/ leakage/fumes	hazardous chemical


Varun Jain


S A Khan


Praveen Kishore


Sl. No.	Description of the equipment	Type of Storage	Check for	Remarks
68.	Sodium hydroxide (NaOH)	Store in canes/ storage tank in dyke area	Date of production/ leakage/ fumes/ breather	hazardous chemical ,breather to be checked for air ingress
69.	Sodium hypo chlorite	To be stored under shed	Date of production/ leakage/ fumes	hazardous chemical ,self-life normally 15-30 days after which strength of chemical decays
70.	Ammonia	S	Date of production/ leakage/ fumes	Store in closed storage tanks, hazardous chemical
71.	CW treatment chemicals	S	Date of production , Self-life	Store in closed canes
72.	RO/UF cleaning chemicals	S	Date of production , Self-life	Store in closed canes
73.	Lime	C	Damage to packing , seepage	Prevent moisture, rain
74.	Alum bricks	C	Damage to packing	Prevent moisture, rain
75.	Poly electrolyte	S		Store in closed storage tanks
76.	Laboratory chemicals(powder)	C	Damage, Packing self- life	
77.	Laboratory chemicals(liquid)	C	Damage, Packing self- life	
78.	Lubrication oils	C	Leakage	
79.	Paints	S	Leakage ,air tightness	
80.	Sand	O	Damage of packing	No hooks
81.	Salt (NaCl)	C	Damage of packing, water ingress	Prevent moisture, rain
82.	Anthracite	S	Damage of packing	
83.	Activated carbon	S	Damage of packing	


Varun Jain


S A Khan


Praveen Kishore

Sl. No.	Description of the equipment	Type of Storage	Check for	Remarks
84.	Thermal insulation	S	Damage of packing	
85.	Cement	C	Damage of packing	Prevent moisture, rain
86.	Gravels	O	Damage of packing	
87.	ION exchange resins	C	Damage , packing	Refer manufacturer guidelines
88.	RO membranes	C	Damage , packing	Refer manufacturer guidelines
89.	UF membranes	C	Damage , packing	Refer manufacturer guidelines
90.	Cleaning chemicals	C	Damage , packing	Refer manufacturer guidelines
91.	Chemicals for analysers/calibration	C	Damage , packing	Refer manufacturer guidelines
Electrical and C & I items (motors, cables etc.)				
92.	Motors	C	Damage , packing	
93.	Cable drums	O	Damage	
94.	Control Panel /control desk, UPS ,JB	S	Damage, Packing	
95.	Instruments(gauges/analysers)	C	Damage	
Special items		As per Manufacturer's item, like Hydrogen cylinders, Ozonator, Analyser, Chlorine dioxide generators etc.		


Varun Jain


S A Khan


Praveen Kishore

5. CONCLUSION

Concerned storage agency at site should make sure that loss in equipment performance and wear & tear are minimised through proper storage and preservation. The above are broad guidelines and cover major equipment / materials. However specific storage practices shall be followed as per manufacturer recommendation. All the necessary measures even in addition to the ones mentioned above, if found necessary, should be taken to achieve the objective.


Varun Jain


S A Khan


Praveen Kohore




Figure – 1 – PLATE STACKING ARRANGEMENT




Figure – 2 – STRUCTURAL STEEL STACKING ARRANGEMENT



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM**


SPECIFICATION No: PE-TS-400-553-A001

VOLUME: III

REV. 02

DATE: JUNE 2016

VOLUME III


Varun Jain


S A Khan


Praveen Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
LIST OF DOCUMENTS TO BE SUBMITTED WITH
BID**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME : III

SECTION : 1


REV: 02

DATE: JUNE 2016


SHEET 1 OF 1

**BIDDER SHOULD SUBMIT THE SIGNED AND STAMPED COPY OF THE
FOLLOWING DOCUMENTS:**

1. Compliance cum confirmation certificate
2. Guaranteed power consumption
3. Un priced format for main package
4. Un priced format for mandatory spare
5. Complete set of technical specification
6. No deviation certificate
7. Pre bid clarification schedule


Varun Jain


S A Khan


Praveen Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
COMPLIANCE CUM CONFIRMATION
CERTIFICATE**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME: III

SECTION: 2

REV. NO. 02

DATE: JUNE 2016

SHEET: 1 OF 2

COMPLIANCE CUM CONFIRMATION CERTIFICATE

The bidder shall confirm compliance with following by signing / stamping this compliance certificate (every sheet) and furnish same with the offer.

- a) The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions, other than those mentioned under "exclusion and those resolved as per 'Schedule of Deviations', with regard to same.
- b) There are no other deviations w.r.t. specifications other than those furnished in the 'Schedule of Deviations'. Any other deviation, stated or implied, taken elsewhere in the offer stands withdrawn unless specifically brought out in the 'Schedule of Deviations'
- c) Bidder shall submit QP in the event of order based on the guidelines given in the specification & QP enclosed therein. QP will be subject to BHEL / CUSTOMER approval & customer hold points for inspection / testing shall be marked in the QP at the contract stage. Inspection / testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc. This is within the contracted price without any extra implications to BHEL after award of the contract.
- d) All drawings/ data-sheets / calculations etc. submitted along with the offer shall not be taken cognizance off.
- e) The offered materials shall be either equivalent or superior to those specified in the specification & shall meet the specified / intended duty requirements. In case the material specified in the specifications is not compatible for intended duty requirements then same shall be resolved by the bidder with BHEL during the pre-bid discussions, otherwise BHEL / Customer's decision shall be binding on the bidder whenever the deficiency is pointed out.

For components where materials are not specified, same shall be suitable for intended duty, all materials shall be subject to approval in the event of order.

- f) The commissioning spares shall be supplied on 'As Required Basis' & prices for same included in the base price itself.
- g) All sub vendors shall be subject to BHEL / CUSTOMER approval in the event of order.
- h) Guarantee for plant/equipment shall be as per relevant clause of GCC / SCC / Other Commercial Terms & Conditions
- i) In the event of order, all the material required for completing the job at site shall be supplied by the bidder within the ordered price even if the same are additional to approved billing break up, approved drawing or approved Bill of quantities within the scope of work as tender specification. This clause will apply in case during site

Varun Jain

S.A. Khan

Praveen Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
COMPLIANCE CUM CONFIRMATION
CERTIFICATE**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME: III

SECTION: 2

REV. NO. 02

DATE: JUNE 2016

SHEET: 2 OF 2

commissioning, additional requirements emerges due to customer and / or consultant's comments. No extra claims shall be put on this account

- j) Schedule of drawings submissions, comment incorporations & approval shall be as stipulated in the specifications. The successful bidder shall depute his design personnel to BHEL's / Customer's / Consultant's office for across the table resolution of issues and to get documents approved in the stipulated time.
- k) As built drawings shall be submitted as and when required during the project execution.
- l) The bidder has not tempered with this compliance cum confirmation certificate and if at any stage any tempering in the signed copy of this document is noticed then same shall be treated as breach of contract and suitable actions shall be taken against the bidder.
- m) Successful bidder shall furnish detailed erection manual for each of the equipment supplied under this contract at least 3 months before the scheduled erection of the concerned equipment / component or along with supply of concerned equipment / component whichever is earlier.
- n) Document approval by customer under Approval category or information category shall not absolve the vendor of their contractual obligations of completing the work as per specification requirement. Any deviation from specified requirement shall be reported by the vendor in writing and require written approval. Unless any change in specified requirement has been brought out by the vendor during detail engineering in writing while submitting the document to customer for approval, approved document (with implicit deviation) will not be cited as a reason for not following the specification requirement.
- o) In case vendor submits revised drawing after approval of the corresponding drawing, any delay in approval of revised drawing shall be to vendor's account and shall not be used as a reason for extension in contract completion.

Varun Jain

S.A. Khan

Praveen Kishore



**2x500 MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
PRE-BID CLARIFICATION SCHEDULE**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME: III

SECTION: 3

REV. NO. 02

DATE: JUNE 2016

SHEET: 1 OF 1

PRE-BID CLARIFICATION SCHEDULE

S. NO.	SECTION/CLAUSE/PAGE NO.	STATEMENT OF THE REFERRED CLAUSE	CLARIFICATION REQUIRED

The bidder hereby clarifies that above mentioned are the only clarifications required on the technical specification for the subject package.

Signature: _____


Name: _____

Designation: _____


Company: _____

Date: _____

Company Seal


Varun Jain


S.A. Khan


Praveen Kishore



**2x500MW NNTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
GAURANTEE POWE CONSUMPTION**

SPECIFICATION No: PE-TS-400-553-A001

VOLUME: III

SECTION: 5

REV. NO. 02

DATE: JUNE 2016

SHEET: 1 OF 2

S.NO.	DESCRIPTION OF EQUIPMENT	NO OF EQUIPMENT		TOTAL POWER CONSUMPTION FOR EACH EQUIPMENT AT MOTOR INPUT TERMINAL AND CONTROL PANEL (IN KW)	GUARANTEED CONSUMPTION	DUTY FACTOR	TOTAL KW
		WORKING	STAND BY				
		3A	3B	4		5	6=3Ax4x5
1	AC-Plant-1:						
1.1	Water chilling machine – Screw/Scroll chiller	1	1			1	
1.2	Cooling tower fans for AC plant	1	1			1	
1.3	Condenser water pumps for AC plant	1	1			1	
1.4	Chilled water pumps for AC plant	1	1			1	
1.5	AHUs for ESP control room bld. Unit-1	2	1			1	
1.6	AHUs for ESP control room bld. Unit-2	2	1			1	
				TOTAL (KW)			
NOTES:							
1	Estimated power consumption (EPC) figure at motor input terminals (not shaft power) for the system (for working drives only) shall not be more than 139.8 KW.						

Varun Jain
Varun Jain

S.A. Khan
S.A. Khan

Praveen Kishore
Praveen Kishore



**2x500 MW NTPP
SG PACKAGE
AIR CONDITIONING SYSTEM
SUGGESTIVE PRICE FORMAT**

SPECIFICATION No: PE-TS-400-553-A001


VOLUME : III

SECTION : 6

REV 02

DATE: JUNE 2016

SUGGESTIVE PRICE FORMAT


Varun Jain


S A Khan


Praveen Kishore

AC SYSTEM FOR 2x500 MW NEW NEYVELLI TPP (SG PACKAGE) --- SUGGESTIVE PRICE FORMAT

SL No	DESCRIPTION OF EQUIPMENT/ ITEM	QTY	UNIT	SUPPLY						ERECTION AND COMMISSIONING				TOTAL	
				Unit Price (Rs)	Total ex-works price (Rs)	ED (Inc CESS) (Rs)	CST / VAT (Rs)	Freight (Including service tax, if applicable) (Rs)	TOTAL FOR price site SUPPLY (Rs)	Unit Price (Rs)	Total price (Rs)	Service Tax (Rs)	TOTAL PRICE (Erection and commissioning including Service tax)	Total Price Supply FOR site and E&C including service tax (Rs)	
1	LUMPSUM PRICES														
1.1	Total lumpsum firm prices for equipment & Services as specified, Comprising Engineering, design, manufacture, inspection & Testing at manufacturers works/subvendor's work, Painting at manufactures works, duty packed for transportation, delivery to site, unloading storage & handling at site, erection & commissioning, minor civil works as required, carrying out acceptance tests at site, final painting and handing over to customer the complete AC system on turnkey basis for 2X500 MW NNTPP as per specification PE-TS-400-553-A001 R02 including special tool & tackels for maintenance, commissioning spares, Mandatory spares, all taxes, duties etc														
2	Break up prices for items covered in clause 1.1 above														
3	AC-Plant-1: ESP CONTROL ROOM BUILDING														
3.1	Microprocessor controlled, water cooled chiller package each of minimum capacity 80 TR consisting of Hermetic/ semi - Hermetically sealed Screw/Scroll type refrigerant compressor operating on R134a refrigerant complete with motor, unit mounted starter, complete with suction and discharge shut off valves, HP / LP cutouts, oil pressure failure switch, gauge panel, automatic capacity control; Condenser, relief valve, chiller, controls such as thermostatic/electronic expansion valve, cooling thermostat, antifreeze thermostat, water flow switch, integral refrigerant pipes & fittings, strainer, sight glass, isolating valves, chiller drain valve, chiller insulation, refrigerant piping insulation, first charge of gas and oil, base frames, vibration isolators, integral wiring, unit mounted isolator / fuse switch and other accessories as specified.	2	NO												
3.2	Sheet metal cabinet type air handling units (double skin as per specification) consisting of chilled water cooling coil, centrifugal blower, TEFC sq cage induction motor, drive set, filters (pre, fine and HEPA filters), 3 way motorised mixing valve with thermostatic controls and other accessories to meet AC load of control room areas at ESP-1 and ESP-2 building. Fine and HEPA Filters shall be provided at the discharge of each individual AHUs.	6	NO												
3.3	Fibreglass reinforced plastic (FRP) construction cooling towers complete with fan, VFD driven motor along with VFD, FRP basin, nozzles, make-up water & quick fill water connection, Level Switch, drains, piping, valves, strainers, ladder & all accessories as specified.	2	NO												

AC SYSTEM FOR 2x500 MW NEW NEYVELLI TPP (SG PACKAGE) --- SUGGESTIVE PRICE FORMAT														
SL No	DESCRIPTION OF EQUIPMENT/ ITEM	QTY	UNIT	SUPPLY						ERECTION AND COMMISSIONING				TOTAL
				Unit Price (Rs)	Total ex-works price (Rs)	ED (Inc CESS) (Rs)	CST / VAT (Rs)	Freight (Including service tax, if applicable) (Rs)	TOTAL FOR site price SUPPLY (Rs)	Unit Price (Rs)	Total price (Rs)	Service Tax (Rs)	TOTAL PRICE (Erection and commissioning including Service tax)	Total Price Supply FOR site and E&C including service tax (Rs)
3.4	Centrifugal pump sets for condenser water recirculation complete with TEFC motor & all accessories as specified.	2	NO											
3.5	Centrifugal pump sets for chilled water recirculation complete with TEFC motor & all accessories, as specified.	2	NO											
3.6	MS, Make up, Tank 2 cubm (Inner surface for MS Tank - spray galvanised). Make up water line with float valve & backup, quick fill line with ball valve, drain line with ball valve, overflow & vent line, level gauge shall be provided).	1	NO											
3.7	MS, soft water storage, Tank 8 cubm (Inner surface for MS Tank - spray galvanised). Make up water line with float valve & backup, quick fill line with ball valve, drain line with ball valve, overflow & vent line, level gauge shall be provided).	2	NO											
3.8	MS chilled water Expansion Tank 1 cubm (insulated) with all accessories as required.	1	NO											
3.9	Water softening plant with pump set and all the accessories as required to meet system requirement.	2	NO											
3.10	CONDENSER WATER PIPING with necessary fittings like tees, reducers, expanders, elbows, flanges, all types of valves with flanges, strainers with flanges, air vents etc as per specifications.	1	LOT											
3.11	INSULATED CHILLED WATER PIPING with necessary fittings like tees, reducers, expanders, elbows, flanges, all types of valves with flanges, strainers with flanges, air vents etc as per specifications.	1	LOT											
3.12*	MS medium class DRAIN WATER PIPING from various equipment like cooling tower (including equalising line), condenser water pumps, AHU, FCU, Chilled water pump etc upto nearest available drain point with necessary fittings like tees, reducers, expanders, elbows, flanges, valves with flanges, P trap etc as per specifications. Piping serving chilled water shall be insulated as per specification , whereas piping serving condenser water shall be uninsulated.													
3.12.1*	50mm	100	RMT*											
3.12.2*	40mm	50	RMT*											
3.13	Monsoon reheating/ winter heating kit comprising strip heaters, safety controls, air-stat, contactors, frame work, thermostat & humidistat/ sensors etc.	1	LOT											
3.14	Pan type humidifier for each AHU room complete with humidistat, safety controls, make up water piping from make up tank / nearest source of water, valves fittings etc	1	LOT											

AC SYSTEM FOR 2x500 MW NEW NEYVELLI TPP (SG PACKAGE) --- SUGGESTIVE PRICE FORMAT

SL No	DESCRIPTION OF EQUIPMENT/ ITEM	QTY	UNIT	SUPPLY						ERECTION AND COMMISSIONING				TOTAL	
				Unit Price (Rs)	Total ex-works price (Rs)	ED (Inc CESS) (Rs)	CST / VAT (Rs)	Freight (Including service tax, if applicable) (Rs)	TOTAL FOR site price SUPPLY (Rs)	Unit Price (Rs)	Total price (Rs)	Service Tax (Rs)	TOTAL PRICE (Erection and commissioning including Service tax)	Total Price Supply FOR site and E&C including service tax (Rs)	
3.15	FRESH AIR FANS (axial flow type), complete with motor, inlet cone, air filters (pre and fine), dampers, etc.	1	LOT												
3.16*	FAN COIL UNIT consisting of chilled water cooling coil, blower, motor, driveset, filters (prefilter), 3way motorised mixing valve with thermostatic controls and other accessories as per specifications														
3.16.1*	3 TR	1	NO*												
3.16.2*	2TR	1	NO*												
3.16.3*	1.5 TR	1	NO*												
3.17*	Fire damper.														
3.17.1*	Fire damper with auto resetting, limit switches, indication lamps etc.	10	SQM*												
3.17.2*	Motorized actuator with single phase power supply for the above fire damper.	12	NO*												
3.18*	Finished GSS ductwing fabricated from GSS having zinc coating 275 gms/m ² ducting complete with hangers, supports, gaskets, splitters etc.														
3.18.1*	18G.	400	SQM*												
3.18.2*	20G.	1200	SQM*												
3.18.3*	22G.	50	SQM*												
3.18.4*	24G.	50	SQM*												
3.19*	SUPPLY AIR DIFFUSERS / GRILLS with VCD (Extruded Aluminium powder coated) complete with fixing frames, nuts, bolts, gaskets, washers etc.	10	SQM*												
3.20*	RETURN AIR DIFFUSERS / GRILLS without VCD (Extruded Aluminium powder coated) complete with fixing frames, nuts, bolts, gaskets, washers etc	10	SQM*												
3.21*	VOLUME CONTROL DAMPERS in GI construction as per specifications for supply / return ducts complete with fixing arrangement.	5	SQM*												
3.22*	ACOUSTIC INSULATION of ducting from AHU outlets with material and finish as per specifications	1	LOT												
3.23*	THERMAL INSULATION of supply air duct & return air duct with material and finish as per specifications.	1700	SQM*												
4	Field instruments like pressure gauge, temperature gauge, pressure switch, differential pressure switch, flow switch, flow meters, and other required instruments as per specifications	1	LOT												


AC SYSTEM FOR 2x500 MW NEW NEYVELLI TPP (SG PACKAGE) --- SUGGESTIVE PRICE FORMAT														
SL No	DESCRIPTION OF EQUIPMENT/ ITEM	QTY	UNIT	SUPPLY						ERECTION AND COMMISSIONING				TOTAL
				Unit Price (Rs)	Total ex-works price (Rs)	ED (Inc CESS) (Rs)	CST / VAT (Rs)	Freight (Including service tax, if applicable) (Rs)	TOTAL FOR site price SUPPLY (Rs)	Unit Price (Rs)	Total price (Rs)	Service Tax (Rs)	TOTAL PRICE (Erection and commissioning including Service tax)	Total Price Supply FOR site and E&C including service tax (Rs)
5	AC System for Aux. building													
5.1*	Air-cooled split type AC units consisting of outdoor unit (having compressor condenser coil with fan and motor), indoor unit (having evaporator coil,filter, fan with motor), inter connecting refrigerant piping as per site requirement & fittings with insulation, cordless remote,electrical power cord upto the nearest available point along with isolator/MCB, fixing frame for indoor & out door unit, stabilizer etc.													
5.1.1*	5.0 TR capacity (ductable type, 415 V, 3 phase with isolation switch).	5	NO*											
5.1.2*	2.0 TR capacity (non-ductable type, 240 V, 1 phase isolation switch) with isolation switch , i.e MCB of suitable rating as specified.(Minimum BEE Rating 5 Star for non ductable units).	6	NO*											
5.1.3*	1.5 TR capacity (non-ductable type, 240 V, 1 phase isolation switch) with isolation switch , i.e MCB of suitable rating as specified. (Minimum BEE Rating 5 Star for non ductable units).	1	NO*											
6*	Manually operated, platform trolley of 1 Ton capacity with base area 2m x 1.5m	3	NO*											
7*	Air curtain (for minimum door height 3 m and width 3 feets)	2	NO*											
8	Total lumpsum price for special tools & tackles for maintenance inclusive of packing forwarding, transportation up to site, etc. (Bidder shall submit item-wise price break-up).	1	LOT											
9	Total lumpsum price for commissioning spares inclusive of packing forwarding, transportation up to site, etc. (Bidder shall submit item-wise price break-up).	1	LOT											
10	Total lumpsum price for Mandatory Spare for air conditioning inclusive of packing forwarding, transportation up to site, etc. (Bidder to submit item-wise price break-up).	1	LOT											
11	Any other item not indicated above, but required to make the system complete in all respects.	1	LOT											

NOTES

- 1 The bidder shall furnish unit rates for variable item (marked *) for necessary adjustment (plus or minus) variation during detailed engg. stage.
- 2 Price format shall not be changed by the bidder as the bidder may get disqualified by doing so.
- 3 Item mentioned against Sl. No. 6, 8, 9 and 10 are supply item only, E&C for the same is not applicable.

MANDATORY SPARE LIST - 2 x 500 MW NEW NWYVELI SG PACKAGE

SL No	DESCRIPTION OF EQUIPMENT/ ITEM	SUPPLY								
		UNIT	QUANTIT Y	Unit Price (Rs)	Total ex- works price (Rs)	ED including CESS (Rs)	CST / VAT (Rs)	FREIGHT including Service Tax, If applicable (Rs)	TOTAL F.O.R. Site Price Supply (Rs)	REMARKS
1	Contractor (For each type and rating)	No.	Minimum 1 no. of each type							Applicable items considered. Applicable items are those which are installed in the system.
2	Over load relay (For each type and rating)	No.	2 no. of each type							
3	Relay/Timer (For each type and rating)	No.	3 no. of each type							
4	Fan motor (For each type and rating)	No.	30% of each rating							
5	Electronics cards (For each type and rating)	No.	20% of each rating							
6	Switch fuse unit/MCCB/ELCB (For each type and rating)	No.	2 no. of each rating							
7	Blower motor (For each type and rating)	No.	30% of each rating							
8	Pumps (For each type and size)									
8.1	Impeller (For each type and size)	No.	2							
8.2	Shafts (For each type and size)	No.	1							
8.3	Shaft sleeve (For each type and size)	Set	3							
8.4	Casing wear ring (For each type and size)	Set	6							
8.5	Impeller bearing (For each type and size)	Set	2							
8.6	Motor bearing (For each type and size)	Set	2							
8.7	Thrust bearing (For each type and size)	Set	2							
8.8	Radial bearing (For each type and size)	Set	2							
8.9	Gland packing (For each type and size)	Set	2							
8.1	Fasteners (For each type and size)	Set	1							
8.11	Complete coupling (pump & motor) (For each type and size)	Set	1							
8.12	Motor (For each type and rating)	No.	1							


Varun Jain


S A Khan


Praveen Kishore