



**BHARAT HEAVY ELECTRICALS LIMITED**  
 (A Government of India Undertaking)  
 Ramachandrapuram, Hyderabad, 502032, A.P. India  
 Phone:040-23184526, 23182322 FAX:040-23021910, 1954

**भारत हेवी इलेक्ट्रिकल्स लिमिटेड**  
 (भारत सरकार की उपक्रम)  
 रामचन्द्रपुरम, हैदराबाद, 502032 आंध्र प्रदेश, भारत

RFQ NO :

**PURCHASE DEPARTMENT**  
**ENQUIRY**  
**कम विभाग**

ज्याच (ई मेल) : tenderbox@bhelhyd.co.in

**PURCHASE DEPARTMENT**

HY17001 C  
 REV.NO.0

Phone 091-40-23184526  
 091-40-23182322

FAX : 091-40-23021910  
 091-40-23021954

E Mail: tenderbox@bhelhyd.co.in

**Office Copy**

Eng/Collective Number :M1AINI13482

Eng.Date : 26.05.2014

No.Of Items : 1

DUE DATE OF QUOTATION : 16.06.

Please submit your lowest quotation in sealed cover superscribed with Enquiry No. (RFQ No. ....) and due date subject to our conditions attached, for the materials mentioned below. Your offer has to reach us on or before due date by 11.00 Hours (IST) and will be open Hours (IST). If our Enquiry No./Collective No. (RFQ No. ....) and tender due date are not super scribd on the tender cover, your offer summarily rejected. Whosoever desires to send offers on their own risk (complete in all respects) via e-mail have to send offers to the commo address : tenderbox@bhelhyd.co.in. Incomplete offers and late offers will not be considered.

SL NO	Purchase Req.no	item no	Material Code	Drg no - Ver , Rev & Spec - Ver , Rev	Description	Unit	Qty	Delivery Date	Schedule
1	5000013482	10	HY8210541099		1.5 TR W.A.C. WITH ROTARY COMPRESSOR Window Co) Air(A) Conditioner(C)	EA	20.000	30.06.2014	20.06.2014

Special Remarks

- 1) TWO PART BID SYSTEM MAY BE FOLLOWED.
- 2) GCC & ITB ARE ENCLOSED.

TEST CERTIFICATE REQD: Y  
 GUARANTEE REQ : Y  
 SAMPLE REQD : Y  
 BID TYPE : TWO PART

For and on-behalf of  
 Bharat Heavy Electricals A  
 A SAIL OO  
 SR.MANAGER/PUR/CI

SUPPLY OF 1.5 TR ROTARY COMPRESSOR				DT:
Sl.	Specifications / Description for BHEL Requirement		Deviations	Remarks
1	Compressor should be rotary only	Vendor to confirm		
2	Compressor should be suitable for Power Supply -230 V / 50 Hz / 1 Ph	Vendor to confirm		
3	Compressor should be Suitable for R22 Refrigerant	Vendor to confirm		
4	Warranty: ONE YEAR for COMPRESSOR from the date of Supply.	Vendor to confirm		

