

Corrigendum – 2 Dated Oct 29, 2012 to Tender specification BHEL: PSSR: SCT 1517

Some of the bidders sought clarifications in the above tender and the “clarifications issued” are furnished below for your information.

Sl. no	Published in	Existing clause	Bidder’s queries	Clarifications issued
1.	Techno commercial bid Volume-I Book-I Volume-IA Part-I Chapter-XIII Clause no. 1.13.1.3.2.1 (ii) (j)	Conducting 10 % X - ray and 100 % DPT test on all welded joints of conductor and enclosure and arranging the required radiographic and NDT equipment.	<u>Conducting 10% X -Ray on all welded joints of conductor of IP Bus Duct</u> With our previous experience, it is very difficult to conduct radiography with X-Ray for hanging material and it is also difficult to arrange X-Ray source for such small jobs. Hence we request you to kindly allow us to carry out the radiography with Gamma Ray.	Only X-rays are permitted as mentioned in the tender.
2.	Techno commercial bid Volume-I Book-I Volume-IA Part-I Chapter- XIII Clause no. 1.13.2.11	DIESEL GENERATOR SET	- Please clarify the scope for supporting structure (stud) which is embedded in Brick Wall for "Acoustic Insulation - Glass Wool" - Please specify the grouting material type (Ordinary OR Non-shrink) and qty. which is to be supplied by contractor	Fixing of Supporting structure on brick wall is included in the scope. Non shrinkable cement is not required for fixing the studs for the said supporting structure.

All other conditions of the tender remain unchanged

AGM /SCT