

CORRIGENDUM-1 TO TENDER NOTICE BHEL PSSR SCT 1536, dated: 14/11/2015

**One of the bidders sought clarifications in the Tender Specification BHEL PSSR SCT 1536 - Stage II of 1x600 MW at Kakatiya Thermal Power Station for Erection and Commissioning of Control & Instrumentation works.
BHEL reply against the clarifications are furnished below for Information.**

Sl.No.	Item No / Clause	Clarification Required	BHEL Clarification
1	Technical Condition of Contract Clause – VOLUME-1A-page 103-1.10.2.39. ELECTRICAL INSPECTORATE'S APPROVAL:	We request you to kindly remove ELECTRICAL INSPECTORATE'S APPROVAL from our scope. Since it is a Instrumentation Package.	ELECTRICAL INSPECTORATE'S APPROVAL is required.
2	Technical Condition of Contract Clause – VOLUME-1A-page 108-Part-1 Chapter XI Foundation & Grouting. CI.1.11.3 The contractor at his cost shall arrange for grouting of foundation bolt holes of equipments as specified in the drawings / specification or as advised by the Engineer of BHEL after preparing the foundation top surface for grouting all the materials for grouting (sand, gravel & cement including special Cement) shall be Arranged by the contractor. The grouting has to be done upto basement level. The required consumables like Portland cement, gravel, sand etc., have to be provided by the contractor at his cost. The required special cement like conbextra, GP1, GP2, PAGAL, shrinkomp etc., or its equivalent as approved by BHEL If required shall be arranged by the contractor at his cost. It shall be the responsibility of the contractor to obtain prior approval of BHEL, regarding suppliers, type of grouting cements before procurement of grouting cements	We request you to kindly remove Foundation & Grouting Since it is a Instrumentation Package. Also not listed the quantity in SOR as provided by BHEL	Foundation grouting shall be under the bidder's scope since field instruments need grouting.
3	Technical Condition of Contract Clause – VOLUME-1A-page 142. Part-1 Chapter XVI Painting	Kindly provide the approved Vendor list for painting against supply items as mentioned painting of steel items & Impulse piping.	Paint is to be supplied as per IS standards. The vendor approval may be taken from site.

ALL OTHER CONDITIONS REMAIN UNCHANGED. BIDDERS ARE REQUESTED TO SUBMIT THE CORRIGENDUM WITH DULY SIGNED.

[Signature]
GM/HR&CONTRACTS

14/11/15