


Corrigendum – 1 Dated Oct 18, 2013 to Tender specification BHEL: PSSR: SCT 1537

Some of the bidders sought clarifications in the tender and the “clarifications issued” are furnished below for your information.

Sl. no	Published in	Existing clause	Bidder’s queries	Clarifications issued by BHEL																					
1.	Techno commercial bid Volume-I Book-I Volume-IA Part-I Chapter- VI	<p><u>Clause no. 1.6.3.2</u></p> <table border="1" data-bbox="437 432 1356 790"> <thead> <tr> <th data-bbox="444 437 519 478">No</th> <th data-bbox="526 437 1073 478">Mile stone</th> <th data-bbox="1080 437 1349 478">Milestone month</th> </tr> </thead> <tbody> <tr> <td data-bbox="444 483 519 566">01</td> <td data-bbox="526 483 1073 566">Commencement of Condenser erection</td> <td data-bbox="1080 483 1349 566">Expected start of work Dec 2013</td> </tr> <tr> <td data-bbox="444 571 519 616">02</td> <td data-bbox="526 571 1073 616">Commencement of TG erection</td> <td data-bbox="1080 571 1349 616">Jan 2014</td> </tr> <tr> <td data-bbox="444 620 519 665">03</td> <td data-bbox="526 620 1073 665">Turbine Box-up</td> <td data-bbox="1080 620 1349 665">Nov 2014</td> </tr> <tr> <td data-bbox="444 669 519 714">04</td> <td data-bbox="526 669 1073 714">Completion of oil flushing</td> <td data-bbox="1080 669 1349 714">Dec 2014</td> </tr> <tr> <td data-bbox="444 719 519 763">05</td> <td data-bbox="526 719 1073 763">Barring Gear</td> <td data-bbox="1080 719 1349 763">Jan 2015</td> </tr> <tr> <td data-bbox="444 768 519 813">06</td> <td data-bbox="526 768 1073 813">Rolling & Synchronization</td> <td data-bbox="1080 768 1349 813">Feb 2015</td> </tr> </tbody> </table>	No	Mile stone	Milestone month	01	Commencement of Condenser erection	Expected start of work Dec 2013	02	Commencement of TG erection	Jan 2014	03	Turbine Box-up	Nov 2014	04	Completion of oil flushing	Dec 2014	05	Barring Gear	Jan 2015	06	Rolling & Synchronization	Feb 2015	<p>95% of the work would have been completed on completion of synchronization activity. Six months period is on higher side for completing the balance works. Please clarify.</p>	<p>The tender conditions prevail for all milestones including the in-between milestones.</p> <p>The contract duration indicated is inclusive of attending pending points, trial operation and handing over.</p>
		No	Mile stone	Milestone month																					
		01	Commencement of Condenser erection	Expected start of work Dec 2013																					
		02	Commencement of TG erection	Jan 2014																					
		03	Turbine Box-up	Nov 2014																					
		04	Completion of oil flushing	Dec 2014																					
		05	Barring Gear	Jan 2015																					
		06	Rolling & Synchronization	Feb 2015																					
		<p><u>Clause no 1.6.4</u></p> <p>CONTRACT PERIOD: shall be 21 (twentyone) months from the “COMMENCEMENT OF CONTRACT PERIOD” as</p>																							

Sl. no	Published in	Existing clause	Bidder's queries	Clarifications issued by BHEL					
2.	Techno commercial bid Volume-I Book-I Volume-IA Part-I Chapter- IX Clause no. 1.9.1	E1. Boiler Feed Pumps (Motor driven & Turbine Driven)		Recirculation valves and strainers will be normally in Piping scope and local gauge rack in C & I scope. Whether these are included in the scope.	The sl no 8, 9 and 10 shown in the adjacent table are excluded from the scope. For SI no 11, tender conditions prevail. However the total BFPs weight remains unaltered as 141400 MT kg.				
		SL. No.	DESCRIPTION			TOTAL QTY/ UNIT		WEIGHT (kgs) / Item	
						TD BFP (2 nos.)	MD BFP (1 no.)	TD BFP	MD BFP
		8	Re circulation Valve			2	1	1500	1500
		9	Conical Suction Strainer at BFP suction			2	1	1700	1700
10	Basket type Suction Strainer at BP suction	2	1	3000	3000				
11	Local gauge rack- 1,2,&3	6	3	1800	1800				

All other conditions of the tender remain unchanged


18/01/13
Manager / Subcontracts