

Corrigendum -1 Dt. Dec 31, 2013 to Tender specification BHEL: PSSR: SCT 1541

1. The clarifications that were issued by BHEL for the bidders' queries are furnished below:

Sl. No	Published in	Bidder's Query	BHEL's Clarification
1.	<b>Techno commercial bid Volume-I Book - I</b> Volume-IA Part-I Chapter-II Clause No. 1.2.2	If we consider the No. of Joints mentioned in Erection welding sch PGMA. 80-468, The total ID of welding involvement is Approx. 1,08,000 ID, which is not possible to complete within 2 months time. Please Clarify.	The clause 1.2.2 stands deleted
2.	<b>Techno commercial bid Volume-I Book - I</b> Volume-IA Part-I Chapter- VI Clause No. 1.6.3		The following portion is deleted from the clause.  <i>'Buried pipe work for raw water piping and ACW piping is to be commenced immediately and should be completed within 2 month's time'.</i>
3.	<b>Techno commercial bid Volume-I Book - I</b> Volume-IA Part-I Chapter-VIII	<i>In weight Schedule only pipe 914 x 12 mm thk 110 m has been mentioned but in erection welding schedule, the thickness of pipe 914 mm Ø has been mentioned as 10 mm and apart from above other pipe sizes are also mentioned like 3544 mm Ø /1016 mm Ø / 2540 mm Ø. Please Clarify</i>	The pipes of 12 mm thick shall be welded to fittings of 10 mm thick. The pipes of diameter less than 1000 mm only covered in the scope.

  
31/12/13

Sl. No	Published in	Bidder's Query	BHEL's Clarification																		
4.	<b>Techno commercial bid Volume-I Book - I</b> Volume-IA Part-I Chapter-IX Weight schedule		The approximate number of cranes, hoists to be erected under the scope are mentioned below: <table border="1" data-bbox="1518 381 2078 787"> <thead> <tr> <th>Equipment</th> <th>quantity</th> </tr> </thead> <tbody> <tr> <td>Crane -5T</td> <td>1 No</td> </tr> <tr> <td>Crane -8T</td> <td>2 Nos</td> </tr> <tr> <td>Chain pulley block- 2T</td> <td>2 Nos</td> </tr> <tr> <td>Hoist- 2T</td> <td>2 Nos</td> </tr> <tr> <td>Hoist- 3T</td> <td>13 Nos</td> </tr> <tr> <td>Hoist- 5T</td> <td>3 Nos</td> </tr> <tr> <td>Hoist- 8T</td> <td>2 Nos</td> </tr> <tr> <td>Hoist- 12T</td> <td>3 Nos</td> </tr> </tbody> </table>	Equipment	quantity	Crane -5T	1 No	Crane -8T	2 Nos	Chain pulley block- 2T	2 Nos	Hoist- 2T	2 Nos	Hoist- 3T	13 Nos	Hoist- 5T	3 Nos	Hoist- 8T	2 Nos	Hoist- 12T	3 Nos
Equipment	quantity																				
Crane -5T	1 No																				
Crane -8T	2 Nos																				
Chain pulley block- 2T	2 Nos																				
Hoist- 2T	2 Nos																				
Hoist- 3T	13 Nos																				
Hoist- 5T	3 Nos																				
Hoist- 8T	2 Nos																				
Hoist- 12T	3 Nos																				
5.	<b>Techno commercial bid Volume-I Book - I</b> Volume-IA Part-I Chapter-X Clause No. 1.10.2.8 and clause No. 1.10.2.13	<i>As there is no column of electrical item / works in price bid, Please clarify that for what electrical license is required</i>	Both the clauses stand deleted.																		
6.	<b>Techno commercial bid Volume-I Book - I</b> Volume-IA Part-I Chapter-XIII Clause No. 1.13.18	<i>The pressure part and insulation work are not in the scope of this tender. As such please clarify where attachment welding is to be done</i>	The clause stands deleted.																		

*DM*  
31/12/13

Sl. No	Published in	Bidder's Query	BHEL's Clarification
7.	<b>Techno commercial bid Volume-I Book - I</b> Volume-IA Part-I Chapter-XIII Clause No. 1.13.54	<p><i>The clause says that</i>            The surface of the pipes to be joined shall be suitably prepared as per instructions of BHEL Engineers. Edge preparation shall be done <b>by chamfering machine</b>, whenever required and all welding surfaces must be cleaned ..... as per BHEL Engineer's instructions.</p> <p><i>Please confirm from what thickness and upwards of pipe the edge is to be prepared by chamfering machine.</i></p>	<p>The clause is modified as mentioned below:            The surface of the pipes to be joined shall be suitably prepared as per instructions of BHEL Engineers. Edge preparation shall be done <b>as per instructions of BHEL Engineers</b>, whenever required and all welding surfaces must be cleaned ..... as per BHEL Engineer's instructions.</p>
8.	<b>Techno commercial bid Volume-I Book - I</b> Volume-IA Part-I Chapter-XIII Clause No. 1.13.78.6	<p><i>it is mentioned that even wrapping and coating is to be done for GI pipe, please clarify</i></p>	<p>Wrapping coating is not applicable for of GI Piping.</p>
9.	<b>Techno commercial bid Volume-I Book - I</b> Volume-IA Part-I Chapter-XVI Clause No. 1.16.9	<p><i>it is mentioned that even wrapping and coating is to be done for GI pipe, please clarify</i></p>	<p>Wrapping coating is not applicable for of GI Piping.</p>
10.	<b>Techno commercial bid Volume-I Book-I</b> Volume-IA Part-I Chapter-XVIII Clause no. 1.18. 2	<p><i>Please confirm whether the area for effluent disposal shall be provided by BHEL.</i></p>	<p>The area for effluent disposal shall be provided by BHEL within the plant premises.</p>

*DM*  
31/12/13

Sl. No	Published in	Bidder's Query	BHEL's Clarification
11.	<b>Techno commercial bid Volume-I Book - I</b> Volume-IA Part-I Chapter-XVIII Clause No. 1.18.23	Please confirm the duration for which manpower is required for the stated activities.	Tender condition prevails.
12.	<b>Techno commercial bid Volume-I Book - I</b> Volume-IA Part-II Chapter-2	Erection welding schedule for PGMA 80 - 477 and 478 are not provided. Please Provide.	Erection welding schedule for PGMA 80 - 477 already available along with other Erection Welding Schedules. Erection welding schedule for PGMA 80 - 478 shall be provided at site during execution.
13.	<b>Techno commercial bid Volume-II Book - I</b> Price bid	Rate schedule id 1F & 1G of price bid are excluding wrapping and coating. Please confirm what is to be done for Rate schedule id 1E.	Rate schedule id 1E is for those pipes for which bidder shall carry out wrapping and coating.

All other conditions of the tender remain unchanged

  
31/12/13  
Manager / Subcontracts