



An ISO 9001
Company

Tiruchirappalli – 620014, TAMIL NADU, INDIA

MAINTENANCE & SERVICES

Bharat Heavy Electricals Limited

(High Pressure Boiler Plant)

Phone: +91 431 2578445 / 2575916

Fax : +91 431 252 1416

Email : mohans@bheltry.co.in

CORRIGENDUM 01 to NIT_15454

ANNEXURE

Dt:09.11.2013

Providing temporary HT & LT power supply distribution at PEFP project/ Bhandara District/Maharashtra State:

NIT_15454 - Enq.No: 9251300102 Dt. 31.10.2013 / Due on: 25.11.2013

Changes No:	GENERAL INSTRUCTIONS TO TENDERERS (Revised on 18th May, 2013)		
1	Sl. No	ORIGINAL TEXT	REVISED TEXT
	01.	Sealed Tenders enclosed for the work are hereby invited from contractors holding a valid Electrical contractor's license, issued by the Electrical Licensing Board of Govt. of Tamilnadu, experienced in works of similar kind and magnitude.	Sealed Tenders enclosed for the work are hereby invited from contractors holding a valid Electrical contractor's license, issued by Maharashtra State Govt. Electrical Licensing Board , experienced in works of similar kind and magnitude.

TENDER DOCUMENT

LT POWER DISTRIBUTION :

ITEM.No:	ITEM TEXT (ORIGINAL)	REVISED TEXT
2	10/120	
	Excavation of pit size 0.5 M x 0.5 M and depth 1.80 M and erection of the 10 M length/4 mm thick steel tubular poles . The pole shall be painted with one coat of red oxide paint and two coats of aluminum paint . The pit shall be closed by mud mat cement concrete mixture of ratio 1:4:8 (suitable column box shall be used for concreting if the pit is excavated over size) Coping upto a height of 0.6 M with cement concrete mixture of ratio 1:3:6. Suitable cable entries shall be provided in the concrete by supplying PVC pipes and bends. The poles shall be suitably numbered by painting as per the instructions of the Engineer in charge. Note:- All required items for the work are under contractor's scope.	Excavation of pit size 0.5 M x 0.5 M and depth 1.80 M and erection of the 10 M length / 75 mm Dia / 4 mm thick steel tubular poles . The pole shall be painted with one coat of red oxide paint and two coats of aluminum paint . The pit shall be closed by mud mat cement concrete mixture of ratio 1:4:8 (suitable column box shall be used for concreting if the pit is excavated over size) Coping upto a height of 0.6 M with cement concrete mixture of ratio 1:3:6. Suitable cable entries shall be provided in the concrete by supplying PVC pipes and bends. The poles shall be suitably numbered by painting as per the instructions of the Engineer in charge. Note:- All required items for the work are under contractor's scope.

All other terms and conditions as published in the NIT_15454 remain unaltered.

BHEL commercial terms & conditions with Price Bid formats and all annexure can be downloaded from BHEL web site <http://www.bhel.com> or from the Government tender website <http://tenders.gov.in> (public sector units) Bharath Heavy Electricals Limited) under enquiry reference "9251300102 "

Tenders should reach us before **10:00** hours on the due date.
Qualification bid will be opened at **10:30** hours on the due date.
Tenders would be opened in presence of the tenderers who have submitted their offers and who may like to be present.

Yours faithfully,
For Bharat Heavy Electricals Limited