

Corrigendum -1 Dt May 14, 2014 to Tender specification
BHEL: PSSR: SCT 1554

SI no.: 1

published in	Existing	To be read as
Techno commercial bid Volume-I Book - I Notice Inviting Tender Pre Qualification Criteria published in <u>Annexure-3</u>	<p>B. Technical B.2 Bidder should have executed** Erection, testing and commissioning of Electrical works consisting of HT Switch Gears works in a Power Plant in the last seven years reckoned from the date of bid opening.</p> <p>Note to clause B.2 above: Executed** means "Completed the Charging of the Power Transformers rating 200MVA or above, HT Bus Ducts & HT Switch gears"</p>	<p>B. Technical B.2 Bidder should have executed** Erection, testing and commissioning of Electrical works consisting of HT Switch Gears works in a Power Plant in the last seven years reckoned from the date of bid opening.</p> <p>Note to clause B.2 above: Executed** means "Completed the Charging of HT Switch gears"</p>


SI No.:2.

The clarifications issued by BHEL for the queries raised by a bidder are mentioned below:

No	Query raised by Bidder	Clarification issued by BHEL
2.1	Volume - I A Part - I Chapter IX - Bill of Quantity (BOQ) – Clause 1.9.1. Please provide the approximate dimension or weight and elevation of the panels.	<p>The dimension of Excitation panels (clause 1.9.1) are 4056 x 800 x 2415 mm (suite of 5 pieces) and the approximate weight is 3000kg.</p> <p>The Panels location is at TG floor 11.5 meter, main control DCS panel room.</p>

All other terms and conditions remain unaltered.

For and on behalf of Bharat heavy Electricals Ltd.,


 14/05/14
 Manager / Sub Contracts Dept