

CORRIGENDUM -3 TO TENDER SPECIFICATION BHEL PSSR SCT 1590 - DT:20/07/2015

Some of the bidders sought clarifications vide letters in regard to TENDER SPECIFICATION BHEL PSSR SCT 1590 - Civil, Structural and Architectural works of Twin Flue RCC Chimney for 1 x 150TPH RESID Upgradation Project at CPCL, Manali, Chennai and BHEL's clarifications are furnished below for information.

<u>Sl. No.</u>	<u>Reference</u>	<u>Clarification/Query</u>	<u>BHEL REPLY</u>
1	VOLUME-IA PART - I CHAPTER - IV T&PS TO BE DEPLOYED BY CONTRACTOR FOR ENTIRE PACKAGE	<p>Please clarify about the T&PS to be deployed by contractor for entire package.</p> <p>For the nature of work of chimney construction,for casting of pile cap can be arranged RMC and further shell wall concreting can be done through 10/7 mixer machine because the volume of concrete is 8cum per meter and cannot be used for above said item B1 and B2 for shell wall.</p> <p>B3 -Slipform as per requirement shall be deployed.</p> <p>Kindly clarify whether B1 and B2 must be deployed for entire period of chimney construction.Accordingly we have to arrange the same.</p>	<p>Bidder to refer the " NOTE " under 1.4.3 T & P list. It is clearly mentioned that the T&P shown in the list is suggestive and the actual mobilization may be as per actual site requirement.</p>

Note:-

All other Terms & Conditions remain unchanged.

GM / HR & SCT