


CORRIGENDUM -1 TO TENDER SPECIFICATION BHEL PSSR SCT 1611 - DT:01/04/2016

Following clarification was sought by bidder in regard to TENDER SPECIFICATION BHEL PSSR SCT 1611 - Geotechnical Investigation Work & Topographical survey Work at 2 x 800MW Uppur Thermal Power Station, Ramanathapuram Dist., Tamil Nadu and BHEL's clarification is furnished below for information of all.

Sl. No.	Clarification/Query	BHEL REPLY
1	We would like to know weather the Pump out permeability test that are to be conducted at 10, 15 and 20m depth are to be conducted in the same borehole or in three different boreholes.	It is clarified that the pump out permeability test shall be done in separate bore hole at specified depth in each case.

Note:-
All other Terms & Conditions of Tender Specification remain unchanged.
Bidders are requested to consider this corrigendum as part of tender specification and quote accordingly.


AGM / SCT