

**BHARAT HEAVY ELECTRICALS LIMITED**

(A Government of India Undertaking)  
 Ramachandrapuram, Hyderabad, 502032, A.P., India  
 Phone 040-23184526, 23182322 FAX:040-23021910, 1954

**भारत भारी इलेक्ट्रिकल्स लिमिटेड**

(भारत सरकार की संपत्ति)  
 रामचन्द्रपुरम, हैदराबाद, 502032 और गढ़ना, भारत

RFQ NO :

**PURCHASE DEPARTMENT**SHEET:1  
OF :1HY17001 C  
REV. NO.0Phone 091-40-23184526  
091-40-23182322FAX : 091-40-23021910  
091-40-23021954

E Mail: tenderbox@bhelhyd.co.in

Eng/Collective Number :P&amp;AINI18045

Eng Date : 23.07.2014

No. Of Items : 1

DUE DATE OF QUOTATION : 13.08.2014

PURCHASE DEPARTMENT  
ENQUIRY  
क्रय विभाग  
क्रय (ई मेल : tenderbox@bhelhyd.co.in)**Office Copy**

Please submit your lowest quotation in sealed cover superscribed with Enquiry No./Collective No.(RFQ No ..... ) and date subject to our terms and conditions attached ,for the materials mentioned below. Your offer has to reach us onor before due date by 11.00 Hours (IST) and will be opened at 14.00 Hours.(IST).If our Enquiry No./Collective No.(RFQ No ..... ) and tender due date are not super scribed on the tender cover , your offer shall be summarily rejected. Whosoever desires to send offers on their own risk (complete in all respects) via e-mail have to send offers to the common e-mail address : tenderbox@bhelhyd.co.in . Incomplete offers and late offers will not be considered.

SL NO	Purchase Req.no/Item no	Material Code	Drq no - Ver , Rev & Spec - Ver , Rev	Description	Unit	Qty	Delivery Date	Schedule Qty
1	1200018045	CG2080918087	NA,	RO SYSTEM 500 LPH	EA	1.000	25.08.2014	1.000

**Special Remarks**

- 1) TWO PART BID SYSTEM MAY BE FOLLOWED.
- 2) GCC & ITB ARE ENCLOSED.
- 3) SPECIFICATION IS ENCLOSED.

	<b>TEST CERTIFICATE REQD: Y</b> <b>GUARANTTEE REQ : Y</b> <b>SAMPLE REQD : N</b> <b>BID TYPE : TWO PART</b>
	For and on-behalf of Bharat Heavy Electricals Limited. <b>SREENU K</b> Pdr. Officer/CMM

# PRICE BID

ENQUIRY NO.


ITEM DESCRIPTION :

Sl. No	Description	Price in Rs.
01.	Cost of main equipment	
02.	Cost of spares (item wise) for two years	
03.	Cost of E&C	
04.	O&M cost for six months	


Applicable Taxes :




<b>1.4.6</b>	<b>NaOH Dosing System</b>	
a	Qty : 1 No.	
b	Capacity : 5 LPH @ 2 Kg/Cm2.	
c	Dosing Tank Capacity : 50 L. (min)	
<b>1.4.7</b>	<b>UF Permeate Tank</b>	
a	Qty : 1 no.	
b	Capacity : 3000 L.	
c	MOC:HDPE (High Density Poly Ethylene)	
<b>1.5</b>	<b>RO Feed Pump</b>	
1.5.1	Qty : 1 no.	
1.5.2	Capacity : 1300 LPH.	
1.5.3	Max Discharge Pressure : 10.5 Kg/Cm2. (Bidder to ensure adequacy)	
1.5.4	MOC : SS	
1.5.5	Make: Kirloskar or CRI or equivalent.	
<b>1.6</b>	<b>Antiscalant Dosing System</b>	
<b>1.6.1</b>	<b>Dosing Pump</b>	
a	Qty : 01 No.	
b	Type : Electro Magnetic	
c	Capacity : 0-1.5 LPH.	
d	Max Discharge Pressure : 2.5 Kg/Cm2.	
e	Make: Kirloskar or CRI or equivalent.	
<b>1.6.2</b>	<b>Dosing Tank</b>	
a	Qty : 1 no.	
b	Capacity : 50 L.	
c	MOC : HDPE(High Density Poly Ethylene)	
<b>1.7</b>	<b>Micron Cartridge Filter(MCF)</b>	
1.7.1	Qty : 1 no	
1.7.2	Capacity : 1300LPH	
1.7.3	Micron Rating of Cartridge : 5 Micron	
1.7.4	Size of Cartridge : 20"	
1.7.5	MOC : Poly Propylene (PP)	
<b>1.8</b>	<b>High Pressure Pump</b>	
1.8.1	Qty : 1 no	
1.8.2	Capacity : 1300 LPH	
1.8.3	Max Discharge Pressure : 10.5 Kg/Cm2	
1.8.4	MOC: SS304	
1.8.5	Make: Kirloskar or CRI or equivalent.	
<b>1.9</b>	<b>Reverse Osmosis System</b>	
1.9.1	Qty : 1 no	
1.9.2	Permeate capacity : 500 LPH	
1.9.3	Membrane type : Spiral wound	
1.9.4	Membrane specification : TFC polyamide (Thin Film composit Polyamide)	
1.9.5	Size of Membrane : Dia 4" X 40" Long	
1.9.6	No. of Membranes : 3 nos.	
1.9.7	No. of Membrane Housing : 1 no.	
1.9.8	Skid Material : Mild Steel - Powder Coated	


  
 मनीश कुमार सिंह  
 Sr. Engineer  
 Common Workshop  
 BHEL, HYD-502 032


Pradeep


  
 राधिका सिंहा  
 RADHIKA SISTA  
 Sr. Manager (PE & SD)  
 BHEL, HYD-502 032


  
 मनीश कुमार  
 MANISH KUMAR  
 Dy. Manager / Common Workshop (08 Block)  
 BHEL, Hyderabad - 502 032

1.10	<b>pH Dosing System</b>	
1.10.1	<b>Dosing Pump</b>	
a	Qty : 1 no	
b	Type : Electromagnetic	
c	Capacity : 0 - 1.5 LPH	
d	Discharge Pressure : 2.5 Kg/ Cm <sup>2</sup>	
e	Make: Kirloskar or CRI or equivalent.	
1.10.2	<b>Dosing Tank</b>	
a	Qty : 1 no	
b	Capacity : 50 Lt	
c	MOC:HDPE(High Density Poly Ethylene)	
1.11	<b>Interconnecting Pipe Works (ICPW)</b>	
1.11.1	MOC : Unplasticized Poly Venyl Chloride (UPVC)	
1.11.2	Qty : 1 lot	
1.12	<b>Control Panel (UF-RO)</b>	
1.12.1	Qty : 1 no	
1.12.2	Type : Non- Compartmentlized	
1.12.3	Cabling ( As per Termination ) : 1 Lot	
1.13	<b>Instruments (Bllder to ensure adequate no of instruments are supplied to operate the system in auto mode)</b>	
1.13.1	Pressure Gauges : 1 lot, Bourden type	
1.13.2	Pressure Switches: 4 nos, High & Low	
i)	Type : S.S. Below type	
ii)	Enclosure: Die cast Aluminium	
1.13.3	Conductivity meters : 1 no.	
1.13.4	pH meter : 1no.	
1.13.5	Oxidation Reduction Potential meter (ORP) : 1 no.	
1.13.6	Rota meter : 6 nos.	
1.13.7	AutoFlush valve: 1 no.	
1.13.8	Level switch : 4 nos.	
1.13.8	Make and model of the instruments to be submitted.	
2	<b>Features</b>	
2.1	The Equipment to have an electrical panel with LCD Screen and Over load Panel	
2.2	Operation of the equipment shall be safe. Wherever required safety valves/ switches shall be provided.	
2.3	The equipment shall be easy to operate and maintain.	
2.4	The equipment shall be capable of working at room temperature. The room temperature at Hyderabad in summer will be around 45 °C and in winter around 10°C	
3	<b>Calibration</b>	
3.1	All gauges and electrical equipments shall be calibrated by the authorised certifying agency	
4	<b>Spares</b>	
4.1	Essential spares for two years shall be indicated and quoted with split price for each item	

  
 क.सिंह  
 Sr. E  
 की.ए.  
 क.सिंह  
 Kumar Singh  
 क.सिंह  
 Common Workshop  
 BHEL, HYD-502 032

  
 Pradeep

  
 राधिका सिंहा  
 RADHIKA SISTA  
 वी.ए.ए. प्रबंधक (पी.ई. & एस. डी.)  
 Sr. Manager (PE & SD)  
 BHEL, HYD-502 032

  
 मनीश कुमार  
 MANISH KUMAR  
 उप प्रबंधक / क.सिंह की.ए. (08 ब्लॉक)  
 Dy. Manager Common Work Shop (08 Block)  
 वी.ए.ए.ए.ए./BHEL,Hyderabad - 502 032


5	<b>Documentation:</b>	
5.1	The Vendor to give the three copies of the O&M Manual in English language	
5.2	The vendor shall give a list of customers to whom similar instruments are supplied, preferably Govt./ public Sector	
5.3	The vendor has to submit the General arrangement drawing of the RO Plant along with the offer.	
6	The suppliers shall also indicate the approximate annual maintenance charges after the guarantee period. He shall also indicate if any authorized servicing center in Hyderabad	
7	<b>Guarantee:</b> The instrument shall be guaranteed for its satisfactory performance for at least two years from the date of commissioning.	
8	<b>Installation:</b>	
8.1	The Supplier shall install and commission the equipment at BHEL and impart O&M training to the BHEL technical Personnel.	
8.2	The required piping for giving inlet and outlet connections to the respective holding tanks will be in the suppliers scope. All pipings and necessary items to be supplied by the vendor.	
8.3	<b>Prove Out:</b> The supplier after the installation has to run and maintain the plant for six months. Cost of O&M may be quoted separately. The supplier has to test the the quality of water.i.e. the output water of RO shall meet the requirement of IS:10500:1991 latest revision. The testing should be carried out by approved laboratory at Hyderabad. Testing charges will be in the supplier's scope.	
8.4	In case any special foundation is required for installing the machine, detailed foundation drawings to be submitted. The supplier should agree to supply 5 copies of machine layout and foundation drawings with one month of placement of L.O/Order	
8.5	The equipment shall fulfill safety regulation and guidelines. If any environmental protection is required, it should be built in the machine by the supplier.	
9	After the Installation, Performance of the equipment supplied by the L1 party will be observed for six months. If found satisfactory BHEL may place a repeat order for one more no. of the same equipment. The L1 vendor shall supply the same at the same rate, terms and conditions.	
10	<b>INPUT FOR RO</b>	
10.1	Input water for RO is from output water of ETP.	
10.2	The reject water line of RO shall be as per the scheme enclosed.	

मनीश कुमार सिंह  
Manish Kumar Singh  
वरिष्ठ अभियंता / सामान वर्कशॉप  
Sr. Engineer / Common Workshop  
बी.एच.ई.एल., हैदराबाद / BHEL, HYD-502 032

मनीश कुमार  
MANISH KUMAR  
उप प्रबंधक / सामान वर्क शॉप (08 ब्लॉक)  
Dy. Manager/Common Work Shop (08 Block)  
बी.एच.ई.एल., हैदराबाद - 502 032

च. प्रादेपा  
CH. PRADEEPA  
वरिष्ठ अभियंता / पी.ई. & एस. डी.  
Sr. Design Engineer / (PE & SD)  
बी.एच.ई.एल., हैदराबाद / BHEL, HYD-32


# RO SCHEME



**JOB SPECIFICATION**  
**OF**  
**RO SYSTEM**  
**FOR**  
**THE ZERO DISCHARGE PLANT**  
**(Ref. No. HY/CW/2014/STS/RO/036 Dated 17.05.2014)**



मनोज कुमार सिंह  
Manoj Kumar Singh  
वरि. अभियंता/कामन वर्कशॉप  
Sr. Engineer/Common Workshop  
वी एच ई प्ल, हैद/ BHEL, HYD-502 032



राधिका सिंहा  
RADHIKA SISTA  
वरिष्ठ प्रबंधक (पी ई व एस डी)  
Sr. Manager (PE & SD)  
वीएचईप्ल, हैद / BHEL, HYD-502 032



मनोज कुमार  
MANOJ KUMAR  
उप प्रबंधक (पी ई व एस डी) (08 ब्लॉक)  
Dy. Manager (PE & SD) (08 Block)  
वीएचईप्ल, हैद / BHEL, Hyderabad - 502 032

### INTENT OF SPECIFICATION

1.1 This specification is intended to cover the design, engineering, manufacture assembly, supply, erection and commissioning along with all accessories as specified hereinafter and as required for safe and trouble-free operation of the plant. This section sets out the scope of supply of the RO treatment plant, covered by this specification but without excluding other necessary components, which are not mentioned.

### PROCESS DESCRIPTION

- 1.1 The effluents generated from electroplating, phosphate and other related chemical treatments are chemically treated in ETP to remove/reduce the toxicity.
- 1.2 This chemically treated effluent is then passed to the proposed RO plant for further treatment.
- 1.3 The treated water i.e. RO permeate, pertaining to IS: 10500 standard, is collected in a tank.
- 1.4 The RO-reject is partially re-cycled in the system and partially sent for other uses such as gardening purposes.

### RO SCHEME


1.1 The scheme consists of the following equipment:


- a. Dual Media Filter
- b. Activated Carbon Filter
- c. Ultra Filtration unit
- d. Cartridge filter
- e. RO-Membrane
- f. Chemical Dosing system
- g. Associated piping.
- h. Associated Electricals



### SCOPE OF SUPPLY

This section sets out the scope of supply of the Water Treatment Plant, covered by this specification but without excluding other necessary components, which are not mentioned. All materials supplied under this contract shall be new and unused.

The quantities and rating of the equipment indicated in this specification is only for the guidance of the bidder. All material required to make the system complete but not specifically mentioned in this specification shall also be deemed to be included in the scope of bidder.

  
मनीश कुमार सिंह  
Manish Kumar Singh  
वरिष्ठ अभियंता/कामन वर्कशॉप  
Sr. Engineer/Common Workshop  
बी.एच.एल. हैद/ BHEL, HYD-502 032



  
राधिका सिंग  
RADHIKA SINGH  
वरिष्ठ प्रबंधक (पी ई एंड एस डी)  
Sr. Manager (PE & SD)  
बी.एच.एल. हैद/ BHEL, HYD-502 032  
  
मनीश कुमार  
MANISH KUMAR  
ज्य. प्रबंधक / ज्य. प्रबंधक (08 ब्लॉक)  
Dy. Manager/ Dy. Manager (08 Block)  
बी.एच.एल. हैद/ BHEL, HYD-502 032

### Treatment plant

- a. 1 X 100% Dual Media filter with head and capacity as per requirement.
- b. 1 X 100% Activated Carbon Filter of net continuous capacity as required by the system with required filter scour blower system.
- c. Ultra-filtration unit of max capacity of 1500 lph and required head.
- d. Cartridge Filter system of capacity sufficient to meet the continuous requirement of downstream RO plant.
- e. Required dosing systems complete with necessary dosing tanks and dosing pumps, upstream of RO system, namely (i) Anti-scalant Dosing System, (ii) Acid dosing system
- f. 1 x 100% RO Booster Pump system, of capacity and head as per requirement.
- g. RO membrane required to produce permeate of 500 LPH.
- h. Associated piping and electrical.

### MECHANICAL

#### I. Dual Media Filter


Filtration plant shall be used to reduce the silt density index (SDI) and turbidity of the effluent to provide safe operating conditions for the RO Plant.


The dual media filter shall be capable of processing all required feed water to the RO streams. The backwashing of the dual media filter shall be accomplished with treated water.


The filtering medium shall be graded sand and anthracite. The flow velocity for filtration shall not exceed 18m/hr to meet the specified capacity. The filter shall be of vertical, cylindrical type. It shall have shells and dished ends both constructed of FRP. The filters shall be designed to contain filter media, distribution system and under drain system. The filters shall be supplied with frontal pipe work with valves and fittings, instrument and accessories.


#### II. Activated Carbon Filters

The water from the dual media filters shall be passed through the ACF. The filtering medium shall be activated carbon grade in granular form and good quality. The flow velocity for filtration shall not exceed 15M/hr to meet the specified capacity. The vessels shall be vertical shell type with dished ends. The material of construction shall be FRP.

  
मनोज कुमार सिंह  
Manoj Kumar Singh  
वरिष्ठ अभियंता/कॉमन वर्कशॉप  
Sr. Engineer/Common Workshop  
बी.एच.ई.एल., हैद/ BHEL, HYD-502 032



  
राधिका सिंहा  
RADHIKA SISTA  
वरिष्ठ प्रबंधक (पी.ई.ए.एस.डी.)  
Sr. Manager (PE & SD)  
बी.एच.ई.एल., हैद/ BHEL, HYD-502 032

  
मनीश कुमार  
MANISH KUMAR  
वरिष्ठ प्रबंधक / कॉमन वर्कशॉप (08 ब्लॉक)  
Sr. Manager/Common Work Shop (08 Block)

### III Ultrafiltration Unit

The water from the filtration plant shall be passed to the Ultrafiltration unit for achieving a SDI of < 3 and make the water suitable for membrane treatment. One no. 100% UF of hollow fiber housed in PP construction shall be of max. 1500 LPH capacity. The UF skid shall also be provided with backwash pump of suitable capacity.

### IV. RO Membrane unit

The effluent shall be passed through the cartridge filter prior to the RO unit. The cartridge filter shall be of PP construction with a rating of 5 micron. The water from the filter outlet will be led to the membrane unit. One skid of 100% capacity shall be provided to produce permeate of 500 LPH. The Reverse osmosis modules shall be of spiral wound or hollow fiber type and membranes of composite polyamide acetate material. Only one type of membrane shall be used for the RO modules. The membrane housing shall be of FRP material

### V. Chemical Dosing

The RO feed shall be chemically treated with suitable chemicals for anti-scalant and pH correction. Suitable capacity of dosing tanks and pumps to be provided. The capacity of the dosing tanks shall be min. 50 liters and of HDPE construction. The dosing pumps shall be controlled volume metering pumps of material suitable for the chemical.


### VI. Interconnecting Piping


One complete set of interconnecting piping from the effluent feed to the permeate storage tank and reject piping shall be in the scope of bidder. This shall cover all interconnection between equipment and pumps along with the necessary fittings and valves. The pipes shall be of UPVC material. The system shall be provided with required valves to necessitate feasible operation. Valves shall be designed, manufactured, tested and marked as per relevant Indian Standards. Bidder shall indicate the type of valves considered for the services. Valves shall be of pressure rating to suit the system requirements at the points of installation. Valves shall be suitable for frequent operation as well as for operation after periods of prolonged idleness in either open or closed positions. The required piping for giving inlet and outlet connections to the respective holding tanks will be in the Bidder's scope.


### Electrical and Instrumentation

The electrical installation shall meet the requirements of Indian Electricity Rules. The scope of supply shall include motors for the pumps and other drives, all power, signal and control cables required for the system and earthing. The UF-RO system shall be provided with an electrical panel with LCD Screen and over load Panel. The power supply upto the panel shall be provided by the customer and the subsequent cabling upto individual equipment shall be by the Bidder. All the power and control cables shall be as per the approved make only. The following listed instruments shall be provided as minimum. All gauges and electrical equipment shall be calibrated by the authorized certifying agency.

- Pressure Gauge – At the outlet of raw water pump and each filter.
- Flow indicator – Online type to be provided on the permeate line and reject line.
- Pressure switches –

  
मनोज कुमार सिंह  
Manoj Kumar Singh  
ज्येष्ठ अभियंता/कामन वर्कशॉप  
Sr. Engineer/Common Workshop  
बी एच ई एल, हैद/भएल, HYD-502 032



  
राधिका शिवा  
RADHIKA SISTA  
वरिष्ठ प्रबंधक (पी ई व एस डी)  
Sr. Manager (PE & SD)  
मुरगन क्लब (08 ब्लॉक)  
Muragan Common Work Shop (08 Block)  
बी एच ई एल/भएल Hyderabad - 502 032

- d. Level switch – In the chemical dosing tank.
- e. Auto Flush valve – In the RO stream.
- f. ORP and pH meter – In the RO feed line.
- g. Conductivity meter – At RO outlet.

**Civil**

The civil works i.e. construction/execution is in the scope of customer but the civil design for the entire system is in the scope of work of the Bidder.

**Erection & Commissioning**


Bidder scope of work includes erection of the entire system. The Bidder shall install and commission the equipment at BHEL and demonstrate its features and working principle to the BHEL technical Personnel.


**INPUTS**


The following documents are enclosed:

- a) Flow diagram / Scheme – Annex-1.
- b) Waste water analysis (RO system feed) – Annex-2
- c) Technical Data Sheet – Annex-3

Duly filled Technical data sheet shall be submitted along with the offer.


  
मनीश कुमार सिंह  
Manoj Kumar Singh  
ज्येष्ठ अभियंता/कामन वर्कशॉप  
Sr. Engineer/Common Workshop  
वा. एच. ई. एल. हेड/BHEL, HYD-502 032



  
राधिका सिंहा  
RADHIKA SISTA  
ज्येष्ठ परियोजना (पी ई व एस डी)  
Sr. Manager (P&SD)

मनीश कुमार  
MANISH KUMAR  
ज्येष्ठ परियोजना / कामन वर्कशॉप (HR ब्लॉक)

# RO SCHEME




श्री राजेश कुमार सिंह  
 Manoj Kumar Singh  
 श्री. अभियंता/आयुक्त कार्यालय  
 Sr. Engineer/Commission WorkShop  
 श्री. एच. 5, एच. 6/भेल, HYD. 502 032

श्री. एच. 5, श्री. एच. 6/भेल, HYD. 502 032  
 M A NISHA KUMAR  
 Sr. Engineer / Sr. SGT (08 एच. 5)  
 Sr. Engineer/Commission Work Shop (08 एच. 6)

*Pradeepa*

श्री. राजेश कुमार सिंह  
 RADHIKA SISTA  
 श्री. एच. 5, श्री. एच. 6/भेल, HYD. 502 032  
 Sr. Manager (PE & SD)



S. NO.	DESCRIPTION	S. NO.	DESCRIPTION

<b>CLIENT:</b> M/S RAJURGI GARDEN NEW DELHI		<b>BIOLOGIC WATER SOLUTIONS PVT. LTD.</b> Plot No. 4, Sector 14 NEW DELHI - 110044	
<b>DIMENSION:</b> NOT IN SCALE		<b>CHECKED BY:</b>	
<b>DRAWN BY:</b>		<b>REV:</b>	
<b>CAD FILE LOC:</b>			



EPTRI  
CPCB & DSIR  
Recognized Laboratory

Environment Protection Training and Research Institute (EPTRI)  
#91/4, Gachibowli, Hyderabad - 500 032, INDIA.  
Ph.: +91-40-23180116; 23180119, Fax : +91-40-23180135;  
email : jssvas@eptri.com ; enquiry@eptri.com

## ANALYSIS REPORT

Encl. report no.12/WWC-111

### TEST RESULT

Page 2 of 2

S.No	Test Parameter(s)	Unit	IS: 10500 Desirable Limits	IS: 10500 Permissi- ble Limits	Test Method	Result
						WW -1
1.	Colour	Pt. co	5	25	2120. B	15
2.	Odour	TON	Unobjectionable	--	2150. B	1
3.	Taste#	--	--	--	--	NP
4.	Total Hardness as CaCO <sub>3</sub>	mg/L	300		2340.C	229
5.	Residual free Chlorine				4500-Cl. B	BDL
6.	Calcium as Ca	mg/L		200	3500-Ca.B	17
7.	Magnesium as Mg	mg/L	50	100	3500-Mg.B	46
8.	Nitrates as NO <sub>3</sub> <sup>-</sup>	mg/L	45	100	PDA	1.38
9.	Anionic Detergents	mg/L	0.2	1.0	IS:13428:2005, Annex K	<0.2
10.	Mineral Oil*	mg/L	0.01	0.03	IS:3025 (part 39)	Absent
11.	Total Alkalinity as CaCO <sub>3</sub>	mg/L	200	600	2320. B	56
12.	Polyaromatic Hydrocarbons (PAH's): Acenaphthene, Acenaphthylene, Anthracene, B(a)A, B(a)P, B(b)F, B(k)F, Pyrene, Dibenz(a,h) anthracene, Fluoranthene, Fluorene, Indeno(1,2,3-cd) Pyrene, Naphthalene, Phenanthrene, Pyrene, 1. Methyl Naphthalene, 2. Methyl Naphthalene	µg/L	--	--	6440.C	ND

Opinion and Interpretation: Not Applicable

# Not performed

\* Out sourcing

TON - Threshold Odour Number

BDL - Below Detection Limit

Detection Limit - Residual free chlorine - 1 mg/L;

ND - Not detected; Detection Limit - PAHs - 1 ppm.

Note: The test result relates to the only items tested.

Authorized Signatory  
Dr. J. Sessa Srinivas  
Sr. Scientist - Laboratory



EPTRI  
CPCB & DSIR  
Recognized Laboratory

Environment Protection Training and Research Institute (EPTRI)  
#91/4, Gachibowli, Hyderabad - 500 032, INDIA.  
Ph.: +91-40-23180116; 23180119, Fax : +91-40-23180135;  
email : jssvas@eptri.com ; enquiry@eptri.com



NABL ACCREDITED  
No: T-0612 & T-1481  
As per ISO/IEC 17025:2005

## ANALYSIS REPORT


Page 1 of 1

Registration Number : 12/WWC-111 Issue date : 20.11.2012  
 Sample received : 31.10.2012 Customer ref : HY/CW/2012/EFF.TEST/  
 Date of Commencement : 01.11.2012 101  
 Date of Completion : 02.11.2012 and date : 29.10.2012  
 Name & Address of the customer : Sri S.K. Bandyopadhyay,  
 Sr. Dy. General Manager,  
 Common Workshop,  
 08 Block,  
 Bharat Heavy Electricals Limited,  
 Ramachandrapuram,  
 Hyderabad.  
 Sample Particulars : Sewage  
 Qty-received : 1 L  
 Type of Sampling : Grab  
 Sample condition : Suitable for analysis. Sample was submitted in glass bottle.  
 Sampling Procedure : Sample Collected and submitted by the customer  
 Sample Code : Sample Location  
 WW-1 : Acid/ Alkali Effluent  
 Date of Sampling : 31.10.2012  
 Sampled by : Customer  
 Industry representative : Sri S.K. Bandyopadhyay, Sr. Dy. General Manager.  
 Sub-Contracting : N.A.  
 Deviation from Standard methods : N.A.  
 Sample Tested : As per the Standard Methods for the Examination of water & wastewater by APHA, WEF, & AWWA, 21<sup>st</sup> Ed  
 Remarks : N.A.

### TEST RESULT

S. No	Test Parameter	IS: 10500 Detection Limit	Test Method	Result WW-1
1	<b>Pesticides:</b> (α-BHC, β-BHC, γ-BHC, δ-BHC, Heptachlor, Heptachlor epoxide, Endosulfan, p,p'-DDE, p,p'-DDD, Endrin, p,p'-DDT, Aldrin, Dieldrin, Endrinakdehyde, Endosulfan sulfate)	100	APHA-8830-D	ND

Opinion and Interpretation: Not Applicable.  
 ND - Not detected. Detection Limit - Pesticides - 0.1 ppm  
 NOTE : The test result relates to the only item tested.

  
 Authorized Signatory  
 C. Satish  
 Project Faculty - Laboratory



EPTRI  
CPCB & DSIR  
Recognized Laboratory

Environment Protection Training and Research Institute (EPTRI)  
#91/4, Gachibowli, Hyderabad - 500 032, INDIA.  
Ph.: +91-40-23180116; 23180119, Fax : +91-40-23180135;  
email : jssvas@eptri.com ; enquiry@eptri.com



NABL ACCREDITED  
No: T-0612 & T-1451  
As per ISO/IEC 17025:2005

## ANALYSIS REPORT

Page 1 of 2

Registration Number : 12/WWC-111 Issue date : 20.11.2012  
 Sample received : 31.10.2012 Customer ref : HY/CW/2012/EFF.TEST/  
 Date of Commencement : 31.10.2012 101  
 Date of Completion : 20.11.2012 and date : 29.10.2012  
 Name & Address of the customer : Sri S.K. Bandyopadhyay,  
 Sr. Dy. General Manager  
 Common Work  
 28 Block,  
 Rat H... Limited,  
 Hyderabad - 502032.

Sample Particulars : Waste water  
 Qty-received : ~ 5 Ltrs + 5 Ltrs  
 Type of Sampling : Grab Sample  
 Sample condition : Suitable for analysis. Samples were submitted in plastic containers.  
 Sampling Procedure : Samples Collected and submitted by the customer  
 Sample Code : Sample Location  
 WW-1 : Acid/Alkali Effluent  
 Date of Sampling : 31.10.2012  
 Sampled by : Customer  
 Industry representative : Sri S.K. Bandyopadhyay, Sr. Dy. General Manager.

Sub-Contracting : N.A.  
 Deviation from Standard methods : N.A.  
 Sample Tested : As per the Standard Method for the Examination of water & water bodies, AWWA, 21<sup>st</sup> Ed  
 Remarks : N.A.

  
 Authorized Signatory  
 Dr. J. Sesha Srinivas  
 Sr. Scientist - Laboratory



EPTRI  
CPCB & DSIR  
Recognized Laboratory

Environment Protection Training and Research Institute (EPTRI)  
#91/4, Gachibowli, Hyderabad - 500 032, INDIA.  
Ph.: +91-40-23180116; 23180119, Fax : +91-40-23180135;  
email : jssvas@eptri.com ; enquiry@eptri.com



NABL ACCREDITED  
No: T-0912 & T-1481  
As per ISO/IEC 17025:2005

## ANALYSIS REPORT

Encl. report no.12/WWC-111

TEST RESULT

Page 2 of 2


S.No	Test Parameter(s)	Unit	IS: 10500 Desirable Limits	IS: 10500 Permissi- ble Limits	Test Method	Result
						WW -1
1.	pH	--	6.5 to 8.5	No relaxation	4500-H'B	5.4
	Temperature	°C				25.2
2.	Turbidity	NTU	5		2130. B	6.7
3.	Chlorides as Cl <sup>-</sup>	mg/L	250		4500-Cl.B	212
4.	Fluoride as F <sup>-</sup>	mg/L	1.5		4500-F.C	2.92
5.	Total Dissolved Solids at 180°C	mg/L		2000	2540. C	1020
6.	Sulphates as SO <sub>4</sub>	mg/L		400	4500-SO <sub>4</sub> <sup>2-</sup> .E	391
7.	Phenolic Compounds as C <sub>6</sub> H <sub>5</sub> OH	mg/L	0.001	0.002	5530-D	0.43
8.	Mercury as Hg	µg/L	0.001	No relaxation	3500-Hg.B	BDL
9.	Cyanide as CN <sup>-</sup>	mg/L	0.05	No relaxation	4500-CN.F	BDL
10.	Hexavalent Chromium as Cr <sup>+6</sup>	mg/L	0.05	No relaxation	3500-Cr <sup>+6</sup> .B	2.71
11.	Copper as Cu	mg/L	0.05	1.5	3120-B	3.62
12.	Manganese as Mn	mg/L	0.1	0.3	3120-B	8.24
13.	Cadmium as Cd	mg/L	0.01	No relaxation	3120-B	0.08
14.	Selenium as Se	mg/L	0.01	No relaxation	3120-B	7.38
15.	Arsenic as As	mg/L	0.05	No relaxation	3120-B	BDL
16.	Lead as Pb	mg/L	0.05	No relaxation	3120-B	BDL
17.	Zinc as Zn	mg/L	5	15	3120-B	1.4
18.	Aluminum as Al	mg/L	0.03	0.2	3120-B	BDL
19.	Boron as B	mg/L	1		3120-B	0.21
20.	Iron as Fe	mg/L	0.3		3120-B	0.30

Opinion and Interpretation: Not Applicable

BDL - Below Detection Limit

Maximum Detection Limit - Hg - 20 µg/L, CN - 0.05 mg/L, As - 0.04 mg/L, Pb - 0.04 mg/L, Ni - 0.04 mg/L

Note: The test result relates to the only items tested.

  
Authorized Signatory  
Dr. J. Sesha Srinivas  
Sr. Scientist - Laboratory

