

# Bharat Heavy Electricals Limited

## CIVIL ENGINEERING DEPARTMENT (FACTORY)

|   |  |
|---|--|
| <b>TITLE</b><br>CORRIGENDUM for NIT_19122 | Phone: +91 431 2574658/2574650/2574543<br>Fax : +91 431 252 0333<br>Email : devapurush@bheltry.co.in |
|---|--|

|  |                                    |   |
|--|------------------------------------|---|
| <b>Reference Number:</b><br>Enquiry CF:TS :019/14-15 | <b>Enquiry Date:</b><br>25.08.2014 | <b>Due date for submission of quotation:</b> 17.09.14 |
|--|------------------------------------|---|

You are requested to quote the Enquiry number date and due date in all your correspondences. This is only a request for quotation and not an order

### CORRIGENDUM 3

| S.No | Gist of Queries raised by Bidders   | Clarification by BHEL  |
|------|---|--|
| 1.   | Please confirm Z purlins & material for sag rods are also part of free supply material by BHEL.   | Yes, the Z purlins & material for sag rods are also part of free supply material by BHEL.  |
| 2.   | If fasteners are to be supplied by us please let us know the percentage consumption of fasteners vis-a- vis to total structure.   | The consumption of fasteners will vary case to case. For our tender it can be taken as 0.8 % to 1% approximately.  |
| 3.   | Service tax on Part A is to be paid on the amount including cost of free issue material by BHEL. Please confirm the rate of free issue material to be incorporated in the amount for service tax. | The market rate may be taken for cost of free issue materials while accounting Service tax.  |
| 4.   | There is no item for Grating /Chequered plate for steps in stair cases.   | The Chequered plate for steps in stair cases will be supplied by BHEL and accounted in fabricated quantity.  |
| 5.   | As per Drawing No.OTP-CEG-01602 the size of Turbo Ventilator is 900mm where as in SOR item the size is 600 mm. Please clarify.  | The size of Turbo ventilator is 600 mm only.   |
| 6.   | As per drawing we have to provide valley gutter with FRP coating of 3mm there is no item for supply & fixing of gutter sheet.   | Gutter is made up of 6 mm plate (supplied by BHEL), hence it will be accounted in fabricated quantity.<br><br>FRP lining will be operated separately, if required. |

|     |   |   |
|-----|---|---|
| 7.  | As per item No.3 of Part – A, we have to supply anchorage system but no item related to erection of same is given in SOR.   | Only supply of Foundation Bolt, Nut, anchorage system is covered under this tender, the fixing shall be done by other Civil contractors. However the prior approval is required before purchase of bolts, nuts, etc.  |
| 8.  | Please provide list of approved laboratory to carry out the Ultrasonic test if any  | Ultrasonic test shall be carried out through any NABL accredited laboratories.  |
| 9.  | Please suggest a vendor for Aluminium zinc alloy coating high tensile steel rib profile sheets.   | It is requested to analyse the market and get information on your own, however prior approval is required before purchase.  |
| 10. | In general the rolled sections are heavier than IS code. Please clarify the procedure for reconciliation of material if sections are found heavier than IS section weight.  | The weight of the rolled sections shall be calculated as per IS 808 only. Reconciliation of material shall be calculated as per IS sections weight only.  |
| 11. | Please refer to SCC Page No.69 scope of contractor is to be elaborated against in para No.6. Since there is no such item for grouting of bolts is available in SOR.   | The grouting of bolts is not covered in this tender and shall be done by other Civil contractor.  |
| 12. | Please refer SCC Page No.69 para No.7 no payment is to be made for providing splicing . Please clarify the reconciliation of materials used for splicing.   | Splice plate will be taken into account in fabricated quantity.   |
| 13. | Format for Plant & Equipment as per Annexure – I is for civil job only . Please suggest the revised format.   | You may furnish the required Plant & Equipments to complete the work within contract period under the last heading of “Other plant & equipments required for fabrication & erection of structural steel work” of Annexure 1 of Qualification Bid (page 48).   |
| 14. | Clarify the payment terms for both the Part A and Part B,<br><br>Tender page 17, point 123 - 100% payment will be only for the quantities actually executed for a finished item of work<br><br>Tender GCC page 112, point 52 - Advance on Account | As per clause 123 of preamble page 17 , 100% - Payment will be made only for the quantities actually executed for a finished item of work measured as per IS 1200 and accepted finally. No advance payment will be made. No part payment will be made.<br>This clause overrides the mentioned GCC clause.<br><br>Other clause 13 of preamble in page no 5 & clause 43 of preamble in page no 10 may also be referred. |

|   |  |  |
|---|--|--|
| 15.   | Clarify the gutter and down take pipe item is not in mentioned in the BOQ price Bid  | Gutter is made up of 6 mm plate (supplied by BHEL), hence it will be accounted in fabricated quantity.<br><br>Down taken pipe shall be operated separately as per requirement.   |
| 16.   | Hardware is mentioned in the drawings and not mentioned in the BOQ of price bid  | Items shall be quoted according to the BOQ of price bid. If any deviation found, the GCC clause 50 Pge 111 shall be followed.  |
| 17.   | There is no civil work and relevant civil construction equipment in our scope, as mentioned in page 14, point 89, point 91, 101, 102         | The applicable machineries required to complete the work within contract period shall be made available as mentioned in the referred clause and any additional machineries required for completion of work may be given under the heading of "Other plant & equipments required for fabrication & erection of structural steel work" of Annexure 1 of Qualification Bid pg 48. |
| <b>All other terms and conditions as published in the NIT_19122 remain unaltered</b>  |  |  |
| BHEL commercial terms & conditions with Price Bid formats and all annexure can be downloaded from BHEL web site <a href="http://www.bhel.com">http://www.bhel.com</a> or from the Government tender website <a href="http://tenders.gov.in">http://tenders.gov.in</a> (public sector units) Bharat Heavy Electricals Limited) under enquiry reference "TS No. CF:TS:019/14-15 " |  |  |
| Tenders should reach us before 10:00 hours on the due dateTechnical bid will be opened at 10.15 hours on the due dateTenders would be opened in presence of the tenderers who have submitted their offers and who may like to be present.   | Yours faithfully,<br><b>ForBharat Heavy Electricals Limited</b><br><br>D.Purushothaman<br><b>DY GEN MANAGER / CIVIL / PLANNING (F&amp;T)</b> |  |