



An ISO 9001  
Company

# Bharat Heavy Electricals Limited

(High Pressure Boiler Plant)

Tiruchirappalli – 620014, TAMIL NADU, INDIA

CAPITAL EQUIPMENT / MATERIALS MANAGEMENT

<b>ENQUIRY</b>	Phone: +91 431 257 79 38
<b>NOTICE INVITING TENDER</b>	Fax : +91 431 252 07 19
	Email : <a href="mailto:tvenkat@bheltry.co.in">tvenkat@bheltry.co.in</a>
	Web : <a href="http://www.bhel.com">www.bhel.com</a>

<b>TWO PART BID</b>	<b>Enquiry Number:</b>	<b>Enquiry Date:</b>	<b>Due date for submission of quotation:</b>
Tender to be submitted in two Parts	<b>2631300092</b>	<b>05.08.2013</b>	<b>10.09.2013</b>

You are requested to quote the Enquiry number date and due date in all your correspondence. This is only a request for quotation and not an order.

**Please note that under any circumstances both delayed offer and late offers will not be considered. Hence vendors are requested to ensure that the offer is reaching physically our office before 14.00 hrs on the Date of tender opening.**

Item	Description	Quantity
10	<b>Supply, Erection and Commissioning of 3 Ton Electric Bogie Hearth Heating Furnace</b> as per the technical specification & commercial conditions applicable (to be downloaded from web site <a href="http://www.bhel.com">www.bhel.com</a> or <a href="http://tenders.gov.in">http://tenders.gov.in</a> )	<b>1 No.</b>

**Important points to be taken care during submission of offer**

1. Checklist No. TRY/ IND/ 07 to be filled and enclosed along with the offer failing which, the offer will not be considered for evaluation.
2. All updates, amendments, corrigenda, etc., (if any), for each tender will be posted only on the above websites from time to time, as and when required, until each tender is opened. There will be no publication of such updates, amendments, corrigenda, etc., through newspapers or any other media.
3. Delivery required: Four months from the date of Purchase Order.
4. EMD for this tender will be ` 40,000.00

**BHEL's General guidelines / instructions (refer MM/CE/GENL/001-EMD) including bank guarantee formats and list of consortium banks, commercial terms check-list can be downloaded from BHEL web site <http://www.bhel.com> or from the Government tender website <http://tenders.gov.in> (public sector units > Bharat Heavy Electricals Limited page) under Enquiry reference "2631300092".**

Tenders should reach us before 14:00 hours on the due date Tenders will be opened at 14:30 hours on the due date Tenders would be opened in presence of the tenderers who have submitted their offers and who may like to be present	Yours faithfully, <b>For BHARAT HEAVY ELECTRICALS LIMITED</b>  Sr.Manager / Capital Equipment / MM
--	---

SCOPE:	SUPPLY, ERECTION & COMMISSIONING OF 3T ELECTRIC BOGIE HEARTH FURNACE				
SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
<b>1</b>	<b>PURPOSE &amp; BASIC FEATURES</b>				
1.1	<b>Purpose:</b> Electrically heated single ended Bogie Hearth Furnace having usable dimension of 2500(L) X 2500 (W)X 2500 (H)mm suitable for handling gross charge load of 3000 kg and 800°C operating temperature is required for stress relieving / annealing / tempering etc. of ferrous components of various grades and sizes as per the preset (adjustable) time-temperature programme.	Vendor to note & accept			
	<b>BASIC FEATURES:</b> The furnace design is to be in accordance with up-to date standards and special care is to be taken to ensure ease of operation and maintenance, accuracy of heating, safety etc. The furnace is basically of a fabricated mild steel chamber and mild steel bogie. Both the chamber and bogie are suitably insulated with conventional refractory bricks.	Vendor to note & accept			
<b>2</b>	<b>SPECIFICATIONS:</b>				
<b>2.1</b>	<b>TECHNICAL DATA</b>				
2.1.1	<b>Electrically heated single ended Bogie hearth type furnace</b>	Vendor to offer			
<b>2.2</b>	<b>. GENERAL PARAMETERS</b>				
2.2.1	Batch capacity (Gross Load)	3000kg.			
2.2.2	Inside chamber dimensions				
2.2.2.1	Length	2500 mm			
2.2.2.2	Width	2500 mm			
2.2.2.3	Height	2500 mm			
2.2.3	Over all dimensions (Indicative)				
2.2.3.1	Length (bogie withdrawn)	Vendor to specify.			
2.2.3.2	Width	Vendor to specify			
2.2.3.3	Height	Vendor to specify			
2.2.3.4	Door opening height	1500 mm			
2.2.3.5	Working height of the Bogie Top : 900 mm (approx.)	Vendor to specify			
2.2.4	Heating rate : 50 to 200° C./hr. in full load.	Vendor to specify			
2.2.5	Cooling Rate: max. 50 ° C / hr	Vendor to specify			
2.2.6	Maximum furnace Temperature 1100 ° C	Vendor to specify			

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
2.2.6.1	Temperature Uniformity at any location.	± 5° C of set value			
	Type of temperature control system	Thyristor control with Auto/ manual Function.			
2.2.7	Type of Temperature controller :PID controller with Auto / manual function and with Thyristor controls	Vendor to specify			
2.2.7.1	Make of Thyristor Controller : Siemens / Eurotherm	Vendor to specify			
2.2.7.2	Model of Thyristor controller	Vendor to specify			
2.2.8	Power rating, approx. 120KW	Vendor to specify			
2.2.9	Furnace outer wall temperature : ≤ 40 ° C above ambient temperature at maximum furnace temperature.	Vendor to confirm			
<b>2.3</b>	<b>MECHANICALS</b>				
2.3.1	Casing plate material & thickness : 5 mm (minimum)	Vendor to specify			
2.3.2	Bogie top plate material & thickness :10 mm (minimum)	Vendor to specify			
2.3.3	Rail size : lbs/yard.	Vendor to confirm			
2.3.4	Bogie Details	Vendor to specify			
2.3.4.1	Brick retainer casting : HRCI with 1.4% Cr.	Vendor to specify			
2.3.4.2	Sealing arrangement :	Vendor to specify			
2.3.4.3	Door details Type of door : Rise & fall, counter balanced Sealing arrangement: By Motorized pulley.	Vendor to confirm			
2.3.4.4	Drive type: By electric motor. Lifting speed : 4 meters/min (approx.) Motor capacity (HP & RPM)	Vendor to specify			
2.3.4.5	Drive type : Electric through rack & pinion.Speed of bogie movement : 5 meters /min. (approx.) Motor capacity (HP & RPM)	Vendor to specify			
2.3.5	Insulation details for Walls, roof, door and Bogie ( for example: 50 mm.128kg/m2 blanket of RTZ grade)	Vendor to specify			
2.3.5.1	Walls	Vendor to specify			
2.3.5.2	Roof	Vendor to specify			
2.3.5.3	Door	Vendor to specify			
2.3.5.4	Bogie	Vendor to specify			
<b>3</b>	<b>INSTRUMENTATION AND CONTROL SYSTEM:</b>				

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
3.1	Instrumentation panel shall be designed for 230 V AC including earthing to all instruments. The Thyristor controller shall be separated from instrument panel. One power socket with switch to be provided inside the panel in addition to that plug point to UPS. The Pre wired Control panel will be located and wired with necessary external wirings adjacent to the furnace are vendor's scope.	Vendor to confirm			
3.2	Furnace temperature control system should have master slave control system along with Auto tuning function to perform accurate control.	Vendor to confirm			
3.3	Furnace temperature control: The PID controller with at least 16 segment/ program and 4 to 20 m A output signal as input to thyristor control system and one alarm output. Any local short interruption to the heating cycle during the operation ,after resuming the power it will automatically start from process temperature and its corresponding segment as per program . Preferred makes for Temperature controller: Eurotherm, Chino	Vendor to confirm			
3.4	Furnace excess temperature control: For excess temperature control, it should be possible to set the limit value. In case of overshoot in the temperature, the control system should have the control	Vendor to confirm			
3.5	thermocouples: 4 Nos. of Duplex thermocouples to be provided. One thermocouple to the temperature controller, second to the excess temperature controller, third to the recorder and fourth as a spare. The thermocouple should be of Cr/Al and thermocouple sheath should be of inconel with 1 Mtr adjustable flange. Asbestos compensating cables to be provided. Preferred makes for the compensating cables: Tempense, Toshniwal.	Vendor to confirm			

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
3.6	Material thermocouples: K-type compensating cables of the temperature recorder should be wired from the control panel to 3 location on either side of the furnace walls for Material temperature measurement. Holes for thermocouples to be provided in between the heating elements with protection sheath at suitable locations approved by BHEL. Supply of suitable length of 6 mm dia Mineral insulated Thermocouples and compensating cables of make Tempense / Toshniwal is under vendor's scope.	Vendor to confirm			
3.7	Control elements: Suitable rated Thyristor control elements and all its accessories to be provided with Auto manual function facility .For manual function of thyristor control, separate 4 to 20 mA source to be provided.	Vendor to confirm			
3.8	Temperature recorder: Minimum 6 point microprocessor based digital strip chart recorder with 180mm along with 50 Nos. of chart paper packs to be provided for Temperature Recording. UPS of suitable rating to be provided to record the temperature for minimum 30 minutes in case of power failure. Chino laxsons / Honeywell make Recorder is preferred.	Vendor to confirm			
3.9	Instrumentation panel drawing approval : Vendor should submit the instrument panel drawing for approval before starting the panel wiring/ manufacturing.	Vendor to confirm			
3.10	Calibration Certificate shall be provided for controllers, recorder, thermocouple, and Test Certificate shall be provided for compensating cable.	Vendor to confirm			
3.11	Three sets of Hard and soft copy of operation, instruction and troubleshooting manual of all the instruments (controllers and recorder) and as built instrumentation panel drawing shall be provided to instrumentation by the vendor.	Vendor to confirm			
4	<b>ELECTRICALS</b>				
4.1	The complete electricals will be designed for 415 V 10%; 3 phase , 3 wire 50 Hz A.C.	Vendor to confirm			
4.2	<b>SCR Controller</b> : Zero fired thyristor controller with phase angle control to control heater power infinitely	Vendor to specify			

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
4.3	<b>Ammeter:</b> 2 (two) Nos minimum. With selector switch for measuring line current. Make: AEPL /equivalent make.	Vendor to specify			
4.4	<b>Energy Meter:</b> 1 (one) Energy meter to monitor power consumption.	Vendor to specify			
4.5	<b>Voltmeter</b> : 1 (one) no. with selector switch. Make AEPL /equivalent make	Vendor to specify			
4.6	<b>Motors for bogie drive: TEFC</b> , squirrel cage induction motor, SI duty, class 'F' insulation with single phase preventer.	Vendor to specify HP and			
		RPM of motor			
4.7	<b>Electrical panel:</b>	Vendor to confirm			
	One no. Mild steel fabrication separate electrical panel will house SCR controllers, Ammeter, Voltmeter, switches, inducting lamps, push buttons etc.				
4.8	<b>Cabling:</b> To provide all the power and control cabling except as stated under clause 7.3.	Vendor to confirm			
4.9	<b>Earthing :</b>	Vendor to confirm			
	Earthing of equipment will be done with GI/MS Flat/Wire and will be connected to existing earthing system.				
5	<b>SAFETY INTERLOCKS :</b>				
5.1	Heating element cannot be switched ON unless the bogie is fully inside the furnace and door is closed.	Vendor to confirm			
5.2	Bogie cannot be moved unless the door is open at least 500mm.	Vendor to confirm			
5.3	Door cannot be lifted unless heating element is OFF.	Vendor to confirm			
5.4	Door can be operated only when the bogie is fully inside	Vendor to confirm			
6	All motors will be provided with thermal overload relays along with single phase preventer	Vendor to confirm			
6.1	The furnace temperature exceeds the set value of furnace temperature controller, it should give alarm and lamp indication along with alarm accepts reset function.	Vendor to confirm			
7	<b>SERVICES PROVIDED BY BHEL</b>				
7.1	Input Power Supply: 415 volt $\pm$ 10 %; 50 Hz, 3 phase, 3 wire A.C.supply.	Vendor to accept & offer			
7.2	Compressed air at a pressure of 3 - 5 kg./cm2 gauge	Vendor to accept & offer			

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
7.3	Termination of electric power cable to incoming of furnace controls' switch-gear panel from BHEL's terminating point.	Vendor to accept & offer			
8.1	Power Supply will be provided by BHEL at a single point near the furnace, as per layout recommended by Vendor. All types of switches, cables, connections, circuit breakers etc. required for connecting BHEL's power supply point to different parts of the machine/control cabinets including Voltage Stabilizer, Isolation Transformer & Air Compressor etc. , shall be supplied by the vendor.	Vendor to accept & offer			
8.2	Tropicalisation: All electrical / electronic equipment shall be tropicalized.	Vendor to offer			
8.3	All electrical & electronic control cabinets & panels should be dust and vermin proof.	Vendor to offer			
8.4	All electrical components in the cabinets should be mounted on DIN Rail and should be of standard make such as L&T , Siemens etc.	Vendor to offer			
8.5	All electrical / electronic panels to be provided with adequate door locks. All electrical & electronic panels including operator's panel should have sufficient illumination and power receptacles/plug points of 220Volts, 5/15 Amp AC with on/off switch. All electrical adapters/receptacles, fittings, consumables etc. should be Indian or should have compatibility with Indian equivalents.	Vendor to offer			
8.6	All motors shall conform to IEC or Indian Standards	Vendor to offer			
8.7	Vendor should ensure the proper earthing for the machine and its peripherals/accessories. Any material requirement for the same should be informed with foundation design/drawings. The vendor can take earthing connection from the nearest column of the production shop.	Vendor to offer			
9	<b>SAFETY ARRANGEMENTS</b>	Vendor to offer			
	Following safety features in addition to other standard safety features should be provided on the machine:				
9.1	Furnace Safety system:	Vendor to offer			

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
	Furnace and the control system should have adequate earthing and reliable safety interlocks/ devices to avoid damage to the furnace, ., job loaded inside furnace and the operator due to the malfunctioning or mistakes. Furnace functions should be continuously monitored and if the furnace temperature exceeds, alarm / warning indications through lights/ alarm on the control panel should be available.				
9.2	All the rotating parts used on furnace should be statically & dynamically balanced to avoid undue vibrations & noise.	Vendor to confirm			
9.3	Emergency Switches at suitable locations as per International Norms should be provided.	Vendor to offer			
9.4	Oil & water pipe lines should not run with electrical cable in the same trench.	Vendor to offer			
10	<b>ENVIRONMENTAL PERFORMANCE OF THE MACHINE : The Furnace system should conform to following factors related to environment :</b>	Vendor to offer			
10.1	Maximum noise level shall be 85 dB(A) at normal load condition, 1 meter away from the furnace with correction factor for back ground noise, if necessary.	Vendor to confirm			
	This will be measured as per international standards like DIN 45635-16, if required. Supplier to demonstrate compliance to noise level, if so required.				
10.2	There shall not be any hazardous emissions from the furnace during operation.	Vendor to confirm			
10.3	No hazardous chemicals shall be required to be used in the furnace.	Vendor to confirm			
10.4	If any safety / environmental protection enclosure is required it should be built in the machine by the vendor.	Vendor to confirm			
10.5	Paint of the furnace should be oil / heat resistant and should not get peeled off and mixed up with oil.	Vendor to confirm			
11	<b>SPARES :</b>				

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
11.1	Itemised breakup of mechanical, pneumatic, electrical and electronic spares and heating elements used on the furnace in sufficient quantity as per recommendation of Vendor for 2 years of trouble free operation on three shifts continuous running basis should be offered by vendor.	Vendor to offer			
	The list to include following, in addition to other recommended spares: (Unit Price of each item of spare should be offered)				
11.2	Electrical /Electronic Spares: Following Spares are to be offered.	Vendor to offer			
11.2.1	Relays ( 2 Nos each type )	Vendor to offer			
11.2.2	Contactors ( 2 Nos each type )	Vendor to offer			
11.2.3	RTD temperature transmitter ( 1 No each type )	Vendor to offer			
11.2.4	Push Buttons ( 5 Nos each type )	Vendor to offer			
11.2.5	Indicating Lamps ( 10 Nos each type )	Vendor to offer			
11.2.6	Semiconductor Fuses ( 5 Nos each type )	Vendor to offer			
11.2.7	Special Fuses ( 5 Nos each type )	Vendor to offer			
11.2.8	Circuit Breakers ( 1 No each type )	Vendor to offer			
11.2.9	Main Power Switch ( 1 No )	Vendor to offer			
11.2.10	Complete drive controller.	Vendor to offer			
11.2.11	Thermocouple ( 2 nos each type)	Vendor to offer			
11.2.12	Programmable temperature controller ( 1 no. each type)	Vendor to offer.			
11.2.13	Recirculating Fan ( 4 nos) , Fan shaft ( 4 nos) , Bearings ( 10 nos each)				
11.3	All types of spares for total Furnace and accessories should be available for at least ten years after supply of the machine. If component or control is likely to become obsolete in this period, the vendor should inform BHEL sufficiently in advance and provide drawings of parts / details of spares & suppliers to enable BHEL to procure these in advance, if required	Vendor to confirm			
11.4	Vendor to confirm that complete list of spares for Furnace and accessories, along with specification / type / model, and name & address of the spare supplier shall be furnished along with documentation to be supplied with the furnace.	Vendor to confirm			
12	<b>DOCUMENTATION :</b>	Vendor to offer			

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
	Three sets of following documents (Hard copies & soft copies) in English language should be supplied along with the machine				
12.1	Operating manuals of Heat Treatment furnace.	Vendor to offer			
12.2	Detailed Maintenance manual of the furnace with all drawings of machine assemblies/sub-assemblies/parts including Electrical / Pneumatic circuit diagrams. All Assembly/ Sub Assembly Drawings shall be supplied with the part list also. All Electrical schematic, wiring diagram, cable layout and junction box diagram, circuit diagram and interface diagram of Electronic PCB's used in the Furnace.	Vendor to offer			
12.3	Catalogues, Operation & Maintenance Manuals of all bought out items including drawings, wherever applicable.	Vendor to offer			
12.3.1	Drawing of furnace shell and recirculating fan with dimensions.	Vendor to offer.			
12.4	Detailed specification of all rubber items and pneumatic fittings	Vendor to offer			
12.5	Complete list of parts/items( Bill of materials) used in the furnace in English language.	Vendor to offer			
12.6	One additional set of all the above documentation on CD ROM, wherever possible.	Vendor to offer			
12.7	Calibration certificate of all controllers is required.	Vendor to confirm			
13	<b>PROVE-OUT HEAT TREATMENT OF BHEL COMPONENT</b>				
13.1	Vendor shall be fully responsible for heat treatment of prove out component as per heat treatment cycle to the full satisfaction of BHEL	Vendor to accept & confirm			
13.2	Vendor shall be responsible for any deviation/rejection in prove out component due to malfunctioning of the furnace during prove out heat treatment. The cost of such component shall be refunded by the vendor to BHEL in case of rejection of the component.	Vendor to accept & confirm			
14	<b>TRAINING OF BHEL PERSONNEL</b>				
14.1	Training of BHEL furnace operators in operation of complete machine	Vendor to confirm			
	& accessories etc by the supplier's experts / engineers during their stay at BHEL work.				

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
14.2	Training of BHEL maintenance personnel in maintenance of complete furnace & accessories etc by the supplier's experts / engineers during their stay at BHEL works.	Vendor to confirm			
14.3	Training of BHEL Instrumentation personnel in programming and maintenance of controller in detail to be provided at company's specialized training center or at BHEL works by suppliers experts/engineers.	Vendor to confirm			
15	Vendor shall submit the preliminary layout drawings for getting BHEL's approval within one month from the date of Letter of Intent (LOI) or Purchase Order, whichever is earlier.	Vendor to accept & offer			
15.1	Complete Foundation Design including details viz. static / dynamic load details etc. and final layout drawings shall be submitted by the supplier within two months after getting BHEL's approval for Preliminary layout Drgs..				
15.2	The layout should consist of all requirements pertaining to complete machine including space requirement for all accessories/ attachments/ offered items.				
15.3	BHEL shall construct complete foundation for the furnace system under supervision of supplier and at vendor's responsibility.				
15.4	Vendor should arrange equipment required for the testing of foundation, if required by the vendor.				
15.5	The vendor shall also indicate detailed specifications/requirement of earthing material, grouting compound and grouting procedure etc. for foundation bolts of the machine.				
16	<b>ERECTION &amp; COMMISSIONING</b>				
16.1	Erection & Commissioning of the complete bogie hearth furnace and other accessories/attachments with all electrical & mechanical connections shall also be responsibility of the vendor.	Vendor to offer			

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
16.2	Successful proving of BHEL components by the supplier shall be considered as part of commissioning for the machine . All features and functions, as mentioned at Sl. No. 20 (Machine Acceptance) shall also be part of the commissioning activity.	Vendor to offer			
16.3	Tools, Tackles, instruments and other necessary equipment required to carry out all erection & commissioning activities should be arranged and brought by the supplier.	Vendor to accept			
16.4	Commissioning spares, required for commissioning of the complete furnace within stipulated time, shall be brought by the supplier on returnable basis.	Vendor to accept			
16.5	Schedule of Erection and Commissioning shall be submitted with the offer.	Vendor to submit			
16.6	Terms & conditions for Erection & Commissioning should be furnished in detail separately by vendor along with offer.	Vendor to submit			
16.7	Portion, if any, of the machine, accessories/attachments and other supplied items where paint got rubbed or peeled off during transit or erection should be repainted and matched with the original adjoining paint by the vendor. For this purpose, the vendor should supply sufficient quantity of touch-up paint of various colors/shades of paints used. The vendor shall ensure performing touching after commissioning but before final acceptance.	Vendor to offer			
17	<b>AMBIENT CONDITIONS &amp; THERMAL STABILITY</b>				
17.1	Total machine including all supplied items should work trouble free and should give specified accuracies under existing power supply and ambient operating conditions, as mentioned below at Sl. Nos. 19.4	Vendor to accept & confirm			
17.2	Power Supply (AC): Voltage = 415V 10% of fluctuations, Frequency= 50Hz ± 3%, No. of phases = 3 phase with neutral.	Vendor to accept & confirm			
17.3	Compressed Air Supply: available at Pressure 3 - 5 Kg /cm2 gauge.	Vendor to accept & confirm			

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
17.4	Ambient Operating Conditions: Temperature = 5 to 45 degree Celsius Relative Humidity = 95% max. Weather conditions are tropical. Atmosphere may be dust laden during some part of the year. Machine shall be kept in the normal shop floor condition without any temperature controlled enclosure/shop. Max. Temperature variation is 25 deg Celsius in 24 hours.	Vendor to accept			
17.5	Thermal Stability: Thermal Stability of the complete furnace components and all supplied items including controls for their trouble-free operation with specified accuracy in the specified Ambient Conditions should be ensured and confirmed by vendor.	Vendor to offer & confirm			
17.6	The complete furnace system should be suitable for continuous operation to its full capacity for 24 hours a day and 7 days a week throughout year. Vendor to ensure and confirm the same.	Vendor to offer & confirm			
18	<b>MACHINE ACCEPTANCE (Tests/Activities to be performed &amp; demonstrated by Vendor at BHEL works while commissioning the furnace)</b>	Vendor to accept & confirm			
18.1	Demonstration of all features of the furnace, control system & accessories to the satisfaction of BHEL for efficient and effective use of the furnace.	Vendor to accept & confirm			
18.2	Job Proving: The complete furnace should be tested ( for the performance of the furnace and all sub systems) by continuously running for 96 hrs to its full capacity (with respect to load and maximum temperature etc.). If any break down occurs during this test, the test should be repeated for 96 hrs from that time	Vendor to accept & confirm			
18.3	Two weeks of supervision by Vendor of independent operation of the furnace by BHEL after job prove out.	Vendor to accept & confirm			
18.4	Training of BHEL furnace operators in operation of complete machine	Vendor to accept & confirm			
	& accessories etc by the supplier's experts / engineers during their stay at BHEL work.				

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
18.5	Training of BHEL maintenance personal in maintenance of complete furnace & accessories etc by the supplier's experts / engineers during their stay at BHEL works.	Vendor to confirm			
19	<b>PACKING</b>				
19.1	See worthy & rigid packing for all items of furnace, controls, mechanical movement System, all Accessories and other supplied items to avoid any damage/loss in transit. When machine is dispatched in containers, all small loose items shall be suitably packed in boxes. In case machine is dispatched in container, the container shall be brought upto BHEL, Trichy. De- stuffing of container shall be carried out at BHEL, Trichy by the vendor's representative. Any type of material handling equipment required for the de-stuffing of the container shall be brought by the vendor at Trichy on returnable basis.	Vendor to offer & confirm			
20	<b>GUARANTEE</b>				
20.1	Guarantee for complete Furnace and all supplied accessories/attachments/equipment/items for 24 months from the date of acceptance of the machine.	Vendor to offer			
21	<b>GENERAL</b>				
21.1	Furnace / Machine Model No.	Vendor to inform			
21.2	Total connected load (KVA)	Vendor to inform			
21.3	Total Space required (Length, Width, Height) for complete furnace and accessories/attachments.	Vendor to inform			
21.4	Painting of Machine / Electrical Panels : RAL 6011 Apple Green ( Polyurethane Paint )	Vendor to offer			
21.5	Total weight of the Furnace after erecting at BHEL-Trichy	Vendor to inform			
21.6	Weight of the heaviest assembly of the Furnace system.	Vendor to inform			
21.7	Dimensions of largest part of the Furnace System.	Vendor to inform			
21.8	Vendor to submit reference list of customers where similar furnaces have been supplied mentioning broad specifications of the supplied furnace i.e. Model, chamber size, pay load, maximum temperature, year of supply and customer feedback, if any, etc.	Vendor to submit			

SL. NO.	DESCRIPTION OF BHEL REQUIREMENT	REQUIRED	OFFERED	DEVIATION	REMARKS
21.9	Detailed catalogues, sketches /drawings / photographs pertaining to the offered furnace system and accessories/attachments/items should be submitted with the offer.	Vendor to submit			
21.10	Hydraulic, Pneumatic & Oil piping should be preferably metallic except places where flexible piping are essential. All the pipes required for the same shall be supplied by the vendor.	Vendor to confirm			
21.11	All Cables and Hoses etc. should be well supported & protected in trays / brackets / drag chains etc. All the power / control cables used in the furnace should be of copper and of reputed make.	Vendor to confirm			
22	<b>QUALIFYING CONDITIONS</b>				
22.1	Only those vendors, who have supplied and commissioned at least one Big size Electrical Bogie Hearth Furnace of same or higher sizes for similar applications of stress relieving of fabricated component / casings in the past ten years (on the date of opening of tender) and such furnace is presently working satisfactorily for more than one year after commissioning (on the date of opening of tender) , should quote. However if similar furnace(s) has/had been supplied to BHEL ,then the furnace should be presently working satisfactorily for more than six months after its commissioning and acceptance (on the date of opening of tender ) should quote. The following information should be submitted by the vendor about the companies where similar furnaces have been supplied. This is required from all the vendors for qualification of their offer.	Vendor to comply & submit with the offer			
22.1.1	Name of the customer / company where similar furnace is installed.	Vendor to inform			
22.1.2	Complete postal address of the customer.	Vendor to inform			
22.1.3	Month & Year of commissioning.	Vendor to inform			
22.1.4	Broad specification of the furnace(s) supplied (Chamber Size LxWxH, Max. Payload, Maximum temperature) and application for which the furnace is supplied.	Vendor to inform			

<b>SL. NO.</b>	<b>DESCRIPTION OF BHEL REQUIREMENT</b>	<b>REQUIRED</b>	<b>OFFERED</b>	<b>DEVIATION</b>	<b>REMARKS</b>
22.1.5	Name and designation of the contact person of the customer.	Vendor to inform			
22.1.6	Phone, FAX no. and e-mail address of the contact person of the customer.	Vendor to inform			
22.2	Performance certificate from the customers regarding satisfactory performance of furnace supplied to them (Original Certificate or Through E-mail directly from the customer). The original performance certificate may be returned after verification by BHEL, if required.	Vendor to submit			
22.3	BHEL reserves the right to verify information submitted by vendor. In case the information is found to be false/incorrect, the offer shall be rejected.	Vendor to accept & confirm			