



BHARAT HEAVY ELECTRICALS LIMITED

(A Government of India Undertaking)
HIGH PRESSURE BOILER PLANT
PURCHASE DEPARTMENT - FOSSIL BOILERS
THIRUCHIRAPALLI - 620014
TAMILNADU (INDIA)

Page
2/4

PHONE :2577331
GRAMS : BHARATELEC
FAX NO: 2520719
E-mail: srchandran@bheltry.co.in
Web:

2661500141 / 09.05.2015

3.08 Change over time (mains to inverter): <10 ms

3.09 Change over time (from inverter to mains):
The output voltage should be switched off after 5 minutes (approx.) once mains supply is resumed. Vendor to confirm.

3.10 Meters: Output AC and DC metering (LED / LCD type) for voltage and current measurement.

3.11 Displays: Capacity, output voltage and frequency, input voltage and frequency, inverter on, mains on, charger on, low battery, all protections, load percentage, present battery full.

Vendor to specify.

3.12 Thermal management: Integrated cooling (fan & heat sink).

3.13 Operating temperature: 15 - 50 deg. Celsius

3.14 Protection: Input under voltage and over voltage.

Battery low voltage.
Output short circuit.
Output under/ over voltage.
Output overload.
Over temperature.
DC over current protection.
Output voltage regulation.
Spike protection.

Vendor to specify.

3.15 Control switches: Input, output and inverter MCBs.

HRC fuses for the above, beep sound for tripping, over/ under/ low voltage, short circuit and inverter trip control.

Vendor to specify.

3.16 Nominal battery voltage: Vendor to specify.

3.17 Battery charging current: 1)Boost charging :-

2)Float charging :-

Vendor to specify.

3.18 Total harmonic distortion: Less than 3%.

Vendor to specify.

4.0 Specification of battery

4.1 Type: Sealed Maintenance Free VRLA battery. Vendor to confirm.

4.2 Make and Model: Exide/ Amara Raja/ Luminous/ SF Sonic/ Standard make batteries are only acceptable.


Vendor to specify.

4.3 Specification: 12 V, 150 Ah batteries are to be offered for the connected load of 4000 Watts for a battery back up of 1 hour.

Vendor to confirm.

The offers should reach us 30 minutes before the time of opening of tenders. The offers will be opened at 14.30 hrs on the due date of tender in the presence of tenderers who have submitted their offer and who may like to be present for the tender opening. Late and delayed offers are liable to be rejected.

Yours faithfully,
For **BHARAT HEAVY ELECTRICALS LIMITED**


MANAGER / PURCHASE
(FOSSIL BOILERS)
Yours faithfully,



BHARAT HEAVY ELECTRICALS LIMITED

(A Government of India Undertaking)
HIGH PRESSURE BOILER PLANT
PURCHASE DEPARTMENT - FOSSIL BOILERS
THIRUCHIRAPALLI - 620014
TAMILNADU (INDIA)

PHONE :2577331
GRAMS : BHARATELEC
FAX NO: 2520719
E-mail: srchandran@bheltry.co.in
Web:

Page
3/4

2661500141 / 09.05.2015


4.3a. No. of batteries offered: Vendor to specify.
4.4 Terminals: Input terminals and Output terminals. Vendor to specify.
4.5 Warranty for battery: Minimum 2 years from the date of commissioning. Vendor to confirm.
5.0 Guarantee: Guarantee for complete equipment and all supplied accessories/ attachments/ equipment/ items for 24 months (approx.) from the date of acceptance of the equipment after commissioning at BHEL works. Vendor to confirm.
6.0 Commissioning: Commissioning will be done by BHEL's personnel in presence of vendor's representatives. Supplier has to send their representative for supervision and guidance.
7.0 Technical leaflet: Technical leaflet of the offered emergency power supply unit and battery indicating the complete technical parameters, features, dimensions etc. are to be enclosed with the offer. Dimensional drawing of the equipment must be attached with the offer. Vendor to confirm.
8.0 Documentation: Detailed Operation & Maintenance manual of the equipment containing all drawings of main assemblies, sub-assemblies, electrical and electronic part details including PCB circuit diagrams shall be provided. Periodic maintenance chart and details of bought-out items (if any) shall also be provided. Vendor to confirm.

General Note:

- 1.POINT-BY-POINT CONFIRMATION TO BHEL'S SPECIFICATIONS, COMMERCIAL TERMS & CONDITIONS ARE TO BE PROVIDED BY THE VENDORS IN "ANNEXURE A &B.
2. FILL UP ANNEXURE A. PLEASE ENSURE THAT ALL TERMS & CONDITIONS SHOULD BE INDICATED IN THE UN-PRICED BID TO BE ATTACHED WITH THE TECHNO-COMMERCIAL BID POSITIVELY.
3. VALIDITY OF THE OFFER SHOULD NOT BE LESS THAN 90 DAYS.
4. THE ORDER WILL BE PLACED ON INDIVIDUAL ITEMWISE L1 BASIS
5. THE BIDDER SHALL MEET PRE-QUALIFICATION CRITERIA

The offers should reach us 30 minutes before the time of opening of tenders. The offers will be opened at 14.30 hrs on the due date of tender in the presence of tenderers who have submitted their offer and who may like to be present for the tender opening.Late and delayed offers are liable to be rejected.

Yours faithfully,
For **BHARAT HEAVY ELECTRICALS LIMITED**


MANAGER / PURCHASE
(FOSSIL BOILERS)
Yours faithfully,



BHARAT HEAVY ELECTRICALS LIMITED

(A Government of India Undertaking)
HIGH PRESSURE BOILER PLANT
PURCHASE DEPARTMENT - FOSSIL BOILERS
THIRUCHIRAPALLI - 620014
TAMILNADU (INDIA)

PHONE :2577331
GRAMS : BHARATELEC
FAX NO: 2520719
E-mail: srchandran@bheltry.co.in
Web:

Page
4/4

2661500141 / 09.05.2015

6. WHEREVER FOR SPLITTING OF ORDER AS PER ANNEXURE II CLAUSE 27,IF SPLITTED QUANTITY COMES OUT <1 ,THE SPLITTING OF ORDER WILL NOT BE FEASIBLE. (For MSE vendors)

7.Your Quotations should be sent to:
,,The Tender Opening Cell/MM
,,Room No-26 , Building - 24 , Ground Floor
,,Bharat Heavy Electrical Limited
,,Tiruchirapalli- 620014 .

In case personal delivery of the offer , it shall be dropped into the respective box after duly entering the data in the system kept in room no 26 .

Vendors are requested to avoid submission of offers thro email / fax . In case of any unavoidable situation, offers shall be sent thro email to the following mail ID only " tender_cell@bheltry.co.in "

As such Tenders are being opened by Common Tender opening Cell , offer covers should be sealed with tender's distinctive seal and super scribed with correct Tender NO, item of supply and due date of Opening .

LIST OF ATTACHMENTS:


- 1.Pre qualification criteria
2. ANNEXURE-II TERMS AND CONDITIONS OF THE ENQUIRY. (TWO PART-BID)
3. ANNEXURE-V- CA certificate format(as per MSMED act 2006) to be furnished , if applicable -Refer ANNEXURE II CLAUSE 27 (For MSE vendors)
- 4.ANNEXURE-A CHECK LIST FOR TECHNICAL & COMMERCIAL TERMS CONFIRMATION-TO BE FILLED BY THE SUPPLIER.
5. ANNEXURE-B MODEL PRICE BID FORMAT.
6. ANNEXURE-VI CHECK LIST TO BE SUBMITTED ALONG WITH OFFER
- 7.Tachnical specification annexure -I (a) to be filed & to be submitted by supplier

Enclosures:

"LD clause has to be confirmed without fail."

The offers should reach us 30 minutes before the time of opening of tenders. The offers will be opened at 14.30 hrs on the due date of tender in the presence of tenderers who have submitted their offer and who may like to be present for the tender opening.Late and delayed offers are liable to be rejected.

Yours faithfully,
For **BHARAT HEAVY ELECTRICALS LIMITED**


MANAGER / PURCHASE
(FOSSIL BOILERS)
Yours faithfully,

**PRE- QUALIFICATION CRITERIA FOR Requirement of ups with
battery**

S.NO.	BHEL requirements	Vendor to confirm
1	Only those vendors who have supplied and commissioned similar or higher capacity equipment in the last five years (from the date of enquiry) should quote.	
2	Performance certificate or any other supporting document from the customer to whom the equipment was supplied shall be attached to support point 2.1 along with address and contact details of the customer for cross reference by BHEL.	
3	If upon verification by BHEL, the performance of the equipment is found not satisfactory at the mentioned customer's end or if any abnormalities are found in customer data then BHEL holds the right to reject the offer	

Annexure - 1 (A)
Technical Specifications for 5 kVA Emergency Power Supply Unit

Sl.No.	Description for BHEL Requirement	Specifications	Vendor to Specify/ Confirm	Deviations if any
1.0	Scope of supply	General purpose 5 kVA emergency power supply unit for a connected load of 4000W, suitable to provide 1 hour battery backup and operating on single phase or three phase AC supply. Quantity : 1 No.		
2.0	Pre - Qualification Criteria:			
2.1	Only those vendors who have supplied and commissioned similar or higher capacity equipment in the last five years (from the date of enquiry) should quote.	Vendor has to confirm and give the following details: 1. kVA rating of the equipment. 2. To whom supply was made. 3. Date of PO/ any equivalent document.		
2.2	Performance certificate or any other supporting document from the customer to whom the equipment was supplied shall be attached to support point 2.1 along with address and contact details of the customer for cross reference by BHEL.	Vendor has to confirm and documents have to be attached.		
2.3	If upon verification by BHEL, the performance of the equipment is found not satisfactory at the mentioned customer's end or if any abnormalities are found in customer data then BHEL holds the right to reject the offer.	Vendor has to confirm.		
3.0	SPECIFICATION			
3.01	Make and Model	Vendor to specify.		

Annexure - 1(A)

Technical Specifications for 5 kVA Emergency Power Supply Unit

Sl.No.	Description for BHEL Requirement	Specifications	Vendor to Specify/ Confirm	Deviations if any
3.02	AC input Voltage	Single Phase 230 V, 50 Hz AC or Three Phase 415 V, 50 Hz AC. Vendor has to specify.		
3.03	Power rating	Minimum capacity 5 kVA		
3.04	Output voltage & frequency	Phase:- Single Phase, Voltage:- 230 Volt AC, Frequency:- 50 Hz.		
3.05	Output waveform	Pure sine wave.		
3.06	Conversion technology	Whether Diode/ SCR/ IGBT. Vendor to specify.		
3.07	Efficiency	90% and above on resistive load. Vendor to specify.		
3.08	Change over time (mains to inverter)	<10ms		
3.09	Change over time (from inverter to mains)	The output voltage should be switched OFF after 5 minutes (approx.) once mains supply is resumed. Vendor to confirm.		
3.10	Meters	Output AC and DC metering (LED / LCD type) for voltage & current.		
3.11	Displays	Capacity, output voltage and frequency, input voltage and frequency, inverter on, mains on, charger on, low battery, all protections, load percentage, present battery full. Vendor to specify.		
3.12	Thermal management	Integrated cooling (fan & heat sink)		
3.13	Operating temperature	15- 50 deg. Celsius		

Annexure - 1 (a)
Technical Specifications for 5 kVA Emergency Power Supply Unit

Sl.No.	Description for BHEL Requirement	Specifications	Vendor to Specify/ Confirm	Deviations if any
3.14	Protection	Input under voltage and over voltage. Battery low voltage. Output short circuit. Output under/ over voltage. Output overload. Over temperature. DC over current protection. Output voltage regulation. Spike protection. Vendor to specify.		
3.15	Control switches	Input, output and inverter MCBs. HRC fuses for the above, beep sound for tripping, over/ under/ low voltage, short circuit and inverter trip control. Vendor to specify.		
3.16	Nominal battery voltage	Vendor to specify.		
3.17	Battery charging current	1)Boost charging :- 2)Float charging :- Vendor to specify.		
3.18	Total harmonic distortion	Less than 3%. Vendor to specify.		
4.0	BATTERY SPECIFICATIONS			
4.1	Type	Sealed Maintenance Free VRLA battery. Vendor to confirm.		
4.2	Make and Model	Exide/ Amara Raja/ Luminous/ SF Sonic/ Standard make batteries are only acceptable. Vendor to specify.		

Annexure - 1 (a)
Technical Specifications for 5 kVA Emergency Power Supply Unit

Sl.No.	Description for BHEL Requirement	Specifications	Vendor to Specify/ Confirm	Deviations if any
4.3	Specification	12 V, 150 Ah batteries are to be offered for the connected load of 4000 Watts for a battery back up of 1 hour. Vendor to confirm.		
4.3a	No. of batteries offered	Vendor to specify.		
4.4	Terminals	Input terminals and Output terminals. Vendor to specify.		
4.5	Warranty for battery	Minimum 2 years from the date of commissioning. Vendor to confirm.		
5.0	GUARANTEE	Guarantee for complete equipment and all supplied accessories/ attachments/ equipment/ items for 24 months (approx.) from the date of acceptance of the equipment after commissioning at BHEL works. Vendor to confirm.		
6.0	Commissioning	Commissioning will be done by BHEL's personnel in presence of vendor's representatives. Supplier has to send their representative for supervision and guidance.		
7.0	Technical leaflet			
7.1	Technical leaflet of the offered emergency power supply unit and battery indicating the complete technical parameters, features, dimensions etc. are to be enclosed with the offer. Dimensional drawing of the equipment must be attached with the offer.	Vendor to confirm.		

Annexure - 1 (a)

Technical Specifications for 5 kVA Emergency Power Supply Unit

Sl.No.	Description for BHEL Requirement	Specifications	Vendor to Specify/ Confirm	Deviations if any
8.0	DOCUMENTATION			
8.1	Documentation: (3 hard copies +1 soft copy in form of CD or Pen drive)	Detailed Operation & Maintenance manual of the equipment containing all drawings of main assemblies, sub-assemblies, electrical & electronic part details including PCB circuit diagrams shall be provided. Periodic maintenance chart and details of bought-out items (if any) shall also be provided. Vendor to confirm.		

TERMS AND CONDITIONS OF THE ENQUIRY (TWO PART BID)

1. The tender will be operated on two part bid basis i.e. (I).Techno-Commercial Bid & (II).Price Bid.
2. Techno-Commercial Bid: Containing Technical details, specifications, commercial terms and conditions like percentage of Freight & Insurance, ED WITH CESS, Taxes ,delivery terms, delivery schedule, validity of offer, payment terms (except price details), acceptance for LD clause, RP clause etc. as per ANNEXURE-A shall be put in a cover (1) and super scribed as "Techno-Commercial Bid" for Enquiry No:Dt:Due Dt.:
3. Price Bid: Containing the price details shall be put in a separate cover (2) and superscripted as "Price Bid" for Enquiry No:Dt:Due Dt.: as per ANNEXURE -B (submitted in your company letter head)
4. You are requested to put the above two envelopes (Techno-Commercial Bid & Price Bid) inside a separate larger sealed envelope and this envelope shall be super scribed as "Techno-Commercial Bid and Price Bid" for Enquiry No:Dt:Due Dt.:
5. Tender should not be addressed to any individual's name but only by designation.
6. Tenders should be free from CORRECTION AND ERASURES. Corrections if any must be attested; all amounts shall be indicated both in words as well as in figures. Where there is difference between amount quoted in words and figures, amount quoted in words shall only be considered.
7. Please submit point wise compliance to our specifications, terms and conditions. Otherwise it will be presumed that you are accepting BHEL's terms and conditions. Fill Up Annexure A. Please Ensure That All Terms & Conditions Should Be Indicated in The Un-Priced Bid To Be Attached With The Techno-Commercial Bid Positively(ANNEXURE-A)
8. Offer/s received after due date and time: **02:00 pm** will not be considered under any circumstances.
9. **Validity** of quoted rates should be maintained minimum for **90 days** from the date of Tender opening for ordering (Technical Bid). The quoted/Finalized rates shall be Firm till completion of the supplies.
10. The rates are to be quoted on **F.O.R. BHEL THIRUMAYAM/PUDUKKOTTAI Distt-622507 basis (Inclusive of Packing, Forwarding) and separately Freight & Transit Insurance charges which are payable to supplier**. All the items should be supplied at our stores, BHEL **THIRUMAYAM/PUDUKKOTTAI Distt-622507** at your own cost. Offers with any other delivery conditions is not acceptable .

IMPORTANT NOTE: (I) Delivery condition like Ex-works / Ex-godown / Transportation of materials through transport carriers from your works up to the transport carrier's office at THIRUMAYAM and taking delivery of goods by BHEL from such office of transport carriers is not acceptable to us)

11. Payment Terms (Indigenous)

Payment term is 100% direct payment after 45 days from the date of receipt and acceptance of materials.

Any deviation in the above payment term will attract loading as mentioned below.

"Base rate of SBI (as applicable on the date of bid opening. Techno-commercial bid opening in case of two part bids) + 6% shall be considered for loading for the period of relaxation sought by bidders.

Payment through Bank is not preferred. In case of Payment through Bank is opted by Supplier, BHEL prefers documents submission through bank with copy of LR and door delivery of Goods to Site/Stores with Consignee copy attached. In this case Loading will be 3% on the offered value.

Offers of indigenous Suppliers with payment terms as LC/Advance Payment are liable for rejection.

Payment term for supply portion(For import supplies)

BHEL Payment term is 100% payment on CAD basis after 45 days from the date of receipt of documents, specified in PO, at BHEL bank. Respective bank charges to respective account.

Any deviation in the above payment term will attract loading as mentioned below.

"Base rate of SBI (as applicable on the date of bid opening. Techno-commercial bid opening in case of two part bids) + 6% shall be considered for loading for the period of relaxation sought by bidders.

In the case of Usance LCs the loading will be considered @ 1.5% on the offered Value.

For LC at sight the loading will be considered @ 3.5% on the offered Value.

Normally CAD at sight and Confirmed LCs are liable for rejection.

Payment terms for Indian agent:

Indian Agency Commission ,if any, shall be clearly specified in the offer and the same will be paid in Indian Rupees against acceptance of the materials

12. Liquidated Damages / Penalty:-

Liquidated damages shall be 0.5% of the total order value per week or part thereof subject to a maximum of 10% of the total order value.

For staggered delivery schedule, LD shall be 0.5% of the undelivered portion per week of the delay or part there of subject to a maximum of 10% of the total order value.

Any deviation from the above LD clause, loading will be applied to the extent to which it is not agreed by the bidder (at offered value).

13. If Guarantee / Warranty period is applicable as per tender specification, No deviation permitted and deviated

offers are liable for rejection.

14. IMPORTANT NOTE: BHEL WILL CONSIDER THE RANKING AFTER THE LOADING IS APPLIED AS REFERRED ABOVE WHEREVER DEVIATIONS ARE OBSERVED.

15. No revision of prices will be entertained at any circumstances after tenders are opened.

16. If any sales tax is payable as extra to the quoted price it should be specifically stated in quotations along with CST & VAT Number failing which the purchaser will not be liable for payment of sales tax. Our TIN 33243560005 dt.01.01.2007 & CST no 239383 DT, 11.06.1991

17. On the due date of tender opening, only the technical bids will be opened. Technical bids will be evaluated by us and clarifications required, if any, will be called for from the bidders on technical and commercial points. The price bids of techno-commercially suitable bidders will be opened at a later date with prior intimation to respective suitable bidders.

18. Ranking L-1, L-2 etc. shall be done generally on each individual items for the techno-commercially acceptable offers on landed cost to BHEL, **THIRUMAYAM/PUDUKKOTTAI Distt-622507** basis and BHEL reserves the right to place order for individual items with different vendors. At special circumstance ranking shall be done on compatible basis which will be indicated through Enquiry special instruction General Notes.

19. BHEL reserves the right to increase or decrease the tender quantity and split up the tender quantity among more than one vendor at the lowest acceptable price to BHEL and place order accordingly in any proportion at our own discretion.

20. Lowest price received against BHEL tenders need not be the technically acceptable one and in that case BHEL reserves the right not to consider the same. The purchaser shall be under no obligation to accept the lowest or any other tender and shall be entitled to accept or reject any tender in part or full without assigning any reason whatsoever.

21. BHEL reserves the right to negotiate or refloat the tender opened, if L1 price is not the lowest acceptable price to BHEL due to inter-alia other reasons.

22. **PACKING AND MARKING:** The supplier shall arrange for securely protecting and packing the stores to avoid loss or damages during transit.

23. **RISK PURCHASE:** Alternatively the purchaser at his option will be entitled to terminate the contract and to purchase elsewhere at the risk and cost of the seller either the whole of the goods or any part which the previous supplier has failed to deliver or dispatch within the time stipulated as aforesaid or if the same were not available, the best and the nearest available substitutes therefore. The new supplier shall be liable for any loss, which the purchaser may sustain by reason of such risk purchases in addition to penalty at the rate mentioned in our LD clause.

24. **PREFERENTIAL DELIVERY:**(Applicable in the case of BHEL's Enquiry specifies Preferential Delivery in the Special Instructions) It should be noted if a contract is placed on a higher tendered as a result of this invitation to tender in preference to the lowest acceptable offer in consideration of the earlier delivery, the seller will be liable to pay to the purchaser the difference between the contract rate and that of the lowest acceptable tender on the basis of final price F.O.R destination, including all elements of freights, Sales tax, duties and other incidents, incidental in case of failure to complete supplies in terms of such contract within the date of delivery specified in the tender and incorporated in the contract, such difference amount in addition to penalty at the rate mentioned in our LD clause.

25. **CENVAT CREDIT:** If any Excise Duty is payable, the Chapter Head / Sub -head reference and the rate of the duty should be quoted. If the Tenderer is availing CENVAT credit for this input material, the effect of Performa credit should be passed on to the purchaser. Tenderer under "CENVAT" shall be preferred.

26. Any other conditions which might have been quoted by the seller and are in contravention to the terms prescribed in the order and which have not been specifically accepted by purchaser in written will not be applicable to the contract.

27. The bidder may also be a Micro and Small Enterprises (MSE) vendor registered as per MSE act. As per the public procurement policy notified by the Central government,

20% of the tendered quantity is earmarked for MSE suppliers in this tender.

Out of the 20% tendered quantity reserved for MSE suppliers, 4% shall be earmarked for procurement from MSE owned by SC / ST entrepreneurs.

In case MSE vendor participating in the tender quotes within the price band of L1 + 15%, they will be allowed to supply the portion of the requirement subject to acceptance of L1 price by MSE vendor. In case of more than one such MSE, the supply shall be shared proportionately.

"MSE suppliers can avail the intended benefits only if they submit along with the offer, attested copies of either EM II certificate having deemed validity (five years from the date of issue of acknowledgement in EM, II) or valid NSIC certificate or EM II certificate along with attested copy of a CA certificate (Format enclosed at Annexure -V where deemed validity of EM II certificate of five years has expired) applicable for the relevant financial year (latest audited). Date to be reckoned for determining the deemed validity will be the date of bid opening (Part I in case of two part bid). Non submission of such documents will lead to consideration of their bid at par with other bidders. No benefit shall be applicable for this enquiry if any deficiency in the above required documents are not submitted before price bid opening. Documents should be notarized or attested by a Gazetted officer. "

28. For verification of data submitted towards evaluation of bidder's capability, BHEL may decide to visit the bidder(s) works. Any fact found deviating from submitted data shall make the bidder liable to be disqualified.

29. In the event of more than one vendor becoming L1 for any of the item / items, the enquiry quantity for those item / items will be shared equally among all the L1 vendors.

30. The correspondence between the bidder and BHEL through email is considered as valid document Legally though not signed. It is treated as valid confirmations made on behalf of the respective company and comes under the legal ambit of the business transaction and hence binding on both the parties.

31. Equipment will be inspected and proved at vendor's works prior to dispatch, if applicable as per tender condition. However final inspection and acceptance of equipment will be after installation at BHEL, **THIRUMAYAM/PUDUKKOTTAI Distt-622507**.

32. Erection / commissioning charges , if applicable as per tender condition will be clearly mentioned in the offer or else confirmation that Erection / commissioning shall be done at free of cost is available in the offer.

33. Price shall be quoted item wise.

34. Any warranty replacement during warranty period shall be supplied free of charge on FOR BHEL, **THIRUMAYAM/PUDUKKOTTAI Distt-622507** basis

35. The vendor shall provide necessary drawings, Test Certificates and Operating Maintenance Manuals etc., as called for in the Technical Specification, in the required number of copies at no extra cost.

36. Part Shipment or Transshipment is not permissible.(For import supplies)

37. In case of any short shipment in the main equipment / spares, where separate rates are not available in the contract, the customs duty levied on such supplies, shall be borne by the supplier / Indian agent.(For import supplies)

38. Indicate Nearest airport & sea port, Country of Origin .(For import supplies)

39. Vendors Meeting Our Pre-Qualification Criteria & Technical Specification Will Be Essential For Consideration Of Offer.

40. For The Vendor Willing To Participate In Tender Opening, The Representative Should Have Valid Company ID Proof & Authorization Letter From The Concerned Firm Who Has Submitted The Offer.

41. After Technical Scrutinisation Of The Offers, Price Bid Of Only Technically Qualified Vendors Will Be Opened With Prior Intimation.

42. If The Due Date Of Tender Opening Happens to be a Holiday, Those Tenders Will Be Opened On Next Working Days

43. For any clarification you can contact to srchandran@bheltry.co.in, pgavictor@bheltry.co.in, rrvic@bheltry.co.in

44. This Tender Is Hosted Both In Bhel Website And In NIC, PSU Portal And Any Corrigendum May PI Be Viewed in BHEL's website <http://www.bhel.com> (Tender Notification page)

Govt. Tender website <http://tenders.gov.in> (Public sector units > Bharat Heavy Electricals Limited Page)

45. If we receive offer from both Manufacturer and their Agent / Dealer or any other, the offer of Manufacturer only will be cons

Annexure-V

Certificate by Chartered Accountant on letter head

This is to Certify that M/S
(hereinafter referred to as 'company') having its registered office at
..... is registered under MSMED Act 2006, (Entrepreneur
Memorandum No (Part—II) dtd.....
Category:(Micro/Small)). (Copy enclosed).

Further verified from the Books of Accounts that the investment of the company as per the
latest audited financial year as per MSMED Act 2006 is as follows:

- 1. For Manufacturing Enterprises:** Investment in plant and machinery (i.e. original cost excluding land and building and the items specified by the Ministry of Small Scale Industries vide its notification No.S.0.1722(E) dated October 5, 2006 :
Rs.....Lacs
- 2. For Service Enterprises:** Investment in equipment (original cost excluding land and building and furniture, fittings and other items not directly related to the service rendered or as may be notified under the MSMED Act, 2006:
Rs... ..Lacs

(Strike off whichever is not applicable)

The above investment of RsLacs is within permissible limit of
Rs.Lacs forMicro / Small **(Strike off which is not applicable)**
Category under MSMED Act 2006.

Or

The company has been graduated from its original category (Micro/ Small) **(Strike off which is not applicable)** and the date of graduation of such enterprise from its original category is
(dd/mm/yyyy) which is within the period of 3 years from the date of graduation of such enterprise from its original category as notified vide S.O. No. 3322(E) dated 01.11.2013 published in the gazette notification dated 04.11.2013 by Ministry of MSME.

Date:

(Signature)

Name -

Membership number -

Seal of chartered accountant

ANNEXURE –A (CHECK LIST FOR TECHNICAL & COMMERCIAL TERMS CONFIRMATIONS)**(a).TECHNICAL TERMS CONFIRMATION: AGAINST ALL ENQ SL NOS. (SUBMITTED IN COVER NO: 1)**

ENQ NO	SL	BHEL SPECIFICATIONS	YOUR SPECIFICATION	unit	Quantity	Consignment weight against each item separately	whether quoted/ not quoted
10							
20							
30							

(b).COMMERCIAL TERMS CONFIRMATION REQUIRED FROM SUPPLIERS (SUBMITTED IN COVER NO: 1)

SL NO	DESCRIPTION	BHEL REQUIREMENTS	SUPPLIER CONFIRMATION
1	VALIDITY	MINIMUM 90 Days from Date of tender opening	
2	PRICE QUOTED	FOR BHEL THIRUMAYAM INCLUSIVE OF PACKING & FORWARDING CHARGES.	
3	EXCISE DUTY WITH CESS (Whether inclusive (or) extra) Clearly mention the percentage	SUPPLIER TO QUOTE	
4	VAT % Clearly mention the percentage	SUPPLIER TO QUOTE	
5	CST % against form 'C' Clearly mention the percentage	SUPPLIER TO QUOTE	
6	FREIGHT & INSURANCE CHARGES FOR DELIVERY AT BHEL / THIRUMAYAM STORES/PUDUKKOTTAI Distt-622507	SUPPLIER TO QUOTE IN % ONLY	
7	DEIVERY SCHEDULE FROM THE DATE OF PURCHASE ORDER / LETTER OF INTENT	SUPPLIER TO QUOTE IN NO. OF DAYS/ WEEKS	
8	PAYMENT TERMS	As per Clause 11 of Terms and Conditions of the Enquiry (Two Part Bid)	
9	LIQUIDATED DAMAGES CLAUSE	As per Clause 12 of Terms and Conditions of the Enquiry (Two Part Bid)	
10	RISK PURCHASE CLAUSE	As per Clause 23 of Terms and Conditions of the Enquiry (Two Part Bid)	
11	GUARANTEE / WARRANTY	AS PER TENDER CONDITION	
12	ERECTION / COMMISSIONING	AS PER TENDER CONDITION	
13.	Origin of dispatch	SUPPLIER TO QUOTE	
14.	Nearest airport & sea port (For import supplies)	SUPPLIER TO QUOTE	
15.	Country of Origin (For import supplies)	SUPPLIER TO QUOTE	
16	CONTACT PERSON DETAILS	NAME:	
		MOBILE NO:	
		LAND LINE NO:	
		EMAIL :	
		FAX:	

NOTE: a). -It is confirmed that all the terms and conditions stipulated in the Enquiry have been fully understood by us and all clarifications & details have been obtained.

b)Your specific acceptance to our Payment terms,LD & Risk Purchase Clause are essential for consideration of your offer.

c).No row shall be left blank. Please indicate NA, in case the item is "not applicable"

Full postal Address:

Signature & Office Seal of the vendor

ANNEXURE –B (MODEL PRICE BID FORMAT)

EN Q SL NO	BHEL SPECIFICATIONS	YOUR SPECIFICATION	unit	quantity	Rate in Rs.	Value in Rs.
10						
20						
30						

PRICE BID FORMAT OF ALL QUOTED ITEMS, IF ANY ITEM YOUR ARE NOT QUOTED SIMPLY YOU SHOULD MENTION AS “NOT QUOTED” AGAINST THAT ENQ SL NO. (SUBMITTED IN SEPARATE COVER NO: 2)

Annexure-VI

CHECK LIST TO BE SUBMITTED ALONG WITH OFFER

SL NO	Documents submitted	Vendor's Confirmation Yes/No
01.	Offer Submitted in 2 bid system i.e. (I).Techno-Commercial Bid & (II).Price Bid inside a separate larger sealed envelope and this envelope shall be super scribed as "Techno-Commercial Bid and Price Bid" for Enquiry No:Dt.:Due Dt.:	
02.	Annexure-A part-(a).TECHNICAL TERMS CONFIRMATION & part (b).COMMERCIAL TERMS CONFIRMATION to be SUBMITTED ALONGWITH IN COVER NO: 1	
03.	Annexure-B- Price Bid to be SUBMITTED IN SEPARATE COVER NO: 2	
04.	Pre-Qualification Criteria fulfilled& documents Submitted	
05.	Documents/technical catalouges /DRAWINGS, (wherever as applicable) submitted as per tender condition	
06.	point to point confirmation provided as per tender condition	