



Enquiry Corrigendum-1

NIT – 26752

Enquiry No. 2661600090 dated 05.03.2016

Extended Due date for submission of quotation : 06.04.2016

Item Description: "Fume exhaust blower"

Details of Corrigendum:

*Technical specification is revised.Please refer the attached file.

The due date of the tender is revised as 06.04.2016.Kindly arrange to send your offer before the due date.

The offer should reach us before the time (14:00) of opening of tenders.

In case the offer has been sent already, the same to be sent again.

All other terms & conditions as published in the above NIT No.remain unaltered.

NOTE:

Confirmation of acceptance for BHEL Commercial terms & conditions & Price Bids formats have been posted in BHEL corporate website www.bhel.com or from the government tender website <http://tenders.gov.in> (public sector→Bharat Heavy Electricals Limited page) under Enquiry reference "2661600090".

FOR BHEL TRICHY:


V. CHELLIAH
Sr Manager / Purchase
MM / RM / CP & SP
BHEL, TRICHY -620 014.


CORRIGENDUM FOR PART - B TECHNICAL SPECIFICATION

Ref. Open Tender No.: 2661600090 - 55, Dt: 05.03.2016

Item Description: Fumes Exhaust Blower for Salt Bath Furnace, Heat Treatment Shop, Bldg.63 / VPN

S.No	Clause No.	Existing Specification	Revised Specification
1	3.5	Static Pressure: Vendor to specify	Static Pressure: 60 mmWC
2	4.2	Motor RPM - Vendor to specify.	Motor RPM : Minimum 1400 RPM
3	5.1	The supplier has to interconnect the exhaust blower to the existing FRP chimney and the FRP ducting systems with suitable modifications. Stainless steel collar (SS 316) has to be provided for the interconnection purpose. Vendor to confirm.	The supplier has to interconnect the exhaust blower to the existing FRP chimney and the FRP ducting systems with suitable modifications. Stainless steel collar (SS 316) has to be provided for the interconnection purpose. Vendor to confirm. (Existing FRP Ducting & FRP Chimney Diameter : 0.48 m)


P. EDANCO
 21/3/16
 Maintenance Engineer
 Maintenance & Services
 BHEL, TRICHY - 620 014.


R. SOLAIRAJ
 Sr. Engineer
 Maintenance & Services
 BHEL, TRICHY - 620 014.

21/3/2016

PR AMENDMENT
 Date 21-03-2016