



An ISO 9001
Company

Bharat Heavy Electricals Limited

(High Pressure Boiler Plant)

Tiruchirappalli – 620014, TAMIL NADU, INDIA

MATERIALS MANAGEMENT

TITLE CORRIGENDUM for NIT_27056	Phone: +91 431 257 7447 Fax : +91 431 252 0719 Email : agk@bheltry.co.in sibani@bheltry.co.in deeban@bheltry.co.in
--	---

	Reference Number: Enquiry 1201600010	Enquiry Date: 26.03.2016	Due date for submission of quotation: 24.05.2016
You are requested to quote the Enquiry number date and due date in all your correspondences. This is only a request for quotation and not an order			

CORRIGENDUM

Details of Corrigendum

In addition to the terms and conditions as published in the NIT_27056 are as follows.

The supply of the pipes shall be

1. As per SA312TP304H

OR

2. As per ASTM A 358 CLASS 1 (with radiography) with the following conditions.

a. While using 308H filler wire, it must be ensured that the Delta Ferrite is controlled limiting to within 3 - 8 FN.

b. Single welded pipe is preferred and the weld seam shall be marked for easy identification. "

All other terms and conditions as published in the NIT_ 27056 remain unaltered.

BHEL commercial terms & conditions with Price Bid formats and all annexure can be downloaded from BHEL web site <http://www.bhel.com> or from the Government tender website <http://tenders.gov.in> (public sector units) Bharat Heavy Electricals Limited) under enquiry reference "1201600010"

Tenders should reach us before 14:00 hours on the due date
Technical bid will be opened at 14:30 hours on the due date
Tenders would be opened in presence of the tenderers who have submitted their offers and who may like to be present.

Yours faithfully,
For **Bharat Heavy Electricals Limited**