

NTPC LIMITED

**2 X 800 MW GADARWARA STPP, STG
2 X 800 MW GADARWARA STPP, SG**

VOLUME -IIB

**TECHNICAL SPECIFICATION
FOR
MISCELLANEOUS PUMPS**

Specification No. : PE-TS-394/395-100-N001 (REV. 0)



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
PPEI BUILDING, SECTOR 16 A
NOIDA - 201301**



TECHNICAL SPECIFICATIONS

SPECIFICATION
NO.:

PE-TS-394/395-100-N001

MISCELLANEOUS PUMPS

REV. NO. 0

DATE: 04.07.14

INDEX

SECTION	TITLE
---------	-------

A	SCOPE OF ENQUIRY
---	------------------

B	PROJECT INFORMATION
---	---------------------

C	SPECIFIC TECHNICAL REQUIREMENTS FOR
---	-------------------------------------

C1	PUMPS
----	-------

C2	MOTORS
----	--------


D	STANDARD TECHNICAL SPECIFICATIONS FOR
---	---------------------------------------

D1	PUMPS
----	-------

- STANDARD TECHNICAL SPECIFICATIONS FOR HORIZONTAL PUMPS- NO. PE-TS-179-06
- DATA SHEETS-A FOR ABOVE PROJECT ALONGWITH LIST OF MANDATORY SPARES & WATER ANALYSIS.
- DATA SHEET - C
- STANDARD QUALITY PLAN FOR PUMPS


D2	MOTORS
----	--------

- STANDARD TECHNICAL SPECIFICATION FOR MOTORS
- DATA SHEET-A
- STANDARD QUALITY PLAN FOR MOTORS

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-394/395-100-N001	
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION: A
		REV. NO.	0	DATE: 04.07.14

SECTION A

SCOPE OF INQUIRY

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.: PE-TS-394/395-100-N001		
	MISCELLANEOUS PUMPS SCOPE OF ENQUIRY	VOLUME:	IIB	SECTION: A
		REV. NO.	0	DATE: 04.07.14

1.0 SCOPE

1.1 This enquiry covers the design, manufacture, assembly, inspection and testing at manufacturer's and/or his sub-contractors works, proper packing for delivery and installation checks and replacement of gland packing with Mechanical Seal arrangement (if applicable) at site for Miscellaneous Pumps along with mandatory spares complete with all accessories as per the requirements specified in this specification for following project.

i) 2 X 800 MW GADARWARA STPP, STG
ii) 2 X 800 MW GADARWARA STPP, SG

The bidder's scope shall also include any other services, etc. if called for in the succeeding sections of the specification.

1.2 The miscellaneous pumps covered under this specification shall be Horizontal pumps.

NOTE:-

a) **The bidder shall include complete supplies for the Project/Group as above in his scope. Part supplies offered for the Project/Group shall disqualify the bidder's offer for that Project/Group.**

b) **All pumps for above projects (Gadarwara TG & Gadawara SG) may be combined together for bid evaluation if stated in NIT.**

1.3 The pumps erected by the purchaser shall be checked by the bidder for correctness of their installation, alignment, etc. at site prior to their commissioning. Replacement of gland packing with Mechanical Seal (If applicable) as per Cl. No. 2.0 of Section C1 & Cl. No. 9.08.04 of section D of this volume. The charges for these shall be included by bidder in his base price, itself.

1.4 The miscellaneous pumps and drives covered under this specification for various projects are as per Annexure I. HT drives, wherever applicable and irrespective of motor ratings, shall be issued free of cost by BHEL. The details of pumps with HT drives shall be as per Annexure II.


The Capacity, Head, Materials of construction, Mandatory spares and other particulars of these pumps, are detailed in Data Sheet-A annexed with Section-D of the specification.


1.5 For detailed scope of supply & services refer clause 3.00.00 of Standard technical Specification for Horizontal Centrifugal pumps specified under Section-D of this volume.


1.6 Electrical scope between BHEL and Vendor for Miscellaneous pumps and drives of this specification shall be as per annexure I of section C-2 of this volume.

2.0 GENERAL TECHNICAL INSTRUCTIONS

2.1 It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship, and shall be capable of performing the required duties in a manner acceptable to Engineer/Owner who will interpret the meaning of drawings and specifications and shall be entitled to reject any component or material, which in his judgement is not in full accordance herewith.

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.: PE-TS-394/395-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION: A
	SCOPE OF ENQUIRY	REV. NO.	0	DATE: 04.07.14
<p>2.2 The omission of specific reference to any component/accessory necessary for the proper performance of Miscellaneous Pumps and drives shall not relieve the bidder of the responsibility of providing such facilities to complete the supply of equipment at quoted prices.</p> <p>2.3 BHEL's / Customer's representative shall be given full access to the shop in which the equipments are being manufactured or tested and all test records shall be made available to him.</p> <p>2.4 The equipments covered under this specification shall not be despatched unless the same have been finally inspected, accepted and shipping release issued by BHEL/Customer.</p> <p>2.5 <i>In case of any deviation from this technical specification (Vol.IIB) and General Technical Conditions (Vol.II A), the same shall be indicated in the schedule of deviations enclosed in Vol.III. In the absence of duly filled schedules it will be assumed that the bid strictly conforms to the specification.</i></p> <p>2.6 Unpriced copy of the price bid shall be furnished alongwith the technical bid.</p>				

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-394/395-100-N001		
	MISCELLANEOUS PUMPS SCOPE OF ENQUIRY	VOLUME:	IIB	SECTION:	A
		REV. NO.	0	DATE:	04.07.14
Annexure I					
List of Miscellaneous Pumps and drives for :					
A. 2 X 800 MW GADARWARA STPP, STG					
Sl. No.	Pump Description	Total Qty.	Type of Pumps		
	Horizontal Pumps (Group I)				
1	DMCW TG Aux's Pumps	6 nos.	Horizontal		
2	ACW Pumps	6 nos.	Horizontal		
3	ACW Additional Pumps	3 nos.	Horizontal		
B. 2 X 800 MW GADARWARA STPP. SG					
Sl. No.	Pump Description	Total Qty.	Type of Pumps		
	Horizontal Pumps (Group I)				
1	DMCW SG Aux's Pumps	4 nos.	Horizontal		


	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:		PE-TS-394/395-100-N001	
	MISCELLANEOUS PUMPS SCOPE OF ENQUIRY	VOLUME:	IIB	SECTION:	A
		REV. NO.	0	DATE:	04.07.14

Annexure II

Following HT drives for 2 X 800 MW GADARWARA STPP, irrespective of Motor ratings shall be issue free, by BHEL:


Horizontal Pumps (Group I)

- 1 DMCW TG Aux's Pumps

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-394/395-100-N001	
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION: B
		REV. NO.	0	DATE: 04.07.14

SECTION B


PROJECT INFORMATION

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-394/395-100-N001	
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION: B1
		REV. NO.	0	DATE: 04.07.14


SECTION B1

PROJECT INFORMATION

NTPC - 2 x 800 MW GADARWARA STPP, STAGE-1

CLAUSE NO.	PROJECT INFORMATION ANNEXURE-I		
<p data-bbox="295 324 383 358">1.00.00</p> <p data-bbox="295 380 383 414">1.01.00</p> <p data-bbox="295 571 383 604">1.02.00</p> <p data-bbox="295 761 383 795">1.03.00</p> <p data-bbox="295 952 383 985">1.04.00</p>	<p data-bbox="766 324 957 358" style="text-align: center;">INTRODUCTION</p> <p data-bbox="462 380 654 414">BACKGROUND</p> <p data-bbox="462 436 1452 548">Gadarwara Thermal Power Project (Gadarwara TPP) is being set up as a regional power project for the benefit of States/UTs of Western Region. This project is being set up in two stages. Each stage shall comprise of two units of 800 MW.</p> <p data-bbox="462 571 622 604">Location and</p> <p data-bbox="462 638 1452 817">The site is located near villages Gangai & Umaraiya (about 9 Kms from Gadarwara town in Narsingpur district of Madhya Pradesh. The major cities Bhopal & Jabalpur are located at about 210 Kms & about 140 kms respectively from proposed project site. The nearest BG Railway Station, Gadarwara, on Jabalpur- Itarsi Section on central railway main Line is about 9 Kms from proposed project site.</p> <p data-bbox="462 840 1452 952">The nearest commercial airport, Bhopal and Jabalpur are located about 240 Kms and about 155 Kms respectively from site. The plant latitude and longitude are 22° 51' 42" N and 78° 52' 08" respectively.</p> <p data-bbox="462 974 1197 1008">Vicinity plan of the proposed project is placed at Annexure –A-I</p> <p data-bbox="462 1041 526 1075">Land</p> <p data-bbox="462 1108 1452 1220">About 1844 acres of land (Private Land- about 1480 acres and Govt. Land- about 364 acres) has been envisaged for the project. In-principle land availability clearance has been obtained from Govt. of Madhya Pradesh vide letter dated 19.05.08.</p> <p data-bbox="462 1243 542 1276">Water</p> <p data-bbox="462 1310 1452 1444">The make-up water requirement is estimated as 4680 Cubic Meter/Hr with ash circulation system and about 5980 Cubic Meter/Hr with once through ash water system. The source of water for the Project is Narmada River at a distance of about 30 Kms from the project site.</p> <p data-bbox="462 1467 1452 1579">Govt. of Madhya Pradesh vide dated 19.05.08. has accorded water commitment from Narmada river for the project. CWC vide letter dated 27.07.12 have concurred water availability confirmation accorded by State Govt.</p> <p data-bbox="462 1601 574 1635">Capacity</p> <p data-bbox="686 1668 1101 1702" style="text-align: center;">2 x 800 MW - Present proposal</p> <p data-bbox="686 1736 1005 1769" style="text-align: center;">2 x 800 MW - In Future</p>		
<p data-bbox="303 1859 702 1915">GADARWARA SUPER THERMAL POWER PROJECT (2X800 MW)</p> <p data-bbox="351 1915 686 1948">STEAM TURBINE GENERATOR PACKAGE</p>	<p data-bbox="782 1859 1005 1892">TECHNICAL SPECIFICATION</p> <p data-bbox="845 1892 941 1915">SECTION-VI</p> <p data-bbox="861 1915 925 1948">PART-A</p>	<p data-bbox="1085 1870 1276 1904">PROJECT INFORMATION</p>	<p data-bbox="1356 1870 1404 1892">PAGE</p> <p data-bbox="1356 1904 1404 1926">1 OF 3</p>



CLAUSE NO.	PROJECT INFORMATION		ANNEXURE-I
1.05.00	Meteorological data Important meteorological data from nearest observatory at Narsinghpur is placed at Annexure-A-II .		
1.06.00	Plant Water Scheme The Plant water scheme is described below.		
1.06.01	Condenser Cooling (CW) Water System It is proposed to provide recirculating type CW system with induced draft type cooling towers. For the recirculating type CW system it is proposed to supply clarified water as make up. Raw water from the make-up water pump house shall be pumped to a Water Pretreatment Plant (PT - CW system). The treated clarified water shall be led to the cold water channel of CW system. Designed Clarified Water Analysis is given in this subsection. CW system shall be operated at a C.O.C of about 4.0. Chemical treatment programme (using acid dosing and scale cum corrosion inhibitors dosing) may be employed in addition to blow down of CW water to control the CW system chemistry in case CW system is required to be operated beyond 4.0 COC. CW blow down shall be drawn from the discharge of CW pumps and the same shall be led to a Service water Tank. For carrying circulating water from CW pump house to TG-area and from TG area to cooling tower, steel lined concrete encased duct would be provided. For interconnecting CW duct with CW pump, condenser and cooling towers, steel pipes would be used. Cooled water from cooling tower will be led to CW pump house through the cold water channel by gravity.		
1.06.02	Equipment Cooling Water (ECW) System (Unit Auxiliaries) The plant auxiliaries of Steam Generator and Turbine Generator shall be cooled by Demineralised (DM) water in a closed circuit. The primary circuit DM water shall be cooled through plate type heat exchangers by Circulating Water tapped from CW system in a closed secondary circuit. The hot secondary circuit cooling water shall be cooled in the cooling towers and shall be returned back to the system. It is proposed to provide independent primary cooling water circuit for Steam Generator & auxiliaries and TG & its auxiliaries.		
1.06.03	Station Auxiliaries Cooling Water System The station auxiliaries such as Air compressors, Compressors of ash handling plant, Cooling water circuit of Air Conditioning system, compressor of mill reject system etc. shall be cooled by separate cooling water System using separate set of pumps and cooling towers.		
GADARWARA SUPER THERMAL POWER PROJECT (2X800 MW) STEAM TURBINE GENERATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI PART-A	PROJECT INFORMATION	PAGE 2 OF 9

2

CLAUSE NO.

PROJECT INFORMATION

ANNEXURE-I



ANNEXURE - A-III

**ANALYSIS OF DM WATER TO BE USED FOR
MAKE-UP WATER TO CONDENSER**

Sl.No.	Characteristics	Value
1.	Silica (Max.)	0.01 ppm as SiO ₂
2.	Iron as Fe	Nil
3.	Total hardness	Nil
4.	pH value	6.8 -7.3
5.	Conductivity	Not more than 0.1micro mho/cm excluding the effects of free CO ₂

CLAUSE NO.

PROJECT INFORMATION

ANNEXURE-I



ANNEXURE-A-III

DESIGN CLARIFIED WATER ANALYSIS

Sl. No.	Constituent	as	mg per litre
1.	Calcium	CaCO ₃	102
2.	Magnesium	CaCO ₃	41
3.	Sodium	CaCO ₃	35
4.	Potassium	CaCO ₃	3
5.	Total Alkalinity	CaCO ₃	113
6.	P-Alkalinity	CaCO ₃	Nil
7.	Chloride	CaCO ₃	43
8.	Sulphate	CaCO ₃	25
9.	Silica (Reactive)	SiO ₂	16
10.	Iron	Fe	0.3 mg/l
11.	pH Value	-	6.8 - 8.5
12.	Turbidity	NTU	10


Note- Clarified water shall be used as make up water for cooling water system.

GADARWARA SUPER THERMAL POWER PROJECT
(2X800 MW)
STEAM TURBINE GENERATOR PACKAGE

TECHNICAL SPECIFICATION
SECTION-VI
PART-A

PROJECT INFORMATION


PAGE
8 OF 9

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-394/395-100-N001	
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION: C
		REV. NO.	0	DATE: 04.07.14

SECTION C


SPECIFIC TECHNICAL REQUIREMENTS


- C1: SPECIFIC TECHNICAL REQUIREMENTS FOR PUMPS**
- C2: SPECIFIC TECHNICAL REQUIREMENTS FOR MOTORS**

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-394/395-100-N001	
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION: C1
		REV. NO.	0	DATE: 04.07.14

SECTION C1

SPECIFIC TECHNICAL REQUIREMENTS FOR PUMPS

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-394/395-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	C1
		REV. NO.	0	DATE:	04.07.14
<p>1.0 SPECIFIC TECHNICAL REQUIREMENTS:</p> <p><u>DELIVERY:</u> Delivery of miscellaneous pumps shall be as per NIT requirement.</p> <p>2.0 <u>Horizontal Pumps:</u></p> <p>2.1 Horizontal Pumps with Mechanical seal shall be supplied with gland packing arrangement to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be despatched alongwith main supply for this purpose. Shaft sleeve and any other item required for satisfactory operation of Mechanical seal after replacement at site shall be provided by the pump supplier without any cost implication to BHEL.</p>					

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-394/395-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	C2
		REV. NO.	0	DATE:	04.07.14

SECTION C2

SPECIFIC TECHNICAL REQUIREMENTS FOR MOTORS



**ELECTRICAL EQUIPMENT SPECIFICATION
FOR
MISC. PUMP**

2X800MW GADARWARA TPP

SPECIFICATION NO.


VOLUME NO. : II-B

SECTION : C

REV NO. : 00 DATE : 30.06.14

SHEET : 1 OF 3

**TECHNICAL SPECIFICATION
FOR
MISC. PUMP
(ELECTRICAL PORTION)**

	ELECTRICAL EQUIPMENT SPECIFICATION FOR MISC. PUMP 2X800MW GADARWARA TPP	SPECIFICATION NO.
		VOLUME NO. : II-B
		SECTION : C
		REV NO. : 00 DATE : 30.06.14
		SHEET : 2 OF 3

1.0 EQUIPMENT & SERVICES TO BE PROVIDED BY BIDDER:

- a) Services and equipment as per "Electrical Scope between BHEL and Vendor".
- b) Any item/work either supply of equipment or erection material which have not been specifically mentioned but are necessary to complete the work for trouble free and efficient operation of the plant shall be deemed to be included within the scope of this specification. The same shall be provided by the bidder without any extra charge.
- c) Supply of mandatory spares as specified in the specifications of mechanical equipments.
- d) Erection and Commissioning spares.
- e) Erection & Maintenance tools & tackles.
- f) Electrical load requirement for mill reject system.
- g) All equipment shall be suitable for the power supply fault levels and other climatic conditions mentioned in the enclosed project information.
- h) Bidder to furnish list of makes for each equipment at contract stage, which shall be subject to customer /BHEL approval without any commercial and delivery implications to BHEL
- i) Various drawings, data sheets as per required format, Quality plans, calculations, test reports, test certificates, operation and maintenance manuals etc shall be furnished as specified at contract stage. All documents shall be subject to customer/BHEL approval without any commercial implication to BHEL.
- j) Motor shall meet minimum requirement of motor specification.
- k) LT power & control cables shall meet minimum requirement of LT power & control cables specification.
- l) Cabling, earthing & lightning protection shall meet minimum requirement of cabling, earthing & lightning protection specification.

2.0 EQUIPMENT & SERVICES TO BE PROVIDED BY PURCHASER FOR ELECTRICAL & TERMINAL POINTS:

Refer "Electrical Scope between BHEL and Vendor".

3.0 DOCUMENTS TO BE SUBMITTED ALONG WITH BID

3.1 Bidder shall confirm total compliance to the electrical specification without any deviation from the technical/quality assurance requirements stipulated. In line with this two signed and stamped copies of the following shall be furnished by the bidder as technical offer:

- a) A copy of this sheet "Electrical equipment Specification for Sump Pump" and sheet "Electrical Scope between BHEL and Vendor" with bidder's signature and company stamp.
- b) List of Erection and Commissioning spares.
- c) List of Erection & Maintenance tools & tackles.
- d) Electrical load requirement

3.2 No technical submittal such as copies of data sheets, drawings, write-up, quality plans, type test certificates, technical literature, etc, is required during tender stage. Any such submission even if made, shall not be considered as part of offer.



**ELECTRICAL EQUIPMENT SPECIFICATION
FOR
MISC. PUMP
2X800MW GADARWARA TPP**

SPECIFICATION NO.
VOLUME NO. : II-B
SECTION : C
REV NO. : 00 DATE : 30.06.14
SHEET : 3 OF 3

4.0 List of enclosures :

- a) Electrical scope between NTPC/BHEL & vendor.
- b) Technical specification, datasheets & quality plans for 415V Electric motors.
- c) Technical Specification, datasheets & quality plans for LT power & control cables.
- d) Technical Specification, datasheets & quality plans for cabling, earthing & lightning protection.
- e) Electrical Load data format.

ANNEXURE – I TO SECTION – C : STANDARD ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR
PACKAGE : MISC. PUMP

PROJECT:

<u>S.NO</u>	<u>DETAILS</u>	<u>SCOPE SUPPLY</u>	<u>SCOPE E&C</u>	<u>REMARKS</u>
1	415 V DOL STARTER CUM CONTROL PANEL(SCCP) (Switchgear starter panel)	NTPC/ BHEL site	NTPC/ BHEL site	1. NTPC will provide two suitable Power supply feeders to incoming terminal point of SCCP. Termination of input from NTPC switchgear is in vendor scope. 2. Interposing relays (RE 302 of Jyoti make or equivalent), if required for PLC and microprocessor based systems, shall be provided by Vendor in Starter cum control panel. Located near the motors.
2	Local Push Button Station (for motors)	NTPC/ BHEL site	NTPC/ BHEL site	
3	Power cables, control cables and screened control cables for a) both end equipment in vendor's scope b) one end equipment in vendor's scope & another end in NTPC/BHEL (in case of C & I cables of DCS)	Vendor NTPC/ BHEL	NTPC/ BHEL site NTPC/ BHEL site	1. Incoming cable to SCCP from NTPC supplied MCC will be informed by NTPC. Screened control cable between DCS & field equipment will be informed by NTPC. Vendor shall provide lugs & glands accordingly. 2. Termination at Vendor equipment terminals by Vendor.
4	Any special type of cable like compensating, co-axial, prefab, MICC, fibre optical etc	Vendor	NTPC/ BHEL site	
5	Cable trays, accessories & cable trays supporting system	NTPC (Main tray) BHEL (Branch Tray)	NTPC/ BHEL site	NTPC will supply and erect the cable trays and its supporting structure in the Main cable routes both for their & vendor's cable. Vendor shall provide tray and support arrangements for his cables in the branch routes (i.e. route to each eqp. instruments, JB's, etc from the nearest main route).
6	Cable glands and lugs for equipments supplied by Vendor	Vendor	NTPC/ BHEL site	1. Tinned brass, double compression cable glands. 2. Solder less crimping type heavy duty tinned copper lugs for power cables 3. Solder less crimping type heavy duty copper lugs for control cables.
7	Conduit and conduit accessories for cabling between equipments supplied by vendor	Vendor	NTPC/ BHEL site	Conduits shall be medium duty, hot dip galvanised cold rolled mild steel rigid conduit as per IS: 9537. Makes of conduits shall be subject to NTPC/ BHEL approval at contract stage.
8	Lighting	NTPC	NTPC	
9	Equipment grounding & lightning protection	NTPC	NTPC	
10	Below grade grounding	NTPC	NTPC	
11	LT Motors with base plate and foundation hardware	Vendor	Vendor	Makes shall be subject to NTPC/ BHEL approval at contract stage.
12	Mandatory spares	Vendor	-	Vendor to quote as per specification.
13	Recommended O & M spares, E & C spares, erection & maintenance tools & tackle	Vendor	-	As per specification

**ANNEXURE – I TO SECTION – C : STANDARD ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR
PACKAGE : MISC. PUMP**

14	Any other equipment/material/service required for completeness of system but not specified above (to ensure trouble free and efficient operation of the system).	Vendor	NTPC/ BHEL site	
15	a) Input cable schedules (C & I) b) Cable interconnection detail for the above c) Cable block diagram	Vendor Vendor Vendor	- - -	Cable listing for control cables for vendor supplied equipment (soft copies in the CUSTOMER cable schedule format) shall be furnished during detail engineering by vendor.
16	Equipment layout drawings	Vendor	-	For ensuring cabling requirements are met, vendor shall furnish layout drawings (both in print form as well as in AUTOCAD) of the complete plant (including electrical area) indicating location and identification of all equipments requiring cabling, and shall incorporate cable routing details marked on the drawing as per CUSTOMER interface comments. Electrical equipment layout drawing shall be to CUSTOMER approval.
17	Electrical equipment GA drawing	Vendor	-	For necessary interface review.

NOTES:

1. Make of all electrical equipments/items supplied shall be reputed make & shall be subject to approval of BHEL/NTPC after award of contract.
2. All QPs shall be subject to approval of BHEL/NTPC after award of contract without any commercial implication.
3. For skid mounted system, 2 nos. (1W+1S) supply of 415 V, 3 phase, 3 wire AC shall be provided by CUSTOMER. Complete skid including changeover between feeder/starters/LCP/inter-locks/protection devices / any other supply etc. shall be in bidder's scope only.



TITLE

LV MOTORS**DATA SHEET-A**

SPECIFICATION NO.

VOLUME IIB

SECTION D

REV NO. DATE

SHEET 1 OF 1

- 1.0 Design ambient temperature : 50 °C
- 2.0 Maximum acceptable kW rating of LV motor : 200 KW
- 3.0 Installation (Indoors/ Outdoors) : As required
- 4.0 Details of supply system
- a) Rated voltage (with variation) : 415V ± 10%, 11/3.3kV ± 6%,
 - b) Rated frequency (with variation) : 50 Hz ± 5%
 - c) Combined voltage & freq. variation : 10% (sum of absolute values)
 - d) System fault level at rated voltage : 40 kA for 1 sec for 11kV & 3.3kV
45 kA for 1 sec for 415V system
 - e) LV System grounding : Solidly
- 5.0 Class of insulation : Class 'F', with temp rise limited to Class B.
- 6.0 Minimum voltage for starting (As percentage of rated voltage) : 80% of rated voltage
- 7.0 Power cables data : Details attached
- 8.0 Earth Conductor Size & Material : Details attached
- 9.0 Space heater supply : 240 V, 1 ϕ , 50 Hz
- 10.0 Rating up to which Single phase motor : Acceptable below 0.2 kW
- 11.0 Locked rotor current
- a) Limit as percentage of FLC : Details as per spec attached
 - b) Permissible tolerance, if any : ±20%
- 12.0 Energy Efficient Motors : Details as per spec attached
- 13.0 Additional tests : As per QP
- 14.0 Flame-proof motor
- a) Enclosure suitable (As per IS:2148) : As per requirement
 - b) Classification of Hazardous area (As per IS: 5572 part-I) : As per requirement
- 15.0 Makes : ABB/ Bharat Bijlee/ CGL / KEC/ NGEF/Siemens/ALSTOM (SUBJECT TO CUSTOMER APPROVAL DURING DETAILED ENGG)

Note: **Motor name plate rating at 50°C shall have at least 10% margin over input power requirement at rated duty point unless otherwise stated in driven equipment specification**



B - 2

MOTORS

LARA SUPER THERMAL POWER PROJECT, STAGE-I (2X800 MW)
DARLIPALI SUPER THERMAL POWER PROJECT, STAGE-I (2X800 MW)
GAJMARA SUPER THERMAL POWER PROJECT, STAGE-I (2X800 MW)
KUDGI SUPER THERMAL POWER PROJECT, STAGE-I (3X800 MW)
STEAM TURBINE GENERATOR PACKAGE

TECHNICAL SPECIFICATION
SECTION-VI
PART-B


185

288

~~287~~


[Handwritten mark]

[Handwritten mark]


CLAUSE NO.	TECHNICAL REQUIREMENTS									
MOTORS										
1.00.00	GENERAL REQUIREMENTS									
1.01.00	For the purpose of design of equipment/systems, an ambient temperature of 50 deg. Centigrade and relative humidity of 95% (at 40 deg C) shall be considered. The equipment shall operate in a highly polluted environment.									
1.02.00	All equipments shall be suitable for rated frequency of 50 Hz with a variation of +3% & -5%, and 10% combined variation of voltage and frequency unless specifically brought out in the specification.									
1.03.00	Contractor shall provide fully compatible electrical system, equipments, accessories and services.									
1.04.00	All the equipment, material and systems shall, in general, conform to the latest edition of relevant National and international Codes & Standards, especially the Indian Statutory Regulations.									
1.05.00	<p>The auxiliary AC voltage supply arrangement shall have 11kV, 3.3 kV and 415V systems and DC voltage shall be 220 V. It shall be designed to limit voltage variations as given below under worst operating condition :</p> <table border="0" data-bbox="414 1086 1268 1265"> <tr> <td>(a) 11kV, 3.3 kV</td> <td>+/- 6%</td> </tr> <tr> <td>(b) 415/240V</td> <td>+/- 10%</td> </tr> <tr> <td>(c) 220 V DC</td> <td>-15% to +10%. However the nominal continuous DC power supply shall be 242V.</td> </tr> </table>		(a) 11kV, 3.3 kV	+/- 6%	(b) 415/240V	+/- 10%	(c) 220 V DC	-15% to +10%. However the nominal continuous DC power supply shall be 242V.		
(a) 11kV, 3.3 kV	+/- 6%									
(b) 415/240V	+/- 10%									
(c) 220 V DC	-15% to +10%. However the nominal continuous DC power supply shall be 242V.									
1.06.00	<p>The voltage level for motors shall be as follows :-</p> <table border="0" data-bbox="414 1332 1268 1534"> <tr> <td>a) Upto 0.2KW</td> <td>: Single phase 240V AC / 3 phase 415V AC</td> </tr> <tr> <td>b) Above 0.2KW and upto 200KW</td> <td>: 3 phase 415V AC — S no 116</td> </tr> <tr> <td>c) Above 200KW and upto 1500 KW</td> <td>: 3.3 kV</td> </tr> <tr> <td>d) Above 1500 KW</td> <td>: 11 kV</td> </tr> </table>		a) Upto 0.2KW	: Single phase 240V AC / 3 phase 415V AC	b) Above 0.2KW and upto 200KW	: 3 phase 415V AC — S no 116	c) Above 200KW and upto 1500 KW	: 3.3 kV	d) Above 1500 KW	: 11 kV
a) Upto 0.2KW	: Single phase 240V AC / 3 phase 415V AC									
b) Above 0.2KW and upto 200KW	: 3 phase 415V AC — S no 116									
c) Above 200KW and upto 1500 KW	: 3.3 kV									
d) Above 1500 KW	: 11 kV									
1.07.00	Fault level shall be limited to 40kA RMS for 1 second for 11kV & 3.3 kV system and 45 kA RMS 1 second for 415V system. 415V system shall be solidly grounded and 220 VDC system shall be isolated type.									
1.08.00	Paint shade shall be as per RAL 5012 (Blue) for indoor and outdoor equipment.									
1.09.00	The responsibility of coordination with electrical agencies and obtaining all necessary clearances shall be of the contractor. — S. no - 117 / Coord / 14									
LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-2 MOTORS								
PAGE 1 OF 10										

Handwritten marks and scribbles

CLAUSE NO.	TECHNICAL REQUIREMENTS	एनटीपीसी NTPC
1.10.00	<p>Degree of Protection</p> <p>Degree of protection for various enclosures as per IS:4691, IEC60034-05 shall be as follows :-</p> <p>i) Indoor motors - IP 54</p> <p>ii) Outdoor motors - IP 55</p> <p>iii) Cable box-indoor area - IP 54</p> <p>iv) Cable box-Outdoor area - IP 55</p>	
2.00.00	<p>CODES AND STANDARDS</p> <p>1) Three phase induction motors : IS:325, IEC:60034</p> <p>2) Single phase AC motors : IS:996, IEC:60034</p> <p>3) Crane duty motors : IS:3177, IEC:60034</p> <p>4) DC motors/generators : IS:4722</p> <p>5) Energy Efficient motors : IS 12615, IEC:60034-30</p>	
3.00.00	<p>TYPE</p>	
3.01.00	<p>AC Motors:</p> <p>a) Squirrel cage induction motor suitable for direct-on-line starting.</p> <p>b) Continuous duty LT motors upto 160 KW Output rating (at 50 deg.C ambient temperature), shall be Energy Efficient motors, Efficiency class-Eff 1, conforming to IS 12615, or High efficiency (IE2) as per IEC:60034-30.</p> <p>c) Crane duty motors shall be slip ring/ squirrel cage Induction motor as per the requirement.</p>	
3.02.00	<p>DC Motors Shunt wound.</p>	
4.00.00	<p>RATING</p> <p>(a) Continuously rated (S1). However, crane motors shall be rated for S4 duty, 40% cyclic duration factor.</p> <p>(b) Whenever the basis for motor ratings are not specified in the corresponding mechanical specification sub-sections, maximum continuous motor ratings shall be at least 10% above the maximum load demand of the driven</p>	
<p>LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION-VI PART-B</p>	<p>SUB-SECTION-B-2 MOTORS</p> <p>PAGE 2 OF 10</p>

CLAUSE NO.	TECHNICAL REQUIREMENTS	
	<p>equipment under entire operating range including voltage and frequency variations.</p> <p>(c) For BFP motors starting MVA shall be restricted to 80 MVA.</p>	
5.00.00	<p>TEMPERATURE RISE</p> <p>Air cooled motors</p> <p>70 deg. C by resistance method for both thermal class 130(B) & 155(F) insulation.</p> <p>Water cooled</p> <p>80 deg. C over inlet cooling water temperature mentioned elsewhere, by resistance method for both thermal class 130(B) & 155(F) insulation.</p>	<p>S.w-118 Amndt-4 dt. 25/81</p>
6.00.00	<p>OPERATIONAL REQUIREMENTS</p>	
6.01.00	<p>Starting Time</p>	
6.01.01	<p>For motors with starting time upto 20 secs. at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be at least 2.5 secs. more than starting time.</p>	
6.01.02	<p>For motors with starting time more than 20 secs. and upto 45 secs. at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be at least 5 secs. more than starting time.</p>	
6.01.03	<p>For motors with starting time more than 45 secs. at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be more than starting time by at least 10% of the starting time.</p>	
6.01.04	<p>Speed switches mounted on the motor shaft shall be provided in cases where above requirements are not met.</p>	
6.02.00	<p>Torque Requirements</p>	
6.02.01	<p>Accelerating torque at any speed with the lowest permissible starting voltage shall be at least 10% motor full load torque.</p>	
6.02.02	<p>Pull out torque at rated voltage shall not be less than 205% of full load torque. It shall be 275% for crane duty motors.</p>	
6.03.00	<p>Starting voltage requirement</p> <p>(a) 85% below 110 KW</p> <p>(b) 80% from 110 KW to 200 KW</p>	
<p>LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJMARIA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION-VI PART-B</p>	<p>SUB-SECTION-B-2 MOTORS</p>
<p>PAGE 3 OF 10</p>	<p>Y</p>	<p>291</p>

CLAUSE NO.	TECHNICAL REQUIREMENTS	एन.टी.पी.सी. NTPC	
	(c) 85% above 200 KW to 1000 KW (d) 80% from 1001 KW to 4000 KW (e) 75% above 4000KW Except AOP & JOP motors running on D.G emergency supply, starting voltage shall be 80%.		
7.00.00	DESIGN AND CONSTRUCTIONAL FEATURES		
7.01.00	Suitable single phase space heaters shall be provided on motors rated 30KW and above to maintain windings in dry condition when motor is standstill. Separate terminal box for space heaters & RTDs shall be provided. However for flame proof motors, space heater terminals inside the main terminal box may be acceptable.		
7.02.00	All motors shall be either Totally enclosed fan cooled (TEFC) or totally enclosed tube ventilated (TETV) or Closed air circuit air cooled (CACW) type. However, motors rated 3000KW or above can be Closed air circuit water cooled (CACW). CW motors can be screen protected drip proof (SPDP) type. Motors and EPB located in hazardous areas shall have flame proof enclosures conforming to IS:2148 as detailed below (a) Fuel oil area : Group - IIB (b) Hydrogen generation : Group - IIC (or Group-I, Div-II as per plant area NEC) or (Class-1, Group-B, Div-II as per NEMA IEC60034)		
7.03.00	Winding and Insulation (a) Type : Non-hygroscopic, oil resistant, flame resistant (b) Starting duty : Two hot starts in succession, with motor initially at normal running temperature. (c) 11kV & 3.3 kV AC motors : Thermal class 155 (F) insulation. The winding insulation process shall be total Vacuum Pressure Impregnated i.e resin poor method. The lightning Impulse & interturn insulation surge withstand level shall be as per IEC-60034 part-15 (d) 240VAC, 415V AC & 220V DC motors : Thermal Class (B) or better		
7.04.00	Motors rated above 1000KW shall have insulated bearings to prevent flow of shaft currents.		
LARA STPP, STAGE-I (2X800 MW) DARJUPALI STPP, STAGE-I (2X800 MW) GAJMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-2 MOTORS	PAGE 4 OF 10


CLAUSE NO.	TECHNICAL REQUIREMENTS		
7.05.00	Motors with heat exchangers shall have dial type thermometer with adjustable alarm contacts to indicate inlet and outlet primary air temperature.		
7.06.00	Noise level for all the motors shall be limited to 85dB(A) except for BFP motor for which the maximum limit shall be 90dB(A). Vibration shall be limited within the limits prescribed in IS:12075 / IEC 60034-14 . Motors shall withstand vibrations produced by driven equipment. HT motor bearing housings shall have flat surfaces, in both X and Y directions, suitable for mounting 80mmX80mm vibration pads.		
7.07.00	In HT motors, at least four numbers simplex / two numbers duplex platinum resistance type temperature detectors shall be provided in each phase stator winding. Each bearing of HT motor shall be provided with dial type thermometer with adjustable alarm contact and preferably 2 numbers duplex platinum resistance type temperature detectors.		
7.08.00	Motor body shall have two earthing points on opposite sides.		
7.09.00	HT motors can be offered with either elastimould termination or dust tight phase separated double walled (metallic as well as insulated barrier) cable boxes. In case elastimould terminations are offered, then protective cover and trifurcating sleeves shall also be provided. In case cable box is offered, then Employer shall provide termination kit. Removable gland plates of thickness 3 mm (hot/cold rolled sheet steel) or 4 mm (non magnetic material for single core cables) shall be provided in case of cable boxes.		
7.10.00	The spacing between gland plate & centre of terminal stud shall be as per Table-I.		
7.11.00	All motors shall be so designed that maximum inrush currents and locked rotor and pullout torque developed by them at extreme voltage and frequency variations do not endanger the motor and driven equipment.		
7.12.00	The motors shall be suitable for bus transfer schemes provided on the 11kV, 3.3 kV /415V systems without any injurious effect on its life.		
7.13.00	For motors rated 2000 KW & above, neutral current transformers of PS class shall be provided on each phase in a separate neutral terminal box.		
7.14.00	11kV and 3.3 kV motor Terminal Box shall be suitable for fault level of 750MVA for 0.12 sec and 250 MVA for 0.12 sec respectively. Elastimould termination kit shall be suitable for fault level of 25 KA for 0.17 seconds.		
7.15.00	The size and number of cables (for HT and LT motors) to be intimated to the successful bidder during detailed engineering and the contractor shall provide terminal box suitable for the same.		
8.00.00	The ratio of locked rotor KVA at rated voltage to rated KW shall not exceed the following (without any further tolerance) except for BFP motor.		
LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-2 MOTORS	PAGE 5 OF 10


293

202

2

2

CLAUSE NO.	TECHNICAL REQUIREMENTS		
	(a) Below 110KW : 10.0 (b) From 110 KW & upto 200 KW : 9.0 (c) Above 200 KW & upto 1000KW : 10.0 (d) From 1001KW & upto 4000KW : 9.0 (e) Above 4000KW : 6 to 6.5		
10.00.00	TYPE TEST		
10.01.00	HT MOTORS		
10.01.01	<p>The contractor shall carry out the type tests as listed in this specification on the equipment to be supplied under this contract. The bidder shall indicate the charges for each of these type tests separately in the relevant schedule of Section - VII-(BPS) and the same shall be considered for the evaluation of the bids. The type tests charges shall be paid only for the test(s) actually conducted successfully under this contract and upon certification by the employer's engineer.</p>		
10.01.02	<p>The type tests shall be carried out in presence of the employer's representative, for which minimum 15 days notice shall be given by the contractor. The contractor shall obtain the employer's approval for the type test procedure before conducting the type test. The type test procedure shall clearly specify the test set-up, instruments to be used, procedure, acceptance norms, recording of different parameters, interval of recording, precautions to be taken etc. for the type test(s) to be carried out.</p>		
10.01.03	<p>In case the contractor has conducted such specified type test(s) within last ten years as on the date of bid opening, he may submit during detailed engineering the type test reports to the owner for waiver of conductance of such test(s). These reports should be for the tests conducted on the equipment similar to those proposed to be supplied under this contract and test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client. The owner reserves the right to waive conducting of any or all the specified type test(s) under this contract. In case type tests are waived, the type test charges shall not be payable to the contractor.</p>		
10.01.04	<p>Further the Contractor shall only submit the reports of the type tests as listed in "LIST OF TESTS FOR WHICH REPORTS HAVE TO BE SUBMITTED" and carried out within last ten years from the date of bid opening. These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client. However if the</p>		
LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-2 MOTORS	PAGE 6 OF 10

CLAUSE NO.	TECHNICAL REQUIREMENTS 		
10.01.05	<p>contractor is not able to submit report of the type test(s) conducted within last ten years from the date of bid opening, or in the case of type test report(s) are not found to be meeting the specification requirements, the contractor shall conduct all such tests under this contract at no additional cost to the owner either at third party lab or in presence of client/owners representative and submit the reports for approval.</p> <p>LIST OF TYPE TESTS TO BE CONDUCTED</p> <p>The following type tests shall be conducted on each type and rating of HT motor</p> <ul style="list-style-type: none"> (a) No load saturation and loss curves upto approximately 115% of rated voltage (b) Measurement of noise at no load. (c) Momentary excess torque test (subject to test bed constraint). (d) Full load test(subject to test bed constraint) (e) Temperature rise test at rated conditions. During heat run test, bearing temp., winding temp.,coolant flow and its temp. shall also be measured. In case the temperature rise test is carried at load other than rated load, specific approval for the test method and procedure is required to be obtained. Wherever ETD's are provided, the temperature shall be measured by ETD's also for the record purpose. (f) Lightning Impulse withstand test on the sample coil shall be as per clause no. 4.3 IEC-60034, part-15 (g) Surge-withstand test on interturn insulation shall be as per clause no. 4.2 of IEC 60034, part-15 		
10.01.06	<p>LIST OF TESTS FOR WHICH REPORTS HAVE TO BE SUBMITTED</p> <p>The following type test reports shall be submitted for each type and rating of HT motor</p> <ul style="list-style-type: none"> (a) Degree of protection test for the enclosure followed by IR, HV and no load run test. (b) Terminal box-fault level withstand test for each type of terminal box of HT motors only. 		
10.02.00	<p>LT Motors</p>		
10.02.01	<p>LT Motors supplied shall be of type tested design. During detailed engineering, the contractor shall submit for Owner's approval the reports of all the type tests as listed in this specification and carried out within last <i>ten</i> years from the date of bid opening.</p>		
LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-2 MOTORS	PAGE 7 OF 10


APS


295

300

[Handwritten mark]

[Handwritten mark]

CLAUSE NO.	TECHNICAL REQUIREMENTS			
10.02.02	<p>These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client.</p> <p>However if the contractor is not able to submit report of the type test(s) conducted within last ten years from the date of bid opening, or in the case of type test report(s) are not found to be meeting the specification requirements, the contractor shall conduct all such tests under this contract at no additional cost to the owner either at third party lab or in presence of client/owners representative and submit the reports for approval.</p>			
10.02.03	<p>LIST OF TESTS FOR WHICH REPORTS HAVE TO BE SUBMITTED</p> <p>The following type test reports shall be submitted for each type and rating of LT motor of above 50 KW only</p> <ol style="list-style-type: none"> 1. Measurement of resistance of windings of stator and wound rotor. 2. No load test at rated voltage to determine input current power and speed 3. Open circuit voltage ratio of wound rotor motors (in case of Slip ring motors) 4. Full load test to determine efficiency power factor and slip . 5. Temperature rise test . 6. Momentary excess torque test. 7. High voltage test . 8. Test for vibration severity of motor. 9. Test for noise levels of motor(Shall be limited as per clause no 7.06.00 of this section) 10. Test for degree of protection and 11. Overspeed test. 12. Type test reports for motors located in fuel oil area having flame proof enclosures as per IS 2148 / IEC 60079-1 			
10.03.00	<p>All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price.</p>			
<p>LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE</p>		<p>TECHNICAL SPECIFICATION SECTION-VI PART-B</p>	<p>SUB-SECTION-B-2 MOTORS</p>	<p>PAGE 8 OF 10</p>

CLAUSE NO.	TECHNICAL REQUIREMENTS			
10.04.00	<p>The type test reports once approved for any projects shall be treated as reference. For subsequent projects of NTPC, an endorsement sheet will be furnished by the manufacturer confirming similarity and "No design Change". Minor changes if any shall be highlighted on the endorsement sheet.</p>			
LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJWARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE		TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-2 MOTORS	PAGE 9 OF 10


288

297

~~290~~

R

R

CLAUSE NO.	TECHNICAL REQUIREMENTS																												
	<div style="text-align: right; margin-bottom: 10px;"></div> <p style="text-align: center;">TABLE - I</p> <p style="text-align: center;">DIMENSIONS OF TERMINAL BOXES FOR LV MOTORS</p> <table border="0" style="width: 100%;"> <tr> <td style="width: 60%;">Motor MCR in KW</td> <td style="text-align: right;">Minimum distance between centre of stud and gland plate in mm</td> </tr> <tr> <td>UP to 3 KW</td> <td style="text-align: right;">As per manufacturer's practice.</td> </tr> <tr> <td>Above 3 KW - upto 7 KW</td> <td style="text-align: right;">85</td> </tr> <tr> <td>Above 7 KW - upto 13 KW</td> <td style="text-align: right;">115</td> </tr> <tr> <td>Above 13 KW - upto 24 KW</td> <td style="text-align: right;">167</td> </tr> <tr> <td>Above 24 KW - upto 37 KW</td> <td style="text-align: right;">196</td> </tr> <tr> <td>Above 37 KW - upto 55 KW</td> <td style="text-align: right;">249</td> </tr> <tr> <td>Above 55 KW - upto 90 KW</td> <td style="text-align: right;">277</td> </tr> <tr> <td>Above 90 KW - upto 125 KW</td> <td style="text-align: right;">331</td> </tr> <tr> <td>Above 125 KW-upto 200 KW</td> <td style="text-align: right;">203</td> </tr> </table> <p>For HT motors the distance between gland plate and the terminal studs shall not be less than 500 mm.</p> <p>PHASE TO PHASE/ PHASE TO EARTH AIR CLEARANCE:</p> <p>NOTE: Minimum inter-phase and phase-earth air clearances for LT motors with lugs installed shall be as follows:</p> <table border="0" style="width: 100%;"> <tr> <td style="width: 60%;">Motor MCR in KW</td> <td style="text-align: right;">Clearance</td> </tr> <tr> <td>UP to 110 KW</td> <td style="text-align: right;">10mm</td> </tr> <tr> <td>Above 110 KW and upto 150 KW</td> <td style="text-align: right;">12.5mm</td> </tr> <tr> <td>Above 150 KW</td> <td style="text-align: right;">19mm</td> </tr> </table>	Motor MCR in KW	Minimum distance between centre of stud and gland plate in mm	UP to 3 KW	As per manufacturer's practice.	Above 3 KW - upto 7 KW	85	Above 7 KW - upto 13 KW	115	Above 13 KW - upto 24 KW	167	Above 24 KW - upto 37 KW	196	Above 37 KW - upto 55 KW	249	Above 55 KW - upto 90 KW	277	Above 90 KW - upto 125 KW	331	Above 125 KW-upto 200 KW	203	Motor MCR in KW	Clearance	UP to 110 KW	10mm	Above 110 KW and upto 150 KW	12.5mm	Above 150 KW	19mm
Motor MCR in KW	Minimum distance between centre of stud and gland plate in mm																												
UP to 3 KW	As per manufacturer's practice.																												
Above 3 KW - upto 7 KW	85																												
Above 7 KW - upto 13 KW	115																												
Above 13 KW - upto 24 KW	167																												
Above 24 KW - upto 37 KW	196																												
Above 37 KW - upto 55 KW	249																												
Above 55 KW - upto 90 KW	277																												
Above 90 KW - upto 125 KW	331																												
Above 125 KW-upto 200 KW	203																												
Motor MCR in KW	Clearance																												
UP to 110 KW	10mm																												
Above 110 KW and upto 150 KW	12.5mm																												
Above 150 KW	19mm																												
LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-2 MOTORS	PAGE 10 OF 10																										

2

297

298

298

NTPC Logo and other vertical markings on the right edge of the page.

PROJECT: BULK SUPPLY (9X800KW) Package: TG & AUXILIARY CONTRACTOR: BHEL- 3000 P&P CONT NO: 2280-186		LIST OF ITEMS REQUIRING QUALITY PLAN AND SUB SUPPLIER APPROVAL				Ref No: 9548954995669373-110 Revision No: 00		
SR NO	ITEM	QP /MS- NO. /PN CAT	QP SUB- QP MISSION APPL SCHEDULE	PROPOSED SUB SUPPLIER	PLACE	Date: 11-03-10		REMARKS
						SS APPL STATUS / CAT	SS DETAIL SUB- SCHEDULE	
1	LT MOTOR (Ref NOTE 2)	1		CGL	AHMEDNAGAR	A		RQP
		1		KBC	RANGLORE/HUBLI*	A		*appx 90kw,RQP
		1		JYOTI	VADDODARA	A		
		1		NGEF	BANGALORE	A		UPTO 15 KW
		1		LHP	SOLAPUR	A		UPTO 120 KW
		1		ABB	PAINDABA D/BANGALORE	A		* RQP & UPTO 55 KW
		1		SIEMENS	MUMBAI	A		RQP
		1		BHARAT BIULEE	MUMBAI	A		UPTO 160 KW
		1		MARATHON	KOLKATA	A		RQP(UPTO 690 V & 600 KW)
		1						
		1		SCHENDER	NASHIK	A		
		1		JOLLY ENGG	KOLKATA	A		
		1		ELECHMECH	AHMEDABAD	A		
		1		SWITCHING CIRCUIT	KOLKATA	A		
		1		L&T	MUMBAI/COMBATOR	A		
		1		CONTROL & SWITCHGEAR	NOIDA/RARIDWAR	A		

2 CONTROL PANEL(NON PLC) FOR MECHANICAL SYSTEM & GENERATOR AC & DC MOTOR STARTER AUXILIARY SYSTEM

2280-186
 BHEL-3000 P&P
 11-03-10
 9548954995669373-110
 Revision No: 00
 RQP

Q

228


94

SR NO	ITEM	QP /INS. NO. -PN CAT	QP /INS. NO. -PN CAT	2250-186	PROPOSED SUB SUPPLIER	PLACE	SS APPL STATUS / CAT	SS DETAIL SUB-SCHEDULE	SS APPL SCHED / SCHEDULE	REMARKS

NOTE 1: NOMENCLATURES USED
 CAT-I QP APPROVAL AND INSPECTION BY NTPC; CAT-II QP APPROVAL BY NTPC INSPECTION BY TEL
 CAT-III INSPECTION AS PER TEL QUALITY SYSTEM
 A: APPROVED VENDOR : DR: DETAILS REQUIRED : DR- VENDOR HISTORICALLY APPROVED, UPDATION OF DATA REQUIRED.
 NOTE 2: A) MOTORS Less than 30 KW
 Acceptance of Motor less than 30 KW is based on COC of the Manufacturer and the Contractor confirming as follows:
 It is hereby confirmed that the above mentioned motor/motors was/were manufactured taking care of NTPC specific requirements regarding ambient temp., voltage, frequency variation, hot starts, pull out torque, starting KV/A/KW, temp. rise, distance between centre of stud gland plate and tested in accordance with approved drawing /data sheets 7 NTPC specification
 B) Between 30 KW and 50KW
 Acceptance of Motor rating between 30 KW and 50 KW is based on NTPC review of Routine Test inspection report as per IS 325 witnessed by main contractor along with COC of the Manufacturer and the Contractor confirming as follows:
 It is hereby confirmed that the above mentioned motor (motors was/were manufactured taking care of NTPC specific requirements regarding ambient temp., voltage, frequency variation, hot starts, pull out torque, starting KV/A/KW, temp. rise, distance between centre of stud gland plate, space heater and tested in accordance with approved drawing /data sheets. FOR MOTORS ABOVE 50 KW: AS PER NTPC APPROVED QUALITY PLAN
 NOTES : IN CASE OF GALVANISED JB EARTHING MATL GALVANISATION TO BE CARRIED OUT AT NTPC APPROVED GALVANISER INDICATED FOR CABLE TRAY
 NOTE 4: ELECTRICAL SUB VENDOR LIST UNDER HYDROGEN PLANT SHALL BE FINALIZED AFTER FINALIZATION OF VENDOR FOR HYDROGEN PLANT.
 NOTE 5: ITEMS NOT REFERED IN ABOVE SHALL BE INTIMATED TO NTPC FOR APPROVAAA

234

100




[Handwritten signature]
 NTPC

[Handwritten signature]
 NTPC

[Handwritten signature]
 NTPC



	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-394/395-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	D
		REV. NO.	0	DATE:	04.07.14

SECTION D

STANDARD TECHNICAL SPECIFICATIONS

D1: STANDARD TECHNICAL SPECIFICATIONS FOR PUMPS

D2: STANDARD TECHNICAL SPECIFICATIONS FOR MOTORS



TECHNICAL SPECIFICATIONS

SPECIFICATION
NO.:

PE-TS-394/395-100-N001

MISCELLANEOUS PUMPS

VOLUME:

IIB

SECTION:

D1

REV. NO.

0

DATE:

04.07.14

SECTION D1

STANDARD TECHNICAL SPECIFICATIONS FOR HORIZONTAL PUMPS NO. PE TS-179-06

STANDARD TECHNICAL SPECIFICATIONS FOR VERTICAL PUMPS NO. PE TS-179-07

DATA SHEET A ALONGWITH LIST OF MANDATORY SPARES &
WATER ANALYSIS

DATA SHEET C

QUALITY PLAN



TITLE:
**STANDARD TECHNICAL SPECIFICATION
HORIZONTAL CENTRIFUGAL PUMPS**

SPECIFICATION NO. PES-179-06

VOLUME: II B

SECTION: D

REV. NO. 03

DATE: 16.07.2012

SHEET 1 of 14

1.00.00 GENERAL INFORMATION

1.01.00 The general guidelines as illustrated in the subsequent clauses of this section shall be applicable for horizontal centrifugal pumps to be procured under the scope of this package.

2.00.00 CODES AND STANDARDS

2.01.00 In addition to the requirements spelt out elsewhere in the specification, the equipment to be provided under this section shall specifically conform to the following codes, standards, specifications and regulations, as applicable, including all the latest amendments subsequent to the year of publication as mentioned below.

- 2.01.01 IS-1520/1980: Horizontal Centrifugal pumps for clear, cold and fresh water.
- 2.01.02 IS-5120/1977: Technical requirements for Rotodynamic special Purpose pumps.
- 2.01.03 IS-5639/1970: Pumps for handling chemicals & corrosive liquids.
- 2.01.04 IS-5659/1970: Pumps for process water.
- 2.01.05 IS-6536/1972: Pumps for handling volatile liquids.
- 2.01.06 IS-9137/1978: Code for acceptance tests for centrifugal, mixed flow and axial flow pumps- Class 'C'.
- 2.01.07 ISO 3555/1977: Acceptance test for centrifugal, mixed flow and axial flow pumps - Class 'B' tests.
BS 5316/1977
Part 2
- 2.01.08 ISO 2548/1973: - Do - Class 'C' tests.
BS 5316/1976
Part 1
- 2.01.09 API-610/1989: Centrifugal pumps for general refinery services.
- 2.01.10 HIS Hydraulic Institute Standards, USA
- 2.01.11 PTC 8.2/1965: Power Test Codes - Centrifugal pumps.
- 2.01.12 ASTM-1-165-55 Standard Methods for Liquid Penetration Inspection.
- 2.02.00 In case of any contradiction with the above standards and annexure, the stipulations in the annexure shall prevail and shall be binding on the bidder.



TITLE:

**STANDARD TECHNICAL SPECIFICATION
HORIZONTAL CENTRIFUGAL PUMPS**

SPECIFICATION NO. PES-179-06

VOLUME: II B

SECTION: D

REV. NO. 03

DATE: 16.07.2012

SHEET 2 of 14

3.00.00 SCOPE OF SUPPLY & SERVICES:

3.01.00 The miscellaneous pumps and drives scope shall be as specified in Data Sheet A /Section A.

3.02.00 The Capacity, Head, Materials of construction and other particulars of pumps are detailed in Data Sheet A of the specification.

3.03.00 Accessories:

All the pumps under this specification shall be complete with following standard/special accessories.

3.03.01 Standard accessories:

- a) LT Electric drives/motors (as applicable) with cable gland and lugs at motor end. (The bare HT drive motors and LT motors not in bidder's scope of supply, wherever required supplied as free issue by BHEL refer Cl. 5.08.00).
- b) Pump motor coupling along with coupling guard.
- c) Common base plate for pumps and motor.
- d) Self contained lubrication system along with all internal piping, valves, fittings, specialties etc. as required.
- e) Counter flanges for suction/ discharge nozzles along with fixing nuts, bolts and gaskets.
- f) Anchor bolts, nuts, seating steel works, shims etc. as necessary for mounting the pump-motor unit on Civil foundations.
- g) Suitable vent (with valves)/ lifting/ handling attachments for the pump/ motor/ accessories.
- h) Suitable drain connections with isolating valves as applicable.
- i) Supply of first fill of lubricants with topping requirements for one year of operation after commissioning and handing over of equipment.
- j) Set of "Special" Tools & Tackles for Pumps and motors, if any.
- k) Erection and commissioning spares, "on as required" basis.
- l) Bidder shall provide various drawings, data, calculations, test reports/ certificates, operation and maintenance manuals, As-built drawings, etc. as specified and as necessary.



TITLE:

**STANDARD TECHNICAL SPECIFICATION
HORIZONTAL CENTRIFUGAL PUMPS**

SPECIFICATION NO. PES-179-06

VOLUME: II B

SECTION: D

REV. NO. 03

DATE: 16.07.2012

SHEET 3 of 14

m) Mandatory spares as specified in respective Data Sheet-A of this section.

3.04.00 Services included in Bidder's Scope:

3.04.01 The pumps shall be guaranteed to meet the performance requirements specified vide Data Sheet -A and also for trouble free operation after commissioning. Schedule of performance guarantees (enclosed in Volume-III) duly filled and signed shall be furnished with the bid.

3.04.02 Pumps with Mechanical seal shall be supplied with gland packing arrangement initially to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be dispatched along with main supply for this purpose.

3.04.03 The pumps erected by the purchaser shall be checked by the bidder for correctness of their installation, alignment, etc. at site prior to their commissioning.

3.04.04 After commissioning of pumps at site, site performance test for Noise, vibration and parallel running of pumps of all pumps for each unit/project will be conducted by BHEL at project site to ensure that the pumps meet the specified requirements. In case of any deficiency, the vendor shall rectify the same at site at no additional cost to BHEL.

3.04.05 Performance Guarantees for pumps shall stand valid till the satisfactory completion of performance testing by BHEL and its acceptance by purchaser / customer.

3.05.00 Works excluded from Bidder's Scope:

- a) All HT motors and those LT Motors which are specifically excluded.
- b) Civil foundation
- c) Suction/ discharge pipe works
- d) MCC/ Switchgear/Power supply
- e) Power and Control Cables, unless specifically specified in Electrical/ Systems portion of the specification.
- f) Erection of equipments.

4.00.00 BID EVALUATION CRITERIA & LIQUIDATED DAMAGES FOR SHORTFALL:

4.01.00 The bids received shall be evaluated for power consumption at inlet to the motors, in respect of pumps specified in Data Sheet-A (working pump only viz. not the standby), for the purpose of price comparisons as briefed below:

The bid evaluation shall be done at the rate as specified in Data Sheet A per one (1) KW Power consumption, per working pump as follows.

$$\text{KW} = \frac{Q \times H \times S}{P \times M \times 367.2}$$



TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
	VOLUME: II B	
	SECTION: D	
	REV. NO. 03	DATE: 16.07.2012
	SHEET 4 of 14	

- Where Q = Rated capacity M³/hr
H = Rated TDH, MWC
P = Pump Efficiency
M = Motor Efficiency.
S = Specific Gravity of fluid handled

4.02.00 The efficiencies for pumps and motors for arriving at benchmark power for Bid Evaluation shall be as indicated in Data Sheet A for various pumps.

No advantage shall be given to the bidder for Aux. Power quoted lower than the Bench mark values calculated with KW calculation formula at Cl. 4.01.00 above, *considering the bid evaluation efficiencies for pump and motor as indicated in Data Sheet-A.* However the bids shall be evaluated as above if the Aux. Power quoted are higher than Bench mark values.

NOTE:

1. Efficiencies for HT motors and LT motors not in bidder's scope, for bid evaluation purpose shall be taken based on the maximum value as furnished in Data Sheet A.
2. During contract stage the Guaranteed power consumption of Pumps with BHEL supplied drives (HT/LT) for successful bidder shall be reworked by BHEL as below:

Revised guarantee power consumption shall be as per KW calculation formula at Cl. 4.01.00 above, *where P = pump efficiency guaranteed by bidder and M = motor efficiency as per approved datasheet of the supplied HT/LT motor.*

4.03.00 Liquidated damages for shortfall in Guaranteed KW

The above guaranteed power consumption shall be demonstrated by the successful bidder during performance testing at works/ site.


For pumps with BHEL supplied drives, the power consumption shall be compared with the reworked guarantee power consumption, defined as per note no. 2 of Cl. 4.02.00 above for the purpose of shortfall.


The liquated damages @ twice the bid evaluation rate as above per KW per working pump shall be levied in the event of failure of bidder to demonstrate the guaranteed power consumption.

5.00.00 TECHNICAL REQUIREMENTS:

5.01.00 The pumps shall meet the technical requirements of section "D" as well as Data Sheet - A. Wherever there is contradiction between Section D and Data Sheet-A, the latter shall prevail. In the event of any contradiction of section "D" with Section-C, the Section-C will prevail.

5.02.00 The pumps shall be Electric motor driven.

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 5 of 14	
5.03.00	The Pumps shall conform to HIS. It is bare minimum requirement, however, any other equivalent or stringent standard is also acceptable, if, all the requirements of HIS are also met.		
5.04.00	The horizontal pumps shall be Horizontal split casing type with speeds not exceeding 1500 RPM or as indicated in Data Sheet-A.		
5.05.00	No negative tolerance shall be permitted in rated capacity & TDH.		
5.06.00	No negative tolerance shall be permitted in efficiency at rated capacity.		
5.07.00	<p>The shut off head of pumps shall be more than pump rated TDH and percentage variation may vary depending on the specific speed of the pump as under:</p> <ol style="list-style-type: none"> 10-15% for pumps of specific speed up to 1000 US units, 15-20% for pumps of specific speed in the range of 1000 to 2000 US units, 20-40% for pumps of specific speed in the range of 2000 to 4000 US units, Above 50% for pumps of specific speed in the range of 4000 to 7000 US units. 		
5.08.00	<p>All HT motors and those LT motors which are not in bidder's scope of supply : bare motors only, shall be supplied as free issue by BHEL through BHEL, based on ratings and TS (Torque - Speed) curve selected and furnished by the bidders along with their un-priced bid. The responsibility for satisfactory operation for combined performance of pumps & motors shall rest with the bidder only as if, the drive motors also have been supplied by the bidder.</p> <p>Couplings, base plate, foundation bolts, any other fittings, etc. as required shall be supplied by the bidders only. BHEL shall supply one number of each type of drive motors (where drive motor is not in bidder's scope of supply) for shop testing of pumps with job motors. All other motors shall be dispatched by BHEL directly to project sites.</p>		
5.09.00	<p>For all HT motor driven pumps, BHEL has envisaged vibration-monitoring system in their own scope. The bidder shall make provisions for mounting following on the pump/ pump shaft:</p> <ul style="list-style-type: none"> Purchaser's probes in both DE/NDE bearings of pumps Key slots on pump shaft with dimensions as specified in Data Sheet A. Other components as finalized during detailing. For mounting of above on the HT motors, same shall be taken care by BHEL - Bhopal. 		
5.10.00	The pumps shall be capable of developing the required total head at rated capacity for continuous operation. The pumps shall operate satisfactorily at any point on the Q-H characteristic curve over a range of 0% to 130% capacity and shall be suitable for continuous operation between 30% to 130% capacity.		

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 6 of 14	
5.11.00	<p>Selection of the pumps shall be such that the design point shall be met even with negative manufacturing tolerance.</p>		
5.12.00	<p>The total head capacity curve shall be continuously rising towards the shut off, the pumps shall preferably be non-overloading type and stable.</p>		
5.13.00	<p>The pumps shall be capable of running over the entire range of NPSH conditions required without any noise, vibration or cavitations.</p> <p>The prevailing suction pressures for various pumps are indicated in Data Sheet-A for suitable mechanical design of pumps.</p>		
5.14.00	<p>The pumps shall be of stiff shaft design. The minimum internal clearances should be sufficiently more than the max. static deflection of the shaft. Shaft size selected must take into consideration the critical speed as specified in API-610.</p>		
5.15.00	<p>Pumps and motors shall run smooth without undue noise and vibration.</p> <p>The vibration shall be within vibration norms for testing as per American National Standard for 'Rotodynamics Pump' for Vibration Measurement and allowable values, Doc. ANSI/ HIS 9.6.4-2009. The applicable vibration limits for each pump, shall be indicated in the Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO.</p> <p>The noise level shall be limited to 85 dB at distance of 1.0M.</p>		
5.16.00	<p>Pumps of a particular category shall be identical and shall be suitable for parallel operation with equal load division. Components of identical pumps shall be interchangeable.</p>		
5.17.00	<p>After installation, the guaranteed values of noise, vibration and parallel operation of pumps shall be tested and verified. If the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, at his own cost.</p>		
5.18.00	<p>High reliability of the pumps is an essential requirement and therefore it gets weightage over its efficiency. It is therefore essential that the bidder choose a standard proven model from the range of pumps manufactured.</p>		
5.19.00	<p>The offered pumps shall be of proven design meeting the experience-qualifying requirement of their operation at two sites for a minimum period of two years. Any deviation to this criterion shall be suitably highlighted in the deviations schedule.</p>		
5.20.00	<p>The bearings shall be self-water lubricated, no external water supply shall be available. The cooling/ lubrication water for bearings, etc. shall be tapped from the pump discharge and supplied thru' bidder's integral pipe work.</p>		



TITLE:

**STANDARD TECHNICAL SPECIFICATION
HORIZONTAL CENTRIFUGAL PUMPS**

SPECIFICATION NO. PES-179-06

VOLUME: II B

SECTION: D

REV. NO. 03

DATE: 16.07.2012

SHEET 7 of 14

If water handled by pump is dirty/ not suitable for lubrication/ cooling, the bidder shall provide requisite strainer/ filters, tanks, motorized valves, etc. after the tap off for the required service, the arrangement provided shall be subject to Purchaser's approval.

6.00.00 MANDATORY SPARES:

6.01.00 Bidder to provide the Mandatory spares listed vide Data Sheet-A. Unit price of mandatory spares shall be furnished in price Schedule.

6.02.00 Bidder shall include the cost of Mandatory Spares in the base price of the pump, unless specified otherwise in Sec-C of the specification or NIT.

7.00.00 OTHER REQUIREMENTS:

7.01.00 The quality of water handled by various pumps shall be as per Data Sheet-A.

7.02.00 The materials of construction for various components specified are the minimum requirements and materials of construction for other components not specified shall be similarly selected by the bidder for the intended duty.

7.03.00 The makes of various bought out items of bidder (i.e. motor, bearings, mechanical seal etc.) shall be subject to purchaser's approval in the event of order.

7.04.00 Painting for Pumps

- a) The surface of SS, Gun metal, brass, bronze and non-metallic component shall not be applied with any painting.
- b) The Steel surface to be applied with painting shall be thoroughly cleaned before applying painting by brushing, shop blasting etc. as per the agreed procedure.
- c) For all the steel surfaces inside the (indoor installation) building, a coat of red oxide primes of min. thickness DFT of 50 microns followed up with under coat of Synthetic Enamel paint of min. thickness DFT of 50 microns shall be applied. The top coat shall consist of two coats each of min. thickness DFT of 50 microns of synthetic enamel paint and thus total DFT shall be min. 200 microns.
- d) For all the steel surfaces exposed to (outdoor installation) atmosphere, a coat of chlorinated rubber based zinc phosphate primer of min. thickness DFT of 50 microns followed up with under coat of chlorinated rubber paint of min. thickness DFT of 50 microns shall be applied. Then, intermediate coat consisting of one coat of chlorinated rubber based paint pigmented with Titanium di-oxide with min. thickness DFT of 50 microns and top coat shall consist of two coats each of min. thickness DFT of 50



TITLE:

**STANDARD TECHNICAL SPECIFICATION
HORIZONTAL CENTRIFUGAL PUMPS**

SPECIFICATION NO. PES-179-06

VOLUME: II B

SECTION: D

REV. NO. 03

DATE: 16.07.2012

SHEET 8 of 14

microns of chlorinated rubber paint shall be provided. Total DFT of paint system shall be min. 200 microns.

7.05.00 It is mandatory for the bidder to submit along with the bid, the deviations if any – whether major or minor in the schedule of deviations only. In the absence of deviations listed in the “Schedule of deviations, the offer shall be deemed to be full conformity with the specification, “notwithstanding” anything else stated elsewhere in bidder’s offer. The implied/indirect deviations shall not be binding on the purchaser.

8.00.00 PERFORMANCE REQUIREMENTS

8.01.00 Performance requirements for the pumps shall be as guided in Data sheet - A enclosed with this section.

8.02.00 Pump(s) shall preferably be designed to have the best efficiency at flow within $\pm 10\%$ of the specified duty point flow. The pumps shall be suitable for continuous operation at any point within the “Range of Operation” as stipulated in the Data Sheet - A attached with this section.

8.03.00 Pump(s) shall preferably have a continuously rising head-capacity characteristics from the specified duty point towards shut-off point, the maximum being at shut-off to enable parallel operation.

Under all circumstances, the ‘range of operation’ of the pumps shall exclude any unstable operating zone of the head-capacity curve.

8.04.00 Wherever specified in the Data Sheet - A attached to this section, pumps of each category shall be suitable for parallel operation. The head vs. capacity, the BHP vs. capacity characteristics etc. shall be identical to ensure equal load sharing and trouble-free operation of any pump when the other pump(s) working in parallel with it trip.

8.05.00 The pump set along with drive motor shall run smooth without undue noise and vibration. Acceptable vibration limits shall be guided by the HIS of USA. Refer clause 5.15.00 above for permissible limits.

9.00.00 DESIGN AND CONSTRUCTION

9.01.00 Pump Casing

9.01.01 Pump casing shall be provided with adequate number of vents and priming connections with valves unless the pump is made self-venting and priming. Casing drain, as required, shall be provided complete with drain valves. It shall be provided with a connection for suction and discharge pressure gauge as standard feature.

9.01.02 Pump design must ensure that the nozzles are capable of withstanding external reactions not less than those specified in API-610.



TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
	VOLUME: II B	
	SECTION: D	
	REV. NO. 03	DATE: 16.07.2012
	SHEET 9 of 14	

- 9.01.03 In case where an expansion joint is located at pump discharge, the pump assembly will be subjected to an additional thrust which will be transmitted to the foundation. This additional thrust shall be taken into the consideration of pump design.
- 9.02.00 **Impeller**
- 9.02.01 The Impeller assembly shall be dynamically balanced and designed with critical speed substantially above the operating speed.
- 9.03.00 **Wearing Rings**
- 9.03.01 Replaceable type wearing rings shall be furnished to prevent damage to impeller and casing.
- 9.04.00 **Shaft**
- 9.04.01 Shaft size shall be selected considering that the critical speed shall be away from the operating speed as recommended in applicable Code/Standard. The critical speed shall be at least 30% higher than the rated speed.
- 9.05.00 **Shaft Sleeves**
- 9.05.01 Renewable type fine finished shaft sleeves shall be provided at the stuffing boxes/mechanical seals. Length of the shaft sleeves must extend beyond the other faces of gland packing or seal end plate so as to distinguish between the leakage past Shaft and shaft sleeve and that past the seals/glands.
- 9.05.02 Shaft sleeves shall be properly fastened to the shaft to prevent any leakage or loosening. Shaft sleeve assembly should ensure concentric rotation.
- 9.06.00 **Bearings**
- 9.06.01 Bearings shall be easily accessible without disturbing the pump assembly. A drain shall be provided at the bottom of each bearing housing.
- 9.06.02 Heavy-duty sleeve/ball/roller type bearings shall be provided to take care of the radial loads.
- 9.06.03 In case of sleeve type radial, axial thrust shall be absorbed in suitable hydraulic devices and/or thrust bearings.
- 9.06.04 Bearings and hydraulic devices (if provided for balancing axial thrust) shall be of adequate design for taking the entire pump load arising from all probable conditions of continuous operation. Life of the bearings shall be guided by the design standard of the pump. Antifriction bearings of standard type, if provided, shall be selected for a minimum



TITLE:

**STANDARD TECHNICAL SPECIFICATION
HORIZONTAL CENTRIFUGAL PUMPS**

SPECIFICATION NO. PES-179-06

VOLUME: II B

SECTION: D

REV. NO. 03

DATE: 16.07.2012

SHEET 10 of 14

life 20,000 hrs. of continuous operation at maximum axial and radial loads at rated speed. Thrust bearing shall be capable of running continuously at maximum load.

9.06.05 The bearing shall be oil/grease lubricated. Suitable lubricating arrangement for the bearings shall be furnished with the pump complete with all accessories like pump, filters, piping, fittings, valves, interlocking and supervising instruments etc. as necessary. The design shall be such that the bearing lubricant does not contaminate the liquid being pumped.

9.06.06 Bearings of reputed makes are to be provided, same shall be indicated in Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO, subject to acceptance of BHEL/ end customer, without any price implication to BHEL.

9.07.00 **Stuffing Boxes**

9.07.01 Stuffing box design shall permit replacement of packing without removing any part other than the gland.

9.07.02 Stuffing boxes shall be sealed/cooled by the fluid being pumped/external clear water, as specified in the Annexure. All necessary pumps, piping, fittings, valves, instruments etc. as required for safe and trouble-free operation of the pumps and as specified in the Annexure shall be included in the scope of supply.

9.08.00 **Mechanical Seals**

9.08.01 Mechanical seals (cartridge type) shall be provided if specified in the Data Sheet-A of this section. The pump supplier shall co-ordinate with the seal maker in establishing the direct circulation rate for maintaining a stable film at the seal in the chamber. The seal piping system shall form an integral part of the pump assembly.


9.08.02 When handling liquids near boiling point, suitable arrangement for external cooling shall be provided so as to prevent flashing at the seal faces.

9.08.03 For the seals under vacuum service, the seal design must ensure sealing against atmospheric pressure, even when the pumps are not operating.

9.08.04 Pumps with Mechanical seal shall be supplied with gland packing arrangement initially to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be dispatched along with main supply for this purpose. The special tools (if any) required for above shall be arranged by bidder.

9.08.05 Mechanical seals of reputed makes are to be provided, same shall be indicated in Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO, subject to acceptance of BHEL/ end customer, without any price implication to BHEL.

9.09.00 **Drive Unit**

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 11 of 14	
9.09.01	The pumps shall be driven by electric motor directly coupled as specified in the Data Sheet-A of this section. A heavy duty coupling along with coupling guard shall be provided between the pump and drive unit.		
9.09.02	Unless otherwise specified in Data Sheet-A of this section, drive unit power rating shall be the maximum of the following requirements. <ol style="list-style-type: none"> 15% margin over the pump shaft input power at the rated duty point. 5% margin over the maximum pump shaft input power required within the 'Range of Operation'. Pump shaft input power required considering the overloading of the pump assuming single pump operation in the event of tripping of one or more of the pumps operating in parallel. 		
9.10.00	Coupling for pump & Motor Shaft		
9.10.01	The pump and motor shafts shall be connected with adequately sized flexible coupling of proven design with spacer to facilitate dismantling of the pump without disturbing the motor. Necessary coupling guard shall be provided.		
9.10.02	No. of coupling holes for joining coupling hubs shall be even in number and preferably in multiples of four.		
10.00.00	INSPECTION AND TESTING		
10.01.00	The Quality Plans enclosed in the specification are for bidder's guidance only. The bidder shall comply with these and other minimum requirements specified in the specification and shall furnish his own quality plan in the event of order based on the guidance given as above, for approval by BHEL/Customer.		
10.02.00	The Bidder shall carry out the following specific tests inspections to ensure that the equipment furnished lies in strict conformance with the specification and also in accordance with applicable codes/standards and good engineering practice. <ol style="list-style-type: none"> Identification and Testing <ol style="list-style-type: none"> All materials used for pump construction shall be of tested quality. Material shall be tested as per the relevant standard and test certificates shall be made available to the Owner. 100% PMI (Process Material Identification) inspection for material grade of pump casing, shaft and impeller shall be done by vendor & certification shall be submitted for review of BHEL. Further BHEL reserves the right to conduct 		



TITLE:

**STANDARD TECHNICAL SPECIFICATION
HORIZONTAL CENTRIFUGAL PUMPS**

SPECIFICATION NO. PES-179-06

VOLUME: II B

SECTION: D

REV. NO. 03

DATE: 16.07.2012

SHEET 12 of 14

random & independent PMI inspection on pump casing, shaft and impeller to ascertain the grade of material during inspection at vendor works.

iii) Tests for each pump included under this section shall include but not be limited to the following:

- The entire surface of the impeller / casing / diffuser castings shall be subjected to Dye Penetration Test as per ASTM Specification no.:1-165-65.
- Shaft coupling & other active components shall be subjected to Dye Penetration and Ultrasonic Tests.
- Wearing rings, shaft sleeves shall be subjected to Dye Penetration Test.
- Fabricated components of pumps shall be subjected to Dye Penetration test on weld.
- Verification of material, witnessing of pouring, casting and inspection of finished fabricated/castings.
- Inspection of finished castings for impeller and verification of materials.
- Inspection of pump shaft and verification of material.
- Witnessing of NDT/review of NDT reports.
- Static balancing test for impeller and dynamic balancing of complete rotating parts as per ISO- 1940 to grade 6.3 or better.
- Complete Inspection of assembled pump.

b) Hydraulic Testing

The pump casing shall be hydrostatically tested at maximum of the following:

- i. 2 times the TDH (Total Dynamic Head) at rated capacity (or)
- ii. 1.5 times the shut-off pressure (or)
- iii. System Design pressure indicated in Data Sheet-A of this section.

The HT pressure shall be maintained for a period of not less than 30 minutes. During testing there should not be any pressure drop & leakage.

c) Performance Test at Shop

- i) Each pump shall have to be tested to determine the performance curves of the pumps. These tests are to be conducted in presence of Owner's representative as per the requirements of the Standards of Hydraulic Institute



TITLE:

**STANDARD TECHNICAL SPECIFICATION
HORIZONTAL CENTRIFUGAL PUMPS**

SPECIFICATION NO. PES-179-06

VOLUME: II B

SECTION: D

REV. NO. 03

DATE: 16.07.2012

SHEET 13 of 14

of USA (ASME-Power Test Code PTC 8.2/BS-599) or any other equivalent standard.

- ii) Performance tests are to be conducted to cover the entire range of operation of the pumps at rated speed. These shall be carried out to span 130% of rated capacity up to pump shut-off condition. A minimum of five combinations of head and capacity are to be achieved during testing to establish the performance curves, including the design capacity point, shut-off point and the two extremities of the range of operation as specified in the annexure. After completion of performance test, all pumps shall be stripped down for inspection of internals.
- iii) Tests shall be conducted with actual drive motors being furnished.
- iv) NPSH tests are to be conducted for each type at 3% head drop conditions, if specified in the pump approved QP.
- v) Mechanical run test shall be carried out on all pumps to determine the vibration levels, noise levels etc. This test shall be conducted at site also. However, test value at site shall be used for the acceptance of the equipment.

10.03.00 Inspection of Mandatory/ Recommended spares shall be in line with approved QP for main supply.

11.00.00 DRAWINGS/ DOCUMENTS DISTRIBUTION SCHEDULE

11.01.00 After award of LOI, the successful bidder shall submit drawings/documents as per Data Sheet-C.

11.02.00 The no. of drawings/documents to be submitted shall be as per Annexure to Data Sheet-C.

12.00.00 The various Sections-C's & D's along with Data Sheets attached in this specification together with the specification for Miscellaneous Pumps shall be complied with by the bidders.

13.00.00 Bidder to submit all drawing/ documents in soft as well as hard copy within 2 weeks from placement of LOI's in the event of order.

Within one (1) week of receipt of BHEL comments a technical representative from Bidder's works shall come for meeting with BHEL along with revised documents to resolve all issues and incorporate all comments in the soft copy here only for further submission to customer.

Further on receipt of customer's comments on the documents a technical representative from Bidder's works shall come for meeting with Customer to resolve all issues and incorporate all comments in the soft copy here only and further resubmission of same to



TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
	VOLUME: II B	
	SECTION: D	
	REV. NO. 03	DATE: 16.07.2012
	SHEET 14 of 14	

Customer. The representative shall be available here till Category-I approval of all the drawings and documents.

14.00.00 Guarantee for all pumps shall at least remain valid for 18 months from the Unit commissioning date or as specified in NIT.

15.00.00 **The following documents only shall be furnished by the bidder with his offer:**


- a) Compliance certificate duly signed and stamped (enclosed at Vol. III of specn.).
- b) GA drawings of pumps and motors with following: (shall be only for reference purpose, same shall not be reviewed/commented by purchaser at this stage and shall be subject to approval only during contract).
 - Civil static & dynamic loads.
 - Foundation details.
- c) Guarantee Schedule duly signed and stamped (enclosed at Vol. III of specn.).
- d) Technical deviation schedule (if reqd.) (enclosed at Vol. III of specn.).
- e) Data for drive Motor (HT/LT- which is not in bidder's scope of supply - as applicable):
Load torque speed curves of the pumps, selected motor rating, rpm, GD^2 of driven equipment.


Apart from above no other Drgs./Docs./Data sheets etc. are required to be submitted at bid stage and even if furnished shall not be taken cognizance of.


DNMBHE/HR/2014/001/001
60437/2014/001/001

DATA SHEET - A		SPECIFICATION NO.:			
MISCELLANEOUS PUMPS (HORIZONTAL)		REV. NO.: 00			
2 X 800 MW GADARWARA STPP, STAGE-1		DATE : 04/07/2014			
PROJECT/PACKAGE		VOLUME : II B			
2 X 800 MW Gadawara STPP, Stage-1		SECTION : D			
Sl. No.	DESCRIPTION	DMCW TG AUX'S PUMPS	DMCW SG AUX'S PUMPS	ACW Pumps	ACW Additional Pumps
HORIZONTAL PUMPS (GROUP-I)					
1.0	SERVICE				
1.1	Total no. of pumps for Project	6	4	6	3
1.2	No. of working & standby pumps	(2W+1S) per unit	(1W+1S) per unit	(2W+1S) per unit	(2W+1S) for station
1.3	Liquid Handled (ref. water analysis enclosed herein)	PH corrected DM Water	PH corrected DM Water	Clarified water	Clarified water
1.4	Location (Indoor / Outdoor)	Indoor	Indoor	Indoor	Indoor
1.5	Duty	Continuous	Continuous	Continuous	Continuous
1.6	No. of pumps working in parallel	2	-	2	2
1.7	Specific gravity	1	1	1	1
1.8	System design pressure (kg/sqcm)	10	12	7	7
2.0	DESIGN PARAMETERS				
2.1	Design capacity each, M ³ /hr	1110	500	1710	300
2.2	Total dynamic head (MWC)	46	64	17	25
2.3	Suction Pressure(MWC)	32	32	19	17
2.4	Design Temperature (°C)	60	60	60	60
2.5	Maximum permissible speed of pump (RPM)	1500	1500	1500	1500
2.6	Max. limit on shut off head Corresponding to pump TDH (MWC) at 52.5 Hz	Not to exceed 65 MWC	Not to exceed 85 MWC	Not to exceed 48 MWC	Not to exceed 50 MWC
2.7	Operating range	30-130% of design duty point flow			
2.8	Motor rating	Motor rating (at 50 deg. C ambient) shall be either 10% above the maximum power requirement at any condition of the entire characteristic curve of the pump (viz. 0-130%) or 16% extra of the power required at the design point, whichever is maximum.			
2.9	Permissible tolerance in rated capacity & TDH	no negative tolerance			
2.10	Permissible tolerance in efficiency at rated capacity(%)	no negative tolerance			
2.11	Performance/Design Standard	HIS			
3.0	CONSTRUCTION FEATURES				
3.1	Pump type	Horizontal centrifugal type Between Bearing Pump	Horizontal centrifugal type Between Bearing Pump	Horizontal centrifugal type Between Bearing Pump	Horizontal centrifugal type Between Bearing Pump
3.2	Impeller type	Closed	Closed	Closed	Closed
3.3	Casing type	Axial split type	Axial split type	Axial split type	Axial split type
3.4	Coupling type	Flexible type	Flexible type	Flexible type	Flexible type
3.5	Sealing arrangement	Gland packing initially & Mechanical seal finally after commissioning	Gland packing initially & Mechanical seal finally after commissioning	Gland packing	Gland packing
3.6	Type of Lubrication	Oil/ Grease/ Self Liquid	Oil/ Grease/ Self Liquid	Oil/ Grease/ Self Liquid	Oil/ Grease/ Self Liquid
3.7	Pump characteristics	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable
3.8	Drain Plugs, vent, lifting lugs, priming connection	Required			
4.0	MATERIALS OF CONSTRUCTION				
4.1	Casing	ASTM A-351 CF8M	ASTM A-351 CF8M	2.5% Ni Cl to IS 210 Gr. FG 260	2.5% Ni Cl to IS 210 Gr. FG 260
4.2	Impeller	ASTM A-351 CF8M	ASTM A-351 CF8M	Bronze to IS 318 Gr. I/II or SS316	Bronze to IS 318 Gr. I/II or SS316
4.3	Shaft	SS-316	SS-316	SS-316	SS-316
4.4	Shaft Sleeves	SS-410	SS-410	SS-410	SS-410
4.5	Impeller Wearing rings	SS-316	SS-316	High leaded Bronze to IS-318 Gr.V/ SS-316 (in case of SS impeller)	High leaded Bronze to IS-318 Gr.V/ SS-316 (in case of SS impeller)
4.6	Wetted fasteners	SS 304	SS 304	SS 304	SS 304
4.7	Fasteners (others)	High tensile Steel	High tensile Steel	High tensile Steel	High tensile Steel
4.8	Gland/Seal Cover	ASTM A-351 CF8M	ASTM A-351 CF8M	2.5% Ni Cl to IS 210 Gr. FG 260	2.5% Ni Cl to IS 210 Gr. FG 260
4.9	Lantern Ring	SS 316	SS 316	Bronze	Bronze
4.10	Mech. seal	Manufacturer standard	Manufacturer standard	-	-
4.11	Gland Packing	PTFE/ Grafoil	PTFE/ Grafoil	Asbestos (Teflon impregnated)	Asbestos (Teflon impregnated)
4.12	Base Plate	MS fabricated IS-2062 (min. thk.-10 mm) Epoxy Coated			
4.13	Stuffing Box	ASTM A-351 CF8M	ASTM A-351 CF8M	2.5% Ni Cl to IS 210 Gr. FG 260	2.5% Ni Cl to IS 210 Gr. FG 260
4.14	Casing Wearing rings (if applicable)	SS 304	SS 304	SS 304	SS 304
4.15	Connecting Pipe material (for deciding counterflange material)	Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589	Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589	Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589	Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589
5.0	MANDATORY SPARES				
	Pumps				
5.1	Fasteners	1 Set	-	1 Set	1 Set
5.2	Sleeve nuts & O Rings	1 Set	2 sets of each type & size	1 Set	1 Set
5.3	Gland/ Gland packing	2 Sets	2 sets of each type & size	2 Sets	2 Sets
5.4	Impeller	1 Set	1 No	1 Set	1 Set
5.5	Bearings for pumps	2 sets	1 set of each type & size	2 sets	2 sets
5.6	Pump Shaft for each type & Size	1 Set	2 Nos	1 Set	1 Set
5.7	Thrust Bearings (if applicable)	2 sets	2 sets	2 sets	2 sets
5.8	Shaft sleeve	1 Set	2 sets	1 Set	1 Set
5.9	Complete coupling (Pump & Motors)	1 set	1 set of each type & size	1 set	1 set
5.1	Casing Wearing rings (if applicable)	2 sets	2 sets	2 sets	2 sets
5.1	Impeller Wearing rings (if applicable)	2 sets	2 sets of each type & size	2 sets	2 sets
5.1	Mechanical Seal	1 set	1 complete set & size	1 set	1 set

PROJECT/PACKAGE		2 X 800 MW Gadarwara STPP, Stage-1		
DATA SHEET - A		SPECIFICATION NO.:		
MISCELLANEOUS PUMPS (HORIZONTAL)		REV. NO.: 00		
2 X 800 MW GADARWARA STPP, STAGE-1		VOLUME : II B		
		SECTION : D		
SI. No.	DESCRIPTION	DMCW TG AUX'S PUMPS	DMCW SG AUX'S PUMPS	ACW Pumps
	Motors			
5.13	Motor of each type & rating	N.A.	-	1 No
5.14	Motor Bearings	N.A.	2 sets of each type & size	2 Sets
6.0	BID EVALUATION RATE			
6.1	Bid evaluation rate	Rs. 2.0 Lacs/KW	Rs. 2.0 Lacs/KW	Rs. 2.0 Lacs/KW
6.2	Maximum permissible efficiency for Bid evaluation			
6.2.1	Pump Efficiency	86	84	86
6.2.2	Motor Efficiency	93	94	91
Notes :				
1	Material of construction for other components not specified above shall be similarly selected in line with the above for the duty intended and subject to approval.			
2	For items stated as not applicable by bidder, shall have to be supplied without any cost implication to BHEL in the event they are found to be applicable during detail engineering stage.			
3	For all HT motor driven pumps (wherever applicable), bidder shall provide key slots of dimensions 30mm Lx15 mm W x3 mmD on each pump shaft or some other suitable location which shall be confirmed during detail engineering by BHEL.			
4	Wherever SS material is coming in contact with non SS material, suitable isolation (rubber etc.) shall be provided to avoid galvanic corrosion.			
5	For General Notes regarding mandatory spares refer 2 pages annexure.			

CLAUSE NO.	MANDATORY SPARES			
	<p>GENERAL NOTE:</p> <ol style="list-style-type: none"> 1. Unless stated otherwise a 'Set', it will include the total requirement of the item for a unit module or the station as specified. Also are set for the particular equipment e.g. 'set' of bearings for a pump would include the total number of bearings in a pump. Also the 'set' would include all components required to replace the item; for example a set of bearing shall include all hardware normally required while replacing the bearings. It is further, intended that the assembly/sub-assembly which have different orientation (like left hand or right hand, top or bottom), different direction of rotation or mirror image positioning or any other reasons which result in maintaining two different sets of the spares to be used for the subject assembly/sub-assembly, these shall be considered as different types of assembly/sub-assembly. 2. Wherever quantity has been specified as percentage (%), it shall mean percentage (%) of the total population of the item in the station (project), unless specified otherwise and the fraction will be rounded off to the next higher whole number. 3. Wherever the quantities have been indicated for each type, size, thickness, material, radius, range etc. these shall cover all the items supplied and installed and the break up for these shall be furnished in the bid. 4. In case spares indicated in the list are not applicable to the particular design offered by the bidder, the bidder should offer spares applicable to offered design with quantities generally in line with the approach followed in the above list. 5. Interchangeability and Packings: All spares supplied under this contract shall be strictly interchangeable with parts for which they are intended for replacements. These spares should include all mounted accessories like components, boards, add or items, fitting, connectors etc. and be complete in all respects so that the replacement of the main items by these spares does not require any additional item. The vendors must conform the pair to pair compatibility of each electrical spares modules with the modules should be supplied in the 			
GAJMARA SUPER THERMAL POWER PROJECT, STAGE-I (2 X 800MW)	TECHNICAL SPECIFICATION SECTION-VI PART-A	MANDATORY SPARES	PAGE 1 of 2	

CLAUSE NO.	MANDATORY SPARES			
	<p>original package. All electronic modules should be pre set and/or preprogrammed for ready use at site. Alternatively, suitable instruction sheet indicating the details of required PCB jumper position, BCD which is setting, EPROM/PROM listing etc should be packed along with each module. Also a caution mark sign should be put on all such module which needs pre setting/pre programming before putting them in to service. The spare shall be treated and properly packed for long term storage</p> <p>6. Identification:</p> <p>Each spare shall be clearly marked and labeled on the outside of the packing with its description. When more than one spare part is packed in single case, a general description of the contents shall be shown on the outside of such case and a detailed list enclosed. All cases, containers and other packages must be suitably marked and numbered for the purpose of identification.</p> <p>7. Control & Instrumentation Mandatory Spares for specific sub-systems such as hydrogen generation plant and Condensate Polishing Unit (if applicable), the spares shall be governed by the spares indicated against the corresponding specific clauses only. For all remaining systems / equipments offered under the present scope of work, the spares shall be offered in totality as per the complete C&I items supplied in accordance with the applicable clauses of C&I items</p>			
GAJMARA SUPER THERMAL POWER PROJECT, STAGE-I (2 X 800MW)	TECHNICAL SPECIFICATION SECTION-VI PART-A	MANDATORY SPARES	PAGE 2 of 2	

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-394/395-100-N001		
	MISCELLANEOUS PUMPS DATA SHEET - C	VOLUME:	IIB	SECTION:	D1
		REV. NO.	0	DATE:	04.07.14

Drawings / documents distribution schedule to be followed by successful bidder :

- 1.0 Drawings/documents submission schedule, shall be as per NIT. The successful bidder shall submit following drawings/ documents.
- 1.1 Fully dimensioned outline general arrangement drawings of the pump and motor assembly. This drawing should include foundation base plate and sole plate details as applicable, civil foundation and anchor bolt details and loading data, points of connections of external piping and cables and mounting of devices furnished by the supplier.
- 1.2 Cross sectional drawing of the equipment showing the details of assembly of components and their material of construction with standard applicable codes.
- 1.3 Characteristic curves of pump showing the following:
 - a) Flow Vs Head
 - b) Flow VS Power
 - c) Flow Vs Efficiency
 - d) Flow Vs NPSHR
- 1.4 Operation and maintenance manual
- 1.5 Lubrication arrangement drawings for external lubrication (if applicable).
- 2.0 Within the stipulated time period as per vendor's drawings/ documents schedule as per NIT, the O&M Manual comprising of minimum following shall be submitted
 - a) Drawings of components & details as deemed necessary.
 - b) Instruction manual for erection, operation & maintenance.
 - c) Storage instruction.
- 3.0 Before despatch of the equipment the bidder shall furnish the following.
 - a) Material test certificates.
 - b) Shop test reports & certificates.
- 4.0 Distribution of drawings / documents for all projects:

The no. of drawing/ documents to be submitted by the successful bidder, after the award of the contract shall be intimated after award of contract.

**BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN**

**QUALITY PLAN FOR MISCELLANEOUS
PUMPS**

QUALITY PLAN FOR MISCELLANEOUS PUMPS		CUSTOMER		PROJECT TITLE						
		BIDDER/VENDOR		QUALITY PLAN NUMBER						
		SYSTEM		ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
SHEET 1 OF 6										
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS
									P W V	
									10	11
MATERIALS CONTROL										
1.1	CASINGS (INCLUDING BOWLS, DIFFUSERS, STAGE BODIES, DISCH HEAD (IF CAST)), ETC. - (AS APPLICABLE) AND IMPELLER	MECHANICAL AND CHEMICAL PROPS	CR	MECHANICAL AND CHEM. ANALYSIS	ONE/HEAT/BATCH	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	LAB REPORT/ MTC	3/2.	2.1
1.2	STUFFING BOX, SUCTION BELL, WEARING RINGS, NECK RINGS, SHAFT SLEEVES AND IMPELLER	DO- HARDNESS DIFFERENCE BETWEEN CASING / IMPELLER AND WEARING RING	MA	MECHANICAL AND CHEM. ANALYSIS	ONE/HEAT/BATCH	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	LAB REPORT/ MTC	3/2.	2.1
1.3	BARS/FORGINGS FOR SHAFTS, LINE SHAFTS	1. PHYSICAL & CHEMICAL PROPS 2. DIMENSIONS 3. INTERNAL DEFECTS FOR 40MM & ABOVE DIA SHAFTS.	CR	1. MECHANICAL & CHEMICAL ANALYSIS. 2. MEASUREMENT 3. ULTRA SONIC TEST	100% 100%	APPROVED CS DRAWING/DATA SHEET MFR. DRAWING	RELEVANT MATERIAL SPECN. MFR. DRAWING	MILL T.C. OR LAB REPORT INSP. REPORT	3/2. 3/2.	2.1 2.1
1.4	STRESS RELIEVING/ HEAT TREATMENT OF CASTING OF ALL ABOVE (IF APPLICABLE) / SOLUTION ANNEALING OF SS CASTING	1. VERIFICATION OF HT CHART 2. IGC TEST FOR SS CASTING	MA	VERIFICATION OF SR/HT CHART	ALL BATCHES ONE SAMPLE/ HT BATCH	RELEVANT MATERIAL SPECN. ASTM A 262	DO- ASTM A 262 Gr A	CORRELATED SR/HT CHARTS LAB. REPORT	3/2. 3/2.	2.1 2.1
1.5	SHAFT ENCLOSING TUBES, COLUMN PIPES & DISCHARGE ELBOW	1. MECHANICAL & CHEMICAL PROPS. 2. DIMENSIONS. 3. SURFACE FINISH	MA	1. MECH & CHEM TEST 2. MEASUREMENT 3. VISUAL EXAM	1/BATCH 100% 100%	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./MFG. APPROVED DOCS	MFR T.C OR LAB. REPORT	3/2.	2.1
BHEL										
PARTICULARS										
NAME										
SIGNATURE										
DATE										
BIDDER/VENDOR SEAL										

**BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN**

QUALITY PLAN FOR MISCELLANEOUS PUMPS		CUSTOMER		PROJECT TITLE						
		BIDDER/VENDOR		QUALITY PLAN NUMBER						
SYSTEM		ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)								
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECKED	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS
1	2	3	4	5	6	7	8	9	P W V	11
1.6	PLATE FLANGE, C/FLANGE	1. MECHANICAL & CHEMICAL PROS. 2. DIMENSIONS. 3. SURFACE FINISH	MA	1. MECH & CHEM TEST 2. MEASUREMENT 3. VISUAL EXAM	1/CAST 100% 100%	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./ MFR. DRG./ APPROVED DOC	MILL TC/ LAB REPORT	3/2. 2.1	CORRELATION REQ. FOR MAT OTHER THAN IS 2062
1.7	SUCTION STRAINER (IF APPLICABLE)	MECHANICAL & CHEMICAL PROS.	MI	MECH. & CHEMICAL TEST	1/HEAT	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./ MFR. DRG./ APPROVED DOC	MILL TC/ LAB REPORT	3/2. 2.1	
1.8	MECHANICAL SEAL (IF APPLICABLE)	TYPE, SIZE, MFRS, NO., MAKE	MA	VISUAL EXAM	100%	APPROVED DATASHEET / GA MECH. SEAL	APPROVED DATASHEET		3/2. 2.1	COMPLIANCE TO FOR APPROVED MAKE
1.9	PUMP BEARINGS	TYPE, SIZE, MFRS, NO., MAKE	MA	VISUAL EXAM	100%	APPROVED DATASHEET	APPROVED DATASHEET		3/2. 2.1	COMPLIANCE TO FOR APPROVED MAKE
2.0 IN PROCESS CONTROL										
2.1	ALL COMPONENTS UNDER 1.00 ABOVE	VISUAL DEFECTS, DIMENSIONS	MA	VISUAL EXAM, MEASUREMENT	100%	MFG. DRAWING	MFG. DRAWING	COMPLIANCE TC	3/2. 2.1	
2.2	IMPELLER	CLEANING AND DEBURRING	MA	VISUAL	100%	MFG. DRAWING	MFG. DRAWING		3/2. 2.1	
		DYNAMIC BALANCING	CR	DYNAMIC BALANCING	100%	ISO 1940	ISO 1940 Gr 6.3	BALANCING CERTIFICATE	3/2. 2.1	WITNESSING ONLY FOR SIZE GREATER THAN 10KW
2.3	IMPELLER-ALL ACCESSIBLE SURFACES, DIFFUSERS	DP TEST	MA	DP TEST ON M/CD AREA	100%	APPENDIX 8 OF ASME SEC. VIII DIV. 1	APPENDIX 8 OF ASME SEC. VIII DIV. 1	NDT CERTIFICATE	3/2. 2.1	WITNESS BY BHEL & VARIIFICATION BY CUSTOMER
2.4	WERING RING, SHAFT SLEEVES, CASING	DP TEST	MA	DP TEST ON M/CD AREA	100%	APPENDIX 8 OF ASME SEC. VIII DIV. 1	APPENDIX 8 OF ASME SEC. VIII DIV. 1	NDT CERTIFICATE	3/2. 2.1	WITNESS BY BHEL & VARIIFICATION BY CUSTOMER
2.5	SHAFT	DP TEST	MA	DP TEST ON M/CD AREA	100%	ASTM E 165	NO RELEVANT INDICATION ALLOWED	NDT CERTIFICATE	3/2. 2.1	WITNESS BY BHEL & VARIIFICATION BY CUSTOMER
2.6	CASINGS/ BOWLS, STAGE BODIES, DISCHARGE HEAD (IF CAST), SUCTION HOUSING, COLUMN PIPE DISCHARGE PIPE ETC	LEAK TIGHTNESS	CR	VISUAL	100%	TECHNICAL DATA SHEET AND NOTE 2	NO LEAKAGE FOR TEST DURATION OF 30 MIN.	HT CERTIFICATE	3/2. 12.1	HAMMERING OF CASTINGS WITH WOODEN/RUBBER Mallet BEFORE HYDRO TEST
BHEL										
PARTICULARS										
NAME										
SIGNATURE										
DATE										
BIDDER / VENDOR										
BIDDER/VENDOR SEAL										

**BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN**

QUALITY PLAN FOR MISCELLANEOUS PUMPS		CUSTOMER		PROJECT TITLE						
		BIDDERS/VENDOR		QUALITY PLAN NUMBER						
SHEET 3 OF 6		SYSTEM		ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS
1	2	3	4	5	6	7	8	9	P W V	10
2.7	FABRICATED COMPONENTS									
2.7.1	WELDING PROCEDURE SPECIFICATION	CORRECTNESS	MA	EXAM.	100%	ASME SEC.IX	ASME SEC.IX	QW 482 OF ASME SEC.IX	3/2.	2.1
2.7.2	WELDING PROCEDURE QUALIFICATION	WELD SOUNDNESS	MA	VISUAL,PHYS. TESTS RT (AS APPLICABLE)	100%	ASME SEC.IX	ASME SEC.IX	QW 483 OF ASME SEC.IX	3/2.	2.1
2.7.3	WELDER PERFORMANCE QUALIFICATION	WELD SOUNDNESS	MA	VISUAL,PHYS. TESTS RT (AS APPLICABLE)	100%	ASME SEC.IX	ASME SEC.IX	QW 484 OF ASME SEC.IX	3/2.	2.1
2.7.4	WELD FIT-UPS	DIMENSION & ALIGNMENT	MA	MEAS.VISUAL EXAM	100%	WPS, MFG .DRAWING	WPS, MFG .DRAWING	IR/LOGBOOK	3/2.	
2.7.5	ROOT RUNS	SURFACE DEFECTS	MA	PENETRANT TEST	100%	ASTM E 165	NO SURFACE DEFECT	DO.	3/2.	2.1
2.7.6	WELDMENTS	SURFACE DEFECTS	MA	PENETRANT TEST	100%	ASTM E 165	ASME-VIII, DIV I	INSPN REPORT	3/2.	2.1
BHEL										
PARTICULARS										BIDDER / VENDOR
NAME										
SIGNATURE										
DATE										
										BIDDER/VENDOR SEAL

QUALITY PLAN FOR MISCELLANEOUS PUMPS

WELDING PROCEDURE APPROVAL BY BHEL ALT. 3RD PARTY (LLYODS,BVQI OR EQ.) IS ACCEPTABLE.

**BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN**

QUALITY PLAN FOR MISCELLANEOUS PUMPS		CUSTOMER		PROJECT TITLE							
SYSTEM		BIDDER/VENDOR		QUALITY PLAN NUMBER							
SHEET 4 OF 6		SYSTEM		ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)							
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS	
1	2	3	4	5	6	7	8	9	P	W	V
2.7.7	BUTT WELDS	INTERNAL DEFECT	MA	UT/RT	100%			IR	3/2.		2.1
2.7.8	DICHARGE HEAD, COLUMN PIPE, DISCHARGE PIPE, ETC.	1. LEAK TIGHTNESS 2. DIMENSION	CR	1. HYDROTEST 2. MEASUREMENT	100%	TECHNICAL SPEC/DATA SHEET, MFR DRAWING	1. NO LEAKAGE 2. MFR. DRAWING	IR	3/2.	2.1	
3.0	SUB-ASSEMBLY CONTROL										
3.1	ROTOR ASSEMBLY	ECCENTRICITY	MA	MEASUREMENT	100%	MFR. DRAWING	MFR. DRAWING	IR/LOG BOOK	3/2.		1
3.2	ROTOR ASSEMBLY RESIDUAL UNBALANCE	STATIC & DYNAMIC	CR	STATIC & DYNAMIC BALANCING	100%	ISO 1940	ISO 1940 Gr.6.3	BALANCING CERTIFICATE	3/2.	2.1	WTNESSING ONLY FOR SIZE GREATER THAN 10KW
3.3	COMPLETE PUMP ASSEMBLY	COMPLETENESS, CORRECTNESS, CLEANLINESS, CLEARANCES, FREENESS, ALIGNMENT	MA	VISUAL EXAM MEASUREMENT	100%	APPROVED DRG & MFG STANDARDS	APPROVED DRG & MFG STANDARDS	I.R. & CHECK LISTS	3/2.		2.1
BHEL		PARTICULARS									
		NAME									
		SIGNATURE									
		DATE									
										BIDDER/VENDOR SEAL	

**BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN**

QUALITY PLAN FOR MISCELLANEOUS PUMPS		CUSTOMER		PROJECT TITLE							
		BIDDER/VENDOR		QUALITY PLAN NUMBER							
SHEET 5 OF 6		SYSTEM		ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)							
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS	
1	2	3	4	5	6	7	8	9	P W V	10	
4	FINAL INSPECTION, TESTS & PACKING DESPATCH CONTROL										
4.1	PUMP WITH JOB/SHOP MOTOR ASSEMBLED ON INDIVIDUAL BASE FRAME	1. Q V/S HEAD, 2. Q V/S POWER, 3. Q V/S PUMP EFF. 4. VIBRATION 5. NOISE 6. BEARING TEMP. 7. LEAKAGES	CR	PERFORMANCE TEST	100%	APPD. PERFORMANCE TEST PROCEDURE/ APPD. DATA SHEET/APPD. CURVES FOR VIBRATIONS - AS PER ANSI/HIS 9.6.4-2009 (VALUES AS PER APPROVED DATA SHEET) FOR BEARING TEMP. - BEARING HOUSING SHOULD NOT BE UNTOUCHABLY HOT. FOR LEAKAGE - MINOR LEAKAGE (DROP BY DROP) IN CASE OF GLAND PACKING ARRANGEMENT.		IR., PERF. TEST RECORD. PLOTTED CURVES	3/2, 2.1.	* MINIMUM 7 POINTS FROM SHUT-OFF TO MAX. OPERATING FLOW COVERING ENTIRE OPERATION RANGE OF PUMP SHALL BE TAKEN.	
4.2	STRIP DOWN AFTER PERFORMANCE TEST	NPSH/ MIN. SUBMERGENCE REQUIRED	CR	NPSH TEST	1/MODEL	DO.		IR. NPSH/MIN. SUBMERGENCE TEST RECORD. PLOTTED CURVES	3/2, 2.1.	IF SPECIFIED or INSISTED BY CUSTOMER.	
4.3	COMPLETE PUMP WITH UNIT MOTOR BASE FRAME, COUNTER FLANGES ETC, INCLUDING ALL ACCESSORIES AS PER SECTION C OF SPECN.	1. UNDUE WEAR TEAR AND RUBBING	MA	VISUAL EXAM AFTER STRIPPING	1/MODEL	NO UNDUE WEAR TEAR & RUBBING ON IMPELLER & WEAR RING		INSP. REPORT	3/2, 1	WITNESS REQUIRED ONLY WHEN ABNORMAL SOUND OBSERVED DURING PERFORMING TEST.	
		COMPLETENESS, CLEANLINESS, OVERALL DIMENSIONS ORIENTATION, WORKMANSHIP AND FINISH	MA	VISUAL EXAM MEASUREMENT	100%	APPD. G.A DRAWING	APPD. G.A DRAWING	INSP. REPORT	3/2, 1		
		BHEL		PARTICULARS		BIDDER / VENDOR					
		NAME									
		SIGNATURE									
		DATE								BIDDER/VENDOR SEAL	

**BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN**

QUALITY PLAN FOR MISCELLANEOUS PUMPS

QUALITY PLAN FOR MISCELLANEOUS PUMPS		CUSTOMER		PROJECT TITLE						
		BIDDER/VENDOR		QUALITY PLAN NUMBER						
SHEET 6 OF 6		SYSTEM		ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS
									P W V	
1	2	3	4	5	6	7	8	9	10	11
4.4	COMPLETION OF ALL STAGES	1.COMPLETION	MA	VERIFICATION OF IRT,C.ETC.	100%	MFG. DRG./TECHNICAL DOCS.	APPD. MFG. DRG./TECHNICAL DOCS	IR.	3/2, 2,1	WITNESSING ONLY BY BHEL, CUSTOMER VERIFICATION ONLY BUT CHP
4.5	PAINTING	1.SURFACE FINISH, DFT, MARKINGS ETC.	MA	VISUAL EXAM MEASUREMENT AESTHETIC	100%	APPD.DRG.	APPD.DOCS	IR.	3/2.	
4.6	PACKING, MARKING	SOUNDNESS OF PACKING	MI	VISUAL AESTHETIC	100%	MFG. STANDARD	MFG. STANDARD		3/2.	2


MTC -Mill Test Certificate, MA-Major, MI-Minor, TC-Test Certificate, CR-Critical, IGC-Inter Granular Corrosion

- AS CAST HEAT MARKS SHALL BE PROVIDED ON CI CASTING LIKE TOP & BOTTOM CASING.
- HYDRO TEST PRESSURE SHALL BE AT LEAST 2(TWO) TIMES THE DUTY POINT (OR) 1.5 TIMES OF SHUT OFF HEAD (OR) SYSTEM DESIGN PRESSURE, WHICHEVER IS HIGHER.
- THIS QAP IS ALSO APPLICABLE FOR SPARES.
- NO WELD REPAIRS PERMISSIBLE ON CI CASTING.
- MATERIAL SHALL BE AS PER APPROVED CROSS SECTION DRG./ DATA SHEET.
- STRIP TEST- INCASE OF ABNORMAL NOISE OBSERVED DURING PERF. TEST, THOSE PUMP WILL BE STRIPPED DOWN FOR VISUAL INSPECTION OF IMPELLER & WEAR SHALL BE OFFERED FOR VISUAL INSPECTION FOR WEAR /RUBBING MARKS.
- PUMPS WITH MECHANICAL SEAL ARRANGEMENT TO BE TESTED AND SUPPLIED WITH GLAND PACKING ARRANGEMENT. HOWEVER MANUFACTURER TO ENSURE DIMENTIONAL MATCHING OF MECHANICAL SEAL WITH PUMP GA DRAWING.

LEGEND : 1- BHEL OR BHEL NOMINATED THIRD PARTY /END CUSTOMER OF BHEL,
2- VENDOR,
3-SUB-VENDOR

P- PERFORM, W- WITNESS, V-VERIFICATION

BHEL	PARTICULARS	BIDDER /VENDOR
NAME		
SIGNATURE		
DATE		
		BIDDER/VENDOR SEAL

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-394/395-100-N001	
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION: D2
		REV. NO.	0	DATE: 04.07.14

SECTION D2

**STANDARD MOTOR SPECIFICATION
STANDARD QUALTY PLAN FOR MOTORS**



TITLE :
GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS


SPECIFICATION NO. PE-SS-999-506-E101
VOLUME NO. : II-B
SECTION : D
REV NO. : 00 DATE : 28.01.10
SHEET : 1 OF 1

GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS

SPECIFICATION NO.: PE-SS-999-506-E101 Rev 00

	TITLE :	SPECIFICATION NO.																														
	GENERAL TECHNICAL REQUIREMENTS	PE-SS-999-506-E101																														
	FOR	VOLUME NO. : II-B																														
	LV MOTORS	SECTION : D																														
		REV NO. : 00 DATE : 28.01.10																														
		SHEET : 1 OF 4																														
<p>1.0 INTENT OF SPECIFICATION</p> <p>The specification covers the design, materials, constructional features, manufacture, inspection and testing at manufacturer's work, and packing of Low voltage (LV) squirrel cage induction motors along with all accessories for driving auxiliaries in thermal power station.</p> <p>Motors having a voltage rating of below 1000V are referred to as low voltage (LV) motors.</p>																																
<p>2.0 CODES AND STANDARDS</p> <p>Motors shall fully comply with latest edition, including all amendments and revision, of following codes and standards:</p> <table border="0"> <tr> <td>IS:325</td> <td>Three phase Induction motors</td> </tr> <tr> <td>IS : 900</td> <td>Code of practice for installation and maintenance of induction motors</td> </tr> <tr> <td>IS: 996</td> <td>Single phase small AC and universal motors</td> </tr> <tr> <td>IS: 4722</td> <td>Rotating Electrical machines</td> </tr> <tr> <td>IS: 4691</td> <td>Degree of Protection provided by enclosures for rotating electrical machines</td> </tr> <tr> <td>IS: 4728</td> <td>Terminal marking and direction of rotation rotating electrical machines</td> </tr> <tr> <td>IS: 1231</td> <td>Dimensions of three phase foot mounted induction motors</td> </tr> <tr> <td>IS: 8789</td> <td>Values of performance characteristics for three phase induction motors</td> </tr> <tr> <td>IS: 13555</td> <td>Guide for selection and application of 3-phase A.C. induction motors for different types of driven equipment</td> </tr> <tr> <td>IS: 2148</td> <td>Flame proof enclosures for electrical appliance</td> </tr> <tr> <td>IS: 5571</td> <td>Guide for selection of electrical equipment for hazardous areas</td> </tr> <tr> <td>IS: 12824</td> <td>Type of duty and classes of rating assigned</td> </tr> <tr> <td>IS: 12802</td> <td>Temperature rise measurement of rotating electrical machines</td> </tr> <tr> <td>IS: 12065</td> <td>Permissible limits of noise level for rotating electrical machines</td> </tr> <tr> <td>IS: 12075</td> <td>Mechanical vibration of rotating electrical machines</td> </tr> </table> <p>In case of imported motors, motors as per IEC-34 shall also be acceptable.</p>			IS:325	Three phase Induction motors	IS : 900	Code of practice for installation and maintenance of induction motors	IS: 996	Single phase small AC and universal motors	IS: 4722	Rotating Electrical machines	IS: 4691	Degree of Protection provided by enclosures for rotating electrical machines	IS: 4728	Terminal marking and direction of rotation rotating electrical machines	IS: 1231	Dimensions of three phase foot mounted induction motors	IS: 8789	Values of performance characteristics for three phase induction motors	IS: 13555	Guide for selection and application of 3-phase A.C. induction motors for different types of driven equipment	IS: 2148	Flame proof enclosures for electrical appliance	IS: 5571	Guide for selection of electrical equipment for hazardous areas	IS: 12824	Type of duty and classes of rating assigned	IS: 12802	Temperature rise measurement of rotating electrical machines	IS: 12065	Permissible limits of noise level for rotating electrical machines	IS: 12075	Mechanical vibration of rotating electrical machines
IS:325	Three phase Induction motors																															
IS : 900	Code of practice for installation and maintenance of induction motors																															
IS: 996	Single phase small AC and universal motors																															
IS: 4722	Rotating Electrical machines																															
IS: 4691	Degree of Protection provided by enclosures for rotating electrical machines																															
IS: 4728	Terminal marking and direction of rotation rotating electrical machines																															
IS: 1231	Dimensions of three phase foot mounted induction motors																															
IS: 8789	Values of performance characteristics for three phase induction motors																															
IS: 13555	Guide for selection and application of 3-phase A.C. induction motors for different types of driven equipment																															
IS: 2148	Flame proof enclosures for electrical appliance																															
IS: 5571	Guide for selection of electrical equipment for hazardous areas																															
IS: 12824	Type of duty and classes of rating assigned																															
IS: 12802	Temperature rise measurement of rotating electrical machines																															
IS: 12065	Permissible limits of noise level for rotating electrical machines																															
IS: 12075	Mechanical vibration of rotating electrical machines																															
<p>3.0 DESIGN REQUIREMENTS</p>																																
<p>3.1 Motors and accessories shall be designed to operate satisfactorily under conditions specified in data sheet-A and Project Information, including voltage & frequency variation of supply system as defined in Data sheet-A</p>																																
<p>3.2 Motors shall be continuously rated at the design ambient temperature specified in Data Sheet-A and other site conditions specified under Project Information Motor ratings shall have at least a 15% margin over the continuous maximum demand of the driven equipment, under entire operating range including voltage & frequency variation specified above.</p>																																
<p>3.3 Starting Requirements</p>																																
<p>3.3.1 Motor characteristics such as speed, starting torque, break away torque and starting time shall be properly co-ordinated with the requirements of driven equipment. The accelerating torque at any speed with the minimum starting voltage shall be at least 10% higher than that of the driven equipment.</p>																																
<p>3.3.2 Motors shall be capable of starting and accelerating the load with direct on line starting without exceeding acceptable winding temperature.</p>																																



TITLE :
GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS

SPECIFICATION NO.
PE-SS-999-506-E101
VOLUME NO. : **II-B**
SECTION : **D**
REV NO. : **00** DATE : 28.01.10
SHEET : 2 OF 4

The limiting value of voltage at rated frequency under which a motor will successfully start and accelerate to rated speed with load shall be taken to be a constant value as per Data Sheet - A during the starting period of motors.

3.3.3 The following frequency of starts shall apply

- i) Two starts in succession with the motor being initially at a temperature not exceeding the rated load temperature.
- ii) Three equally spread starts in an hour the motor being initially at a temperature not exceeding the rated load operating temperature. (not to be repeated in the second successive hour)
- iii) Motors for coal conveyor and coal crusher application shall be suitable for three consecutive hot starts followed by one hour interval with maximum twenty starts per day and shall be suitable for minimum 20,000 starts during the life time of the motor

3.4 **Running Requirements**

3.4.1 Motors shall run satisfactorily at a supply voltage of 75% of rated voltage for 5 minutes with full load without injurious heating to the motor.

3.4.2 Motor shall not stall due to voltage dip in the system causing momentary drop in voltage upto 70% of the rated voltage for duration of 2 secs.

3.5 **Stress During bus Transfer**

3.5.1 Motors shall withstand the voltage, heavy inrush transient current, mechanical and torque stress developed due to the application of 150% of the rated voltage for at least 1 sec. caused due to vector difference between the motor residual voltage and the incoming supply voltage during occasional auto bus transfer.

3.5.2 Motor and driven equipment shafts shall be adequately sized to satisfactorily withstand transient torque under above condition.

3.6 Maximum noise level measured at distance of 1.0 metres from the outline of motor shall not exceed the values specified in IS 12065.

3.7 The max. vibration velocity or double amplitude of motors vibration as measured at motor bearings shall be within the limits specified in IS: 12075.

4.0 **CONSTRUCTIONAL FEATURES**

4.1 Indoor motors shall conform to degree of protection IP: 54 as per IS: 4691. Outdoor or semi-indoor motors shall conform to degree of protection IP: 55 as per IS: 4691 and shall be of weather-proof construction. Outdoor motors shall be installed under a suitable canopy

4.2 Motors upto 160KW shall have Totally Enclosed Fan Cooled (TEFC) enclosures, the method of cooling conforming to IC-0141 or IC-0151 of IS: 6362.

Motors rated above 160 KW shall be Closed Air Circuit Air (CACA) cooled

4.3 Motors shall be designed with cooling fans suitable for both directions of rotation.



TITLE :
GENERAL TECHNICAL REQUIREMENTS

SPECIFICATION NO.
PE-SS-999-506-E101

VOLUME NO. : **II-B**

SECTION : **D**

REV NO. : **00** DATE : 28.01.10

SHEET : 3 OF 4

FOR
LV MOTORS

- 4.4. Motors shall not be provided with any electric or pneumatic operated external fan for cooling the motors.
- 4.5. Frames shall be designed to avoid collection of moisture and all enclosures shall be provided with facility for drainage at the lowest point.
- 4.6. In case Class 'F' insulation is provided for LV motors, temperature rise shall be limited to the limits applicable to Class 'B' insulation.
In case of continuous operation at extreme voltage limits the temperature limits specified in table-1 of IS:325 shall not exceed by more than 10°C.
- 4.7. **Terminals and Terminal Boxes**
- 4.7.1. Terminals, terminal leads, terminal boxes, windings tails and associated equipment shall be suitable for connection to a supply system having a short circuit level, specified in the Data Sheet-A.

Unless otherwise stated in Data Sheet-A, motors of rating 110 kW and above will be controlled by circuit breaker and below 110 kW by switch fuse-contactor. The terminal box of motors shall be designed for the fault current mentioned in data sheet "A".
- 4.7.2. Unless otherwise specified or approved, phase terminal boxes of horizontal motors shall be positioned on the left hand side of the motor when viewed from the non-driving end.
- 4.7.3. Connections shall be such that when the supply leads R, Y & B are connected to motor terminals A B & C or U, V & W respectively, motor shall rotate in an anticlockwise direction when viewed from the non-driving end. Where such motors require clockwise rotation, the supply leads R, Y, B will be connected to motor terminals A, C, B or V W & V respectively.
- 4.7.4. Permanently attached diagram and instruction plate made preferably of stainless steel shall be mounted inside terminal box cover giving the connection diagram for the desired direction of rotation and reverse rotation.
- 4.7.5. Motor terminals and terminal leads shall be fully insulated with no bar live parts. Adequate space shall be available inside the terminal box so that no difficulty is encountered for terminating the cable specified in Data Sheet-A.
- 4.7.6. Degree of protection for terminal boxes shall be IP 55 as per IS 4691.
- 4.7.7. Separate terminal boxes shall be provided for space heaters.. If this is not possible in case of LV motors, the space heater terminals shall be adequately segregated from the main terminals in the main terminal box. Detachable gland plates with double compression brass glands shall be provided in terminal boxes.
- 4.7.8. Phase terminal boxes shall be suitable for 360 degree of rotation in steps of 90 degree for LV motors.
- 4.7.9. Cable glands and cable lugs as per cable sizes specified in Data Sheet-A shall be included. Cable lugs shall be of tinned Copper, crimping type.
- 4.8. Two separate earthing terminals suitable for connecting G.I. or MS strip grounding conductor of size given in Data Sheet-A shall be provided on opposite sides of motor frame. Each terminal box shall have a grounding terminal.



TITLE :
GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS

SPECIFICATION NO.
PE-SS-999-506-E101
VOLUME NO. : **II-B**
SECTION : **D**
REV NO. : **00** DATE : 28.01.10
SHEET : 4 OF 4

4.9 General

- 4.9.1 Motors provided for similar drives shall be interchangeable.
- 4.9.2 Suitable foundation bolts are to be supplied alongwith the motors.
- 4.9.3 Motors shall be provided with eye bolts, or other means to facilitate safe lifting if the weight is 20Kgs. and above.
- 4.9.4 Necessary fitments and accessories shall be provided on motors in accordance with the latest Indian Electricity rules 1956.
- 4.9.5 All motors rated above 30 kW shall be provided with space heaters to maintain the motor internal air temperature above the dew point. Unless otherwise specified, space heaters shall be suitable for a supply of 240V AC, single phase, 50 Hz.
- 4.9.6 Name plate with all particulars as per IS: 325 shall be provided
- 4.9.7 Unless otherwise specified, the colour of finish shall be grey to Shade No. 631 and 632 as per IS:5 for motors installed indoor and outdoor respectively. The paint shall be epoxy based and shall be suitable for withstanding specified site conditions.

5.0 INSPECTION AND TESTING

- 5.1 All materials, components and equipments covered under this specification shall be procured, manufactured, as per the BHEL standard quality plan No. PED-506-00-Q-006/0 and PED-506-00-Q-007/2 enclosed with this specification and which shall be complied.
- 5.2 LV motors of type-tested design shall be provided. Valid type test reports not more than 5 year shall be furnished. In the absence of these, type tests shall have to be conducted by manufacturer without any commercial implication to purchaser.
- 5.3 All motors shall be subjected to routine tests as per IS: 325 and as per BHEL standard quality plan.
- 5.4 Motors shall also be subjected to additional tests, if any, as mentioned in Data Sheet A.

6.0 DRAWINGS TO BE SUBMITTED AFTER AWARD OF CONTRACT

- a) OGA drawing showing the position of terminal boxes, earthing connections etc.
- b) Arrangement drawing of terminal boxes.
- c) Characteristic curves:
(To be given for motor above 55 kW unless otherwise specified in Data Sheet).
- i) Current vs. time at rated voltage and minimum starting voltage.
- ii) Speed vs. time at rated voltage and minimum starting voltage.
- iii) Torque vs. speed at rated voltage and minimum voltage.
For the motors with solid coupling the above curves i), ii), iii) to be furnished for the motors coupled with driven equipment. In case motor is coupled with mechanical equipment by fluid coupling, the above curves shall be furnished with and without coupling.
- iv) Thermal withstand curve under hot and cold conditions at rated voltage and max. permissible voltage.



B - 3


L.T. POWER CABLES

LARA SUPER THERMAL POWER PROJECT, STAGE-I (2X800 MW)
DARLIPALI SUPER THERMAL POWER PROJECT, STAGE-I (2X800 MW)
GAJMARA SUPER THERMAL POWER PROJECT, STAGE-I (2X800 MW)
KUDGI SUPER THERMAL POWER PROJECT, STAGE-I (3X800 MW)
STEAM TURBINE GENERATOR PACKAGE

TECHNICAL SPECIFICATION
SECTION-VI
PART-B


299

208

CLAUSE NO.	TECHNICAL REQUIREMENTS			
LT POWER CABLES				
1.00.00	CODES & STANDARDS			
1.01.00	<p>All standards, specifications and codes of practice referred to herein shall be the latest editions including all applicable official amendments and revisions. In case of conflict between this specification and those (IS : codes, standards, etc.) referred to herein, the former shall prevail. All the cables shall conform to the requirements of the following standards and codes:</p> <p>IS :1554 - I PVC insulated (heavy duty) electric cables for working voltages upto and including 1100V.</p> <p>IS : 3961 Recommended current ratings for cables</p> <p>IS : 3975 Low carbon galvanised steel wires, formed wires and tapes for armouring of cables.</p> <p>IS : 5831 PVC insulation and sheath of electrical cables.</p> <p>IS:7098 (Part -I) Cross linked polyethylene insulated PVC sheathed cables for working voltages upto and including 1100V.</p> <p>IS : 8130 Conductors for insulated electrical cables and flexible cords.</p> <p>IS : 10418 Specification for drums for electric cables.</p> <p>IS : 10810 Methods of tests for cables.</p> <p>ASTM-D -2843 Standard test method for density of smoke from the burning or decomposition of plastics.</p> <p>IEC-754 (Part-I) Tests on gases evolved during combustion of electric cables.</p> <p>IEC-332 Tests on electric cables under fire conditions. Part-3: Tests on bunched wires or cables (Category-B).</p>			
LARA STPP, STAGE-I (2X800 MW) DARLIPALJ STPP, STAGE-I (2X800 MW) GAJMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE		TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-3 L.T. POWER CABLES	PAGE 1 OF 8

300 300


(Handwritten marks)

CLAUSE NO.	TECHNICAL REQUIREMENTS															
2.00.00	TECHNICAL REQUIREMENTS															
2.01.00	The cables shall be suitable for laying on racks, in ducts, trenches, conduits and under ground buried installation with chances of flooding by water.															
2.02.00	Cables shall be flame retardant, low smoke (FRLS) type designed to withstand all mechanical, electrical and thermal stresses developed under steady state and transient operating conditions as specified elsewhere in this specification.															
2.03.00	Aluminium conductor used in power cables shall have tensile strength of more than 100 N/ sq.mm. Conductors shall be stranded.															
2.04.00	XLPE insulation shall be suitable for a continuous conductor temperature of 90 deg. C and short circuit conductor temperature of 250 deg C. PVC insulation shall be suitable for continuous conductor temperature of 70 deg C and short circuit conductor temperature of 160 deg. C.															
2.05.00	The cable cores shall be laid up with fillers between the cores wherever necessary. It shall not stick to insulation and inner sheath. All the cables, other than single core unarmoured cables, shall have distinct extruded PVC inner sheath of black colour as per IS : 5831.															
2.06.00	<p>For single core armoured cables, armouring shall be of aluminium wires/ formed wires. For multicore armoured cables, armouring shall be of galvanised steel as follows :</p> <table border="1" data-bbox="534 1254 1204 1568"> <thead> <tr> <th data-bbox="534 1254 758 1310">Calculated nominal dia. of cable under armour</th> <th data-bbox="758 1254 1204 1310">Size and Type of armour</th> </tr> </thead> <tbody> <tr> <td data-bbox="534 1321 758 1355">Upto 13 mm</td> <td data-bbox="758 1321 1204 1355">1.4mm dia GS wire</td> </tr> <tr> <td data-bbox="534 1366 758 1400">Above 13 & upto 25mm</td> <td data-bbox="758 1366 1204 1400">0.8 mm thick GS formed wire / 1.6 mm dia GS wire</td> </tr> <tr> <td data-bbox="534 1411 758 1444">Above 25 & upto 40 mm</td> <td data-bbox="758 1411 1204 1444">0.8mm thick GS formed wire / 2.0mm dia GS wire</td> </tr> <tr> <td data-bbox="534 1456 758 1489">Above 40 & upto 55mm</td> <td data-bbox="758 1456 1204 1489">1.4 mm thick GS formed wire /2.5mm dia GS wire</td> </tr> <tr> <td data-bbox="534 1500 758 1534">Above 55 & upto 70 mm</td> <td data-bbox="758 1500 1204 1534">1.4mm thick GS formed wire / 3.15mm dia GS wire</td> </tr> <tr> <td data-bbox="534 1545 758 1579">Above 70mm</td> <td data-bbox="758 1545 1204 1579">1.4 mm thick GS formed wire / 4.0 mm dia GS wire</td> </tr> </tbody> </table>		Calculated nominal dia. of cable under armour	Size and Type of armour	Upto 13 mm	1.4mm dia GS wire	Above 13 & upto 25mm	0.8 mm thick GS formed wire / 1.6 mm dia GS wire	Above 25 & upto 40 mm	0.8mm thick GS formed wire / 2.0mm dia GS wire	Above 40 & upto 55mm	1.4 mm thick GS formed wire /2.5mm dia GS wire	Above 55 & upto 70 mm	1.4mm thick GS formed wire / 3.15mm dia GS wire	Above 70mm	1.4 mm thick GS formed wire / 4.0 mm dia GS wire
Calculated nominal dia. of cable under armour	Size and Type of armour															
Upto 13 mm	1.4mm dia GS wire															
Above 13 & upto 25mm	0.8 mm thick GS formed wire / 1.6 mm dia GS wire															
Above 25 & upto 40 mm	0.8mm thick GS formed wire / 2.0mm dia GS wire															
Above 40 & upto 55mm	1.4 mm thick GS formed wire /2.5mm dia GS wire															
Above 55 & upto 70 mm	1.4mm thick GS formed wire / 3.15mm dia GS wire															
Above 70mm	1.4 mm thick GS formed wire / 4.0 mm dia GS wire															
<table border="1" data-bbox="395 1668 1219 1756"> <tr> <td data-bbox="395 1668 750 1756"> LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE </td> <td data-bbox="750 1668 965 1756"> TECHNICAL SPECIFICATION SECTION-VI PART-B </td> <td data-bbox="965 1668 1141 1756"> SUB-SECTION-B-3 LT. POWER CABLES </td> <td data-bbox="1141 1668 1219 1756"> PAGE 2 OF 8 </td> </tr> </table>			LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-3 LT. POWER CABLES	PAGE 2 OF 8										
LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-3 LT. POWER CABLES	PAGE 2 OF 8													

2

300

301


CLAUSE NO.	TECHNICAL REQUIREMENTS		
2.06.01	The aluminium used for armouring shall be of H4 grade as per IS: 8130 with maximum resistivity of 0.028264 ohm mm ² per meter at 20 deg C. The sizes of aluminium armouring shall be same as indicated above for galvanized steel.		
2.06.02	The gap between armour wires / formed wires shall not exceed one armour wire / formed wire space and there shall be no cross over / over-riding of armour wire / formed wire. The minimum area of coverage of armouring shall be 90%. The breaking load of armour joint shall not be less than 95% of that of armour wire / formed wire. Zinc rich paint shall be applied on armour joint surface of G.S.wire/ formed wire.		
2.07.00	<p>Outer sheath shall be of PVC as per IS: 5831 & black in colour. In addition to meeting all the requirements of Indian standards referred to, outer sheath of all the cables shall have the following FRLS properties.</p> <p>(a.) Oxygen index of min. 29 (as per IS 10810 Part-58).</p> <p>(b.) Acid gas emission of max. 20% (as per IEC-754-I).</p> <p>(c.) Smoke density rating shall not be more than 60 % (as per ASTM-D-2843).</p>		
2.08.00	<p>Cores of the cables shall be identified by colouring of insulation. Following colour scheme shall be adopted:</p> <p>1 core - Red, Black, Yellow or Blue</p> <p>2 core - Red & Black</p> <p>3 core - Red, Yellow & Blue</p> <p>4 core - Red, Yellow, Blue and Black</p>		
2.09.00	For reduced neutral conductors, the core shall be black.		
2.10.00	<p>In addition to manufacturer's identification on cables as per IS, following marking shall also be provided over outer sheath.</p> <p>(a.) Cable size and voltage grade - To be embossed</p> <p>(b.) Word 'FRLS' at every 5 metre - To be embossed</p> <p>(c.) Sequential marking of length of the cable in metres at every one metre -To be embossed / printed</p> <p>The embossing shall be progressive, automatic, in line and marking shall be legible and indelible.</p>		
LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJIMARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE		TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-3 L.T. POWER CABLES PAGE 3 OF 8

302

301

2

2


CLAUSE NO.	TECHNICAL REQUIREMENTS	
2.11.00	All cables shall meet the fire resistance requirement as per Category-B of IEC 332 Part-3.	
2.12.00	Allowable tolerances on the overall diameter of the cables shall be +1-2 mm maximum, over the declared value in the technical data sheets.	
2.13.00	In plant repairs to the cables shall not be accepted. Pimples, fish eye, blow holes etc. are not acceptable.	
3.00.00	Cable selection & sizing	
3.01.00	<p>LT Power cables shall be sized based on the following considerations:</p> <p>(a) Rated current of the equipment</p> <p>(b) The voltage drop in the cable, during motor starting condition, shall be limited to 10% and during full load running condition, shall be limited to 3% of the rated voltage</p> <p>(c) Short circuit withstand capability</p> <p>This will depend on the feeder type. For a fuse protected circuit, cable should be sized to withstand the let out energy of the fuse. For breaker controlled feeder, cable shall be capable of withstanding the system fault current level for total breaker tripping time inclusive of relay pickup time.</p> <p>(d) The minimum conductor size shall be 6 sqmm for aluminium conductor cables and 2.5 sqmm for copper conductor cables. The constructional details of copper conductor cables shall be same as indicated for copper control cable.</p>	
302.00	<p>Derating Factors</p> <p>Derating factors for various conditions of installations including the following shall be considered while selecting the cable sizes:</p> <p>a) Variation in ambient temperature for cables laid in air</p> <p>b) Grouping of cables</p> <p>c) Variation in ground temperature and soil resistivity for buried cables.</p>	
3.03.00	Cable lengths shall be considered in such a way that straight through cable joints are avoided.	
3.04.00	Cables shall be armoured type if laid in switchyard area or directly buried.	
LARA STPP, STAGE-I (2X800 MW) DARLIPALI STPP, STAGE-I (2X800 MW) GAJWARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-3 LT. POWER CABLES PAGE 4 OF 8



2

309


303

303

CLAUSE NO.	TECHNICAL REQUIREMENTS	
3.05.00	All LT power cables of sizes more than 120 sq.mm. shall be XLPE insulated and preferable sizes are 1Cx150, 1Cx300, 1Cx630, 3Cx150 & 3Cx240 sq.mm.	
4.00.00	<p>CONSTRUCTIONAL FEATURES</p> <p>(a) 1.1 KV grade XLPE power cables shall have compacted aluminium conductor, XLPE insulated, PVC inner sheathed (as applicable), armoured/ unarmoured, FRLS PVC outer sheathed conforming to IS:7098. (Part-I).</p> <p>(b) 1.1KV grade PVC power cables shall have aluminium conductor (compacted type for sizes above 10 sq.mm), PVC Insulated, PVC inner sheathed, armoured/ unarmoured, FRLS PVC outer sheathed conforming to IS:1554 (Part-I).</p>	
5.00.00	<p>CABLE DRUMS</p> <p>(a) Cables shall be supplied in non returnable wooden or steel drums of heavy construction. The surface of the drum and the outer most cable layer shall be covered with water proof cover. Both the ends of the cables shall be properly sealed with heat shrinkable PVC/ rubber caps secured by 'U' nails so as to eliminate ingress of water during transportation, storage and erection. Wood preservative anti-termite treatment shall be applied to the entire drum. Wooden drums shall comply with IS: 10418.</p> <p>(b) Each drum shall carry manufacturer's name, purchaser's name, address and contract number, item number and type, size and length of cable and net gross weight, stencilled on both sides of the drum. A tag containing same information shall be attached to the leading end of the cable. An arrow and suitable accompanying wording shall be marked on one end of the reel indicating the direction in which it should be rolled.</p> <p>(c) The standard drum length for power cables shall not be less than 500 meters. The length per drum shall be subjected to a maximum tolerance of +/- 5% of the standard drum length. The Employer shall have the option of rejecting cable drum with shorter lengths. For each size, the variance of total quantity, adding all the supplied drum lengths, from the ordered quantity, shall not exceed +/- 2%.</p>	
5.00.00	TYPE TESTS	
5.01.00	<p>General</p> <p>All equipments to be supplied shall be of type tested design. During detailed engineering, the contractor shall submit for Owner's approval the reports of all the type tests as listed in this specification and carried out within last ten years from the</p>	
LARA STPP, STAGE-I (2X800 MW) DARJIPALI STPP, STAGE-I (2X800 MW) GAJHARA STPP, STAGE-I (2X800 MW) KUDGI STPP, STAGE-I (3X800 MW) STEAM TURBINE GENERATOR PACKAGE	TECHNICAL SPECIFICATION SECTION-VI PART-B	SUB-SECTION-B-3 LT. POWER CABLES
PAGE 5 OF 8		


308
304
~~308~~


QUALITY PLAN		CUSTOMER :				PROJECT TITLE			SPECIFICATION :		
SHEET 1 OF 9		BIDDER/ VENDOR SYSTEM CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	SECTION AGENCY	NUMBER :		VOLUME III REMARKS
SL. NO.	COMPONENT/OPERATION	3	4	5	6	7	8	9	10	11	
		CHARACTERISTIC CHECK				QUALITY PLAN NUMBER PED-506-Q-007/2	ITEM: AC ELECT. MOTORS 75KW & ABOVE (LV & MV)		P	W	V
1	2	3	4	5	6	7	8	9	10	11	
1.0	RAW MATERIAL & BROUGHT CONTROL										
1.1	SHEET STEEL, PLATES, SECTION, EYEBOLTS	1.SURFACE CONDITION	MA	VISUAL	100%	-	FREE FROM BLINKS, CRACKS, WAVINESS ETC	LOG BOOK	3	-	-
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	MANFR'S DRG./SPEC	MANFR'S DRG./SPEC	-DO-	3	-	-
		3.PROOF LOAD TEST (EYE BOLT)	MA	MECH. TEST	-DO-	-DO-	-DO-	INSPEC. REPORT	3	-	-
1.2	HARDWARES	1.SURFACE CONDITION	MA	VISUAL	100%		FREE FROM CRACKS, UN-EVENNESS ETC.	-DO-	3	-	-
		2.PROPERTY CLASS	MA	VISUAL	SAMPLES	MANFR'S DRG./SPEC BOOK	RELEVANT IS/SPEC.	SUPPLIERS TC & LOG	3	-	2
		1.SURFACE CONDITION	MA	VISUAL	100%		FREE FROM CRACKS, BLOW HOLES ETC.	LOG BOOK	3	-	-
1.3	CASTING	2.CHEM. & PHY. PROP.	MA	CHEM & MECH TEST	1/HEAT NO.	MANFR'S DRG./SPEC	RELEVANT IS/	SUPPLIERS TC	3	-	2
		3.DIMENSIONS	MA	MEASUREMENT	100%	MANFR'S DRG.	MANUF'R'S DRG.	LOG BOOK	3	-	-
1.4	PAINT & VARNISH	1.MAKE, SHADE, SHELF LIFE & TYPE	MA	VISUAL	100% CONTINUOUS	MANFR'S DRG./SPEC	MANFR'S DRG./SPEC	LOG BOOK	3	-	-
BHEL											
PARTICULARS											
NAME											
SIGNATURE											
DATE											
BIDDER'S/VENDORS COMPANY SEAL											


		CUSTOMER :				PROJECT				SPECIFICATION :				
		QUALITY PLAN		BIDDER/ VENDOR		TITLE		NUMBER :		SPECIFICATION :		TITLE		NUMBER :
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	SECTION AGENCY	P	W	V	VOLUME III	REMARKS
1	2	3	4	5	6	7	8	9	10				11	
1.5	SHAFT (FORGED OR ROLLED)	1. SURFACE COND. 2. CHEM. & PHYSICAL PROPERTIES 3. DIMENSIONS 4. INTERNAL FLOWS	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	-	-		VENDOR'S APPROVAL IDENTIFICATION SHALL BE MAINTAINED
1.6	SPACE HEATERS, CONNECTORS, TERMINAL BLOCKS, CABLES, CABLE LUGS, CARBON BRUSH TEMP. DETECTORS, RTD, BTD'S	1. MAKE & RATING 2. PHYSICAL COND. 3. DIMENSIONS (WHEREVER APPLICABLE) 4. PERFORMANCE/ CALIBRATION	MA	CHEM. & PHYSICAL TESTS	1/HEAT NO. OR HEAT TREATMENT BATCH NO	MFG. DRG. SPEC.	RELEVANT IS	SUPPLIER'S TC	3	-	2	-		
			MA	MEASUREMENT	100%	-DO-	MANUF'R'S DRG.	LOG BOOK	3	-	-	-		
			CR	UT	-DO-	ASTM-A388	MANUF'R'S SPEC. BHEL SPEC.	-DO-	3	2	1	-		FOR DIA OF 55 MM & ABOVE
			MA	VISUAL	-DO-	MANUF'R'S DRG. SPEC.	MANUF'R'S DRG. SPEC.	-DO-	3	-	-	-		
			MA	-DO-	-DO-	-	NO BREAKAGE ON OTHER PHY. DESIGN	-DO-	3	-	-	-		
			MA	MEASUREMENT	SAMPLE	MANUF'R'S DRG/ SPEC.	MANUF'R'S DRG. / SPEC.	-DO-	3	-	-	-		
			MA	TEST	100%	-DO-	-DO-	INSP. REPORT	3	-	-	-		
BHEL														
PARTICULARS														
NAME														
SIGNATURE														
DATE														
BIDDER/VENDOR														
BIDDER'S/VENDORS COMPANY SEAL														

SL. NO.		COMPONENT/OPERATION		QUALITY PLAN CHARACTERISTIC CHECK		CUSTOMER :			PROJECT TITLE			SPECIFICATION :					
						BIDDER/VENDOR SYSTEM CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	QUALITY PLAN NUMBER PED-506-00-Q-007/2	ITEM: AC ELECT. MOTORS 75KW & ABOVE (LV & MV)	SECTION AGENCY	NUMBER :	TITLE	REMARKS
		3	4	5	6	7	8	9	10		11						
1																	
1.7	OTHER INSULATING MATERIALS LIKE SLEEVES, BINDINGS CORDS, PAPERS, PRESS BOARDS ETC.	1. SURFACE COND. 2. OTHER CHARACTERISTICS	MA	VISUAL	100%	-	NO VISUAL DEFECTS	INSPT. REPORT	3	-							
1.8	SHEET STAMPING (PUNCHED)	1. SURFACE COND. 2. DIMENSIONS INCLUDING BURS HEIGHT 3. ACCEPTANCE TESTS	MA	TEST	SAMPLE	MANUF'S SPEC.	MANUF'S SPEC.	LOG BOOK AND OR SUPPLIER'S TC	3	-	2						
1.9	CONDUCTORS	1. SURFACE FINISH 2. ELECT. PROP. & MECH. PROP	MA	VISUAL	100%	MEASUREMENT	NO VISUAL DEFECTS (FREE FROM BURS)	LOG BOOK	3	-							
			MA	ELECT. & MECH TESTS	-DO-	MANUF'S SPEC./RELEVANT IS	MANUF'S DRG.	-DO-	3	-	2						
			MA	VISUAL	100%		RELEVANT IS	SUPPLIER'S TC	3	-	2						
			MA	ELECT. & MECH. TEST	SAMPLES	RELEVANT IS/BS OR OTHER STANDARDS	RELEVANT IS/BS OR OTHER STANDARDS	SUPPLIERS TC & VENDOR'S INSPN. REPORTS	3/2	-	2						
BHEL																	
PARTICULARS												BIDDER/VENDOR					
NAME																	
SIGNATURE																	
DATE																	
												BIDDER'S/VENDORS COMPANY SEAL					

SPECIFICATION :		CUSTOMER :		PROJECT :		SPECIFICATION :	
NUMBER :		TITLE :		TITLE :		NUMBER :	
TITLE :		TITLE :		TITLE :		TITLE :	
SECTION :		SECTION :		SECTION :		SECTION :	
AGENCY :		AGENCY :		AGENCY :		AGENCY :	
REMARKS :		REMARKS :		REMARKS :		REMARKS :	
VOLUME III :		VOLUME III :		VOLUME III :		VOLUME III :	
REMARKS :		REMARKS :		REMARKS :		REMARKS :	
P		W		V		V	
10		10		10		10	
11		11		11		11	
QUALITY PLAN		QUALITY PLAN		QUALITY PLAN		QUALITY PLAN	
NUMBER PED-506-00-Q-007/2		NUMBER PED-506-00-Q-007/2		NUMBER PED-506-00-Q-007/2		NUMBER PED-506-00-Q-007/2	
ITEM: AC ELECT. MOTORS 75KW & ABOVE (LV & MV)		ITEM: AC ELECT. MOTORS 75KW & ABOVE (LV & MV)		ITEM: AC ELECT. MOTORS 75KW & ABOVE (LV & MV)		ITEM: AC ELECT. MOTORS 75KW & ABOVE (LV & MV)	
FORMAT		FORMAT		FORMAT		FORMAT	
OF RECORD		OF RECORD		OF RECORD		OF RECORD	
ACCEPTANCE		ACCEPTANCE		ACCEPTANCE		ACCEPTANCE	
NORM		NORM		NORM		NORM	
8		8		8		8	
9		9		9		9	
10		10		10		10	
11		11		11		11	
1.10		1.10		1.10		1.10	
BEARINGS		BEARINGS		BEARINGS		BEARINGS	
3.DIMENSIONS		3.DIMENSIONS		3.DIMENSIONS		3.DIMENSIONS	
1.MAKE & TYPE		1.MAKE & TYPE		1.MAKE & TYPE		1.MAKE & TYPE	
2.DIMENSIONS		2.DIMENSIONS		2.DIMENSIONS		2.DIMENSIONS	
3.SURFACE FINISH		3.SURFACE FINISH		3.SURFACE FINISH		3.SURFACE FINISH	
1.11		1.11		1.11		1.11	
SLIP RING		SLIP RING		SLIP RING		SLIP RING	
1.SURFACE COND.		1.SURFACE COND.		1.SURFACE COND.		1.SURFACE COND.	
2.DIMENSIONS		2.DIMENSIONS		2.DIMENSIONS		2.DIMENSIONS	
3.TEMP.WITH-STAND CAPACITY		3.TEMP.WITH-STAND CAPACITY		3.TEMP.WITH-STAND CAPACITY		3.TEMP.WITH-STAND CAPACITY	
4.HV/IR		4.HV/IR		4.HV/IR		4.HV/IR	
1.12		1.12		1.12		1.12	
OIL SEALS & GASKETS		OIL SEALS & GASKETS		OIL SEALS & GASKETS		OIL SEALS & GASKETS	
1.MATERIAL OF GASKET		1.MATERIAL OF GASKET		1.MATERIAL OF GASKET		1.MATERIAL OF GASKET	
2.SURFACE COND.		2.SURFACE COND.		2.SURFACE COND.		2.SURFACE COND.	
3.DIMENSIONS		3.DIMENSIONS		3.DIMENSIONS		3.DIMENSIONS	
PARTICULARS		PARTICULARS		PARTICULARS		PARTICULARS	
BHEL		BHEL		BHEL		BHEL	
NAME		NAME		NAME		NAME	
SIGNATURE		SIGNATURE		SIGNATURE		SIGNATURE	
DATE		DATE		DATE		DATE	
BIDDER/VENDOR		BIDDER/VENDOR		BIDDER/VENDOR		BIDDER/VENDOR	
BIDDER'S/VENDORS COMPANY SEAL		BIDDER'S/VENDORS COMPANY SEAL		BIDDER'S/VENDORS COMPANY SEAL		BIDDER'S/VENDORS COMPANY SEAL	


SL. NO.		COMPONENT/OPERATION		QUALITY PLAN CHARACTERISTIC CHECK		CUSTOMER :				PROJECT TITLE				SPECIFICATION :								
						BIDDER/ VENDOR SYSTEM	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY	SECTION	VOLUME III	REMARKS	NUMBER :	TITLE	AGENCY	SECTION	VOLUME III	REMARKS
		SHEET 5 OF 9		3		4		5		6		7		8		9		10		11		
1		2																				
2.0	IN PROCESS					MA	VISUAL	100%	-DO-		GOOD FINISH	LOG BOOK										
2.1	STATOR FRAME WELDING (IN CASE OF FABRICATED STATOR)		1.WORKMANSHIP & CLEANNESS		MA	MA	MEASUREMENT	-DO-	MANUFS DRG		MANUFS DRG	-DO-										
			2.DIMENSIONS		MA	MA	VISUAL	100%	-DO-		GOOD FINISH	LOG BOOK										
2.2	MACHINING		1.FINISH		MA	MA	MEASUREMENT	-DO-	MANUFS DRG		MANUFS DRG	-DO-										
			2.DIMENSIONS		MA	MA	MEASUREMENT	-DO-	MANUFS DRG		MANUFS DRG	-DO-										
			3.SHAFT SURFACE FLOWS		MA	MA	PT	-DO-	RELEVANT SPEC./ ASTM-E165		MANUFS SPEC./ BHEL SPEC./	-DO-										
2.3	PAINTING		1.SURFACE PREPARATION		MA	MA	VISUAL	100%	MANFR'S SPEC./BHEL SPEC./ RELEVANT STAND		BHEL SPEC. SAME AS COL.7	LOG BOOK										
			2.PAINT THICKNESS (BOTH PRIMER & FINISH COAT)		MA	MA	MEASUREMENT BY ELCOMETER	SAMPLE	-DO-		-DO-	-DO-										
			3.SHADE		MA	MA	VISUAL	-DO-	-DO-		-DO-	Log Book										
			4.ADHESION		MA	MA	CROSS CUTTING & TAPE TEST	-DO-	-DO-		-DO-	Log Book										
BHEL																						
PARTICULARS						BIDDER/VENDOR																
NAME																						
SIGNATURE																						
DATE																						
BIDDER'S/VENDORS COMPANY SEAL																						

CUSTOMER :		PROJECT		SPECIFICATION :							
BIDDER/ VENDOR SYSTEM		TITLE		NUMBER :							
QUALITY PLAN		QUALITY PLAN		SPECIFICATION :							
SHEET 6 OF 9		NUMBER PED-506-00-Q-007/2		TITLE							
COMPONENT/OPERATION		ITEM: AC ELECT. MOTORS 75KW & ABOVE (LV & MV)		SECTION							
CHARACTERISTIC CHECK		REFERENCE DOCUMENT		AGENCY							
CAT.		EXTENT OF CHECK		P W V							
TYPE/ METHOD OF CHECK		ACCEPTANCE NORM		REMARKS							
3		6		10							
4		7		11							
1	2	3	4	5	6	7	8	9			
2.4	SHEET STACKING	1.COMPLETENESS	MA	MEASUREMENT	SAMPLE	MANUFR'S SPEC.	MANUFR'S SPEC.	Log Book	3	-	-
		2.COMPRESSION & TIGHTENING	MA	MEASUREMENT	100%	-DO-	-DO-	Log Book	3	-	-
		3.CORE LOSS & HOTOPOT	MA	ELECT.TEST	-DO-	-DO-	-DO-	Log Book	3	-	2
2.5	WINDING	1.COMPLETENESS	CR	VISUAL	100%	MANUFR'S SPEC./BHEL SPEC.	MANUFR'S SPEC./BHEL SPEC.	Log Book	3	-	-
		2.CLEANLINESS	CR	-DO-	-DO-	-DO-	-DO-	Log Book	3	-	-
		3.IR-HV-IR	CR	ELECT. TEST	-DO-	-DO-	-DO-	Log Book	3	-	-
		4.RESISTANCE	CR	-DO-	-DO-	-DO-	-DO-	Log Book	3	-	2
		5.INTERTURN INSULATION	CR	-DO-	-DO-	-DO-	-DO-	Log Book	3	2	-
		6.SURGE WITH STAND AND TAN DELTA TEST	CR	-DO-	-DO-	-DO-	-DO-	Log Book	3	2	1
2.6	IMPREGNATION	1.VISCOSITY	MA	PHY. TEST	AT STARTING	-DO-	-DO-	Log Book	3	-	-
		2.TEMP. PRESSURE VACCUM	MA	PROCESS CHECK	CONTINUOUS	-DO-	-DO-	Log Book	3	-	-
		3.NO. OF DIPS	MA	-DO-	-DO-	-DO-	-DO-	Log Book	3	-	2
											THREE DIPS TO BE GIVEN
BHEL		PARTICULARS		BIDDER/VENDOR							
		NAME		SIGNATURE							
		DATE									
										BIDDER/ VENDORS COMPANY SEAL	

		CUSTOMER :				PROJECT TITLE				SPECIFICATION NUMBER :			
		BIDDER/VENDOR SYSTEM		QUALITY PLAN NUMBER PED-506-00-Q-007/2		ACCEPTANCE NORM		FORMAT OF RECORD		VOLUME III REMARKS			
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEP. NORM	FORMAT OF RECORD	SECTION AGENCY	SECTION P	SECTION W	SECTION V	REMARKS
1	2	3	4	5	6	7	8	9	10	11			
3.0	TESTS	1. TYPE TESTS INCLUDING SPECIAL TESTS AS PER BHEL SPEC. 2. ROUTINE TESTS INCLUDING SPECIAL TEST AS PER BHEL SPEC. 3. VIBRATION 4. OVERALL DIMENSIONS AND ORIENTATION 5. DEGREE OF PROTECTION 6. NAMEPLATE DETAILS 7. EXPLOSION FLAME PROOF NESS (IF SPECIFIED) 8. PAINT SHADE, THICKNESS & FINISH	MA	ELECT. TEST	1/TYPE/SIZE	IS-325/ BHEL SPEC./ DATA SHEET	IS-325/ BHEL SPEC./ DATA SHEET	TEST REPORT	3	1	1,2		NOTE - 1
			MA	-DO-	100%	-DO-	-DO-	-DO-	3	1,2	1,2		NOTE - 2
			MA	-DO-	100%	IS-12075	IS-12075	-DO-	3	1,2	-		
			MA	MEASUREMENT & VISUAL	100%	APPROVED DRG/DATA SHEET	APPROVED DRG/DATA SHEET & RELEVANT IS	INSPC. REPORT	3	2,1	-		
			MA	ELECT. & MECH. TEST	1/TYPE/ SIZE	RELEVANT IS	BHEL SPEC. AND DATA SHEET	TC	3	-	2,1		TC FROM AN INDEPENDENT LABORATORY NOTE-3
			MA	VISUAL	100%	IS-325 & DATA SHEET	IS-325 & DATA SHEET	INSPC. REPORT	3	2,1	-		
			MA	EXPLOSION FLAME PROOF TEST	1/TYPE	IS-3682 IS-8239 IS-8240	IS-3682 IS-8239 IS-8240	TC	3	-	2,1		NOTE-3
			MA	VISUAL & MEASUREMENT BY ELKOMETER	SAMPLE	BHEL SPEC. & DATA SHEET	BHEL SPEC. & DATA SHEET	TC	3	2,1	-		SAMPLING PLAN TO BE DECIDED BY INSPECTION AGENCY
BHEL													
PARTICULARS													
NAME													
SIGNATURE													
DATE													
BIDDER/VENDOR													
BIDDER'S/VENDORS COMPANY SEAL													

		CUSTOMER :		PROJECT TITLE		SPECIFICATION NUMBER :				
		BIDDER/ VENDOR SYSTEM		QUALITY PLAN NUMBER PED-506-00-Q-007/2		SPECIFICATION TITLE				
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	SECTION AGENCY	VOLUME III REMARKS
1	2	3	4	5	6	7	8	9	10	11
<p>NOTES:</p> <p>1 DEPENDING UPON THE SIZE AND CRITICALLY, WITNESSING BY BHEL SHALL BE DECIDED.</p> <p>2 ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON.</p> <p>3 IN CASE TEST CERTIFICATES FOR THESE TESTS ON SIMILAR TYPE, SIZE AND DESIGN OF MOTOR FROM INDEPENDENT LABORATORY ARE AVAILABLE, THESE TEST MAY NOT BE REPEATED.</p> <p>4 WHEREVER CUSTOMER IS INVOLVED IN INSPECTION WITH THE CUSTOMERS, AGENCY (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER.</p>										
BHEL		PARTICULARS		BIDDER/VENDOR						
		NAME								
		SIGNATURE								
		DATE								
						BIDDER'S/VENDORS COMPANY SEAL				

CUSTOMER :		PROJECT		SPECIFICATION :							
QUALITY PLAN		TITLE		NUMBER :							
SHEET 1 OF 2		QUALITY PLAN		SPECIFICATION							
BIDDER/ VENDOR SYSTEM		NUMBER PED-508-00-Q-006/0		TITLE							
CAT.		ITEM AC ELECT. MOTORS BELOW 75KW (LV)		SECTION VOLUME III							
CHARACTERISTICS CHECK		REFERENCE DOCUMENT		AGENCY							
SHEET 1 OF 2		ACCEPTANCE NORM		P W V							
COMPONENT/OPERATION		EXTENT OF CHECK		FORMAT OF RECORD							
2		4		5							
3		6		7							
8		9		10							
11											
REMARKS											
1	1.0 PAINTING	MA	VISUAL	SAMPLE	MANUF'S SPEC/BHEL SPEC./RELEVANT STANDARD	BHEL SPEC. SAME AS COL.7	LOG BOOK	3	-	-	11
2.0	ASSEMBLY	MA	VISUAL	100%	MANUF'S SPEC	MANUF'S SPEC	-DO-	3	-	-	
		MA	-DO-	-DO-	MFG. DRG./ MFG. SPEC.	MFG. DRG./ MFG. SPEC.	-DO-	3	-	-	
		MA	VISUAL	100%	MFG SPEC./ RELEVANT IS	MFG SPEC./ RELEVANT IS	-DO-	3	-	-	
3.0	TESTS	MA	-DO-	100%	IS-325/ BHEL SPEC./ DATA SHEET	SAME AS COL.7	TEST REPORT	3	2,1	2,1	NOTE-1
		MA	MEASUREMENT & VISUAL	100%	APPROVED DRG/DATA SHEET	APPROVED DRG/DATA SHEET & RELEVANT IS	INSPN. REPORT	2	1	-	
BHEL		PARTICULARS		BIDDER/VENDOR							
		NAME									
		SIGNATURE									
		DATE									
										BIDDER'S/VENDORS COMPANY SEAL	

		QUALITY PLAN				CUSTOMER :			PROJECT TITLE				SPECIFICATION :	
COMPOONENT/OPERATION		SHEET 2 OF 2				BIDDER/ VENDOR			QUALITY PLAN				NUMBER :	
CHARACTERISTICS CHECK		SYSTEM CAT.				EXTENT OF CHECK			ITEM AC ELECT. MOTORS BELOW 75KW (LV)				TITLE :	
SL. NO.	3	4	5	6	7	8	9	10	11	SECTION AGENCY		VOLUME III REMARKS		
	3	4	5	6	7	8	9	10	11	P	W	V		
1	3.NAMEPLATE DETAILS	MA	VISUAL	100%	IS-325 & DATA SHEET	IS-325 & DATA SHEET	INSPN. REPORT			3	1	-		
NOTES: 1 ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON 2 WHERE EVER CUSTOMER IS INVOLVED IN INSPECTION, (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER. 3 FOR EXHAUST/VENTILATION FAN MOTORS OF RATING UPTO 1.5KW , ONLY ROUTINE TEST CERTIFICATES SHALL BE FURNISHED FOR SCRUTINY.														
BHEL														
PARTICULARS														
NAME														
SIGNATURE														
DATE														
BIDDER'S/VENDORS COMPANY SEAL														