

**IB THERMAL POWER STATION, BANHARPALI
2 X 660 MW UNITS 3&4**

VOLUME -IIB

**TECHNICAL SPECIFICATION
FOR
MISCELLANEOUS PUMPS**

Specification No. : PE-TS-391-100-N001 (REV. 0)



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
PPEI BUILDING, SECTOR 16 A
NOIDA - 201301**



1.0 The tender document contains three (3) volumes. The bidder shall meet the requirements of all the three volumes.

1.1 Volume I - CONDITIONS OF CONTRACT

This consists of four parts as below:

Volume - I A : This part contains instructions to bidders for making bids to BHEL.

Volume - I B : This part contains general commercial conditions of the tender and include provision that vendor shall be responsible for the quality of item supplied by their sub-vendors.

Volume - I C : This part contains special conditions of contract.

Volume - I D : This part contains commercial conditions for erection and commissioning site work, as applicable.

1.2 Volume II - TECHNICAL SPECIFICATIONS

Technical requirements are stipulated in Volume II which comprises of:

Volume - II A : General Technical Conditions

Volume - II B : Technical specification including drawings, if any

1.2.1 Volume - II B :

This volume is sub-divided into following sections:

Section - A : This section outlines the scope of enquiry.

Section - B : This section provides "Project Information"

Section - C : This section indicates technical requirements specific to the contract, not covered in Section-D.

Section - D : This section comprises of technical specifications of equipments complete with data sheet A, B & C.

Data sheet - A specifies data and other requirements pertaining to the equipment.


Data sheet - B specifies data to be filled by the bidder (Data Sheet B is contained in Volume - III)

Data sheet - C indicates data documents to be furnished after the award of contract as per agreed schedule by the vendor (as applicable).

1.2.2 Volume - III TECHNICAL SCHEDULES

This volume contains technical schedules and Data Sheets - B, which are to be duly filled by the bidder and the same shall be furnished with the technical bid as per checklist, sec B7 in vol III.


2.0 The requirements mentioned in Section C/Data Sheets-A of Section-D shall prevail and govern in case of conflict between the same and the corresponding requirements mentioned in the descriptive portion in Section - D.

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001	
	MISCELLANEOUS PUMPS	REV. NO.	0	DATE: 12.08.2014

INDEX


SECTION	TITLE
---------	-------

- | | |
|----|---|
| A | SCOPE OF ENQUIRY |
| B | PROJECT INFORMATION |
| C | SPECIFIC TECHNICAL REQUIREMENTS FOR |
| C1 | PUMPS |
| C2 | MOTORS |
| D | STANDARD TECHNICAL SPECIFICATIONS FOR |
| D1 | PUMPS |
| | <ul style="list-style-type: none"> ▪ STANDARD TECHNICAL SPECIFICATIONS FOR HORIZONTAL PUMPS- NO. PE-TS-179-06 ▪ DATA SHEETS-A FOR ABOVE PROJECT ALONGWITH LIST OF MANDATORY SPARES & WATER ANALYSIS. ▪ DATA SHEET - C ▪ STANDARD QUALITY PLAN FOR PUMPS |
| D2 | MOTORS |
| | <ul style="list-style-type: none"> ▪ STANDARD TECHNICAL SPECIFICATION FOR MOTORS ▪ DATA SHEET-A ▪ STANDARD QUALITY PLAN FOR MOTORS |

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	A
		REV. NO.	0	DATE:	12.08.2014

SECTION A

SCOPE OF INQUIRY

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS SCOPE OF ENQUIRY	VOLUME:	IIB	SECTION:	A
		REV. NO.	0	DATE:	12.08.2014

1.0 SCOPE

- 1.1 This enquiry covers the design, manufacture, assembly, inspection and testing at manufacturer's and/or his sub-contractors works, proper packing for delivery and installation checks and replacement of gland packing with Mechanical Seal arrangement (if applicable) at site for Miscellaneous Pumps along with mandatory spares complete with all accessories as per the requirements specified in this specification for following project.

IB THERMAL POWER STATION, BANHARPALI
2 X 660 MW UNITS 3&4

The bidder's scope shall also include any other services, etc. if called for in the succeeding sections of the specification.

- 1.2 The miscellaneous pumps covered under this specification shall be Horizontal pumps.


NOTE:-


- a) **The bidder shall include complete supplies for the Project/Group as above in his scope. Part supplies offered for the Project/Group shall disqualify the bidder's offer for that Project/Group.**

- 1.3 The pumps erected by the purchaser shall be checked by the bidder for correctness of their installation, alignment, etc. at site prior to their commissioning. Replacement of gland packing with Mechanical Seal (If applicable) as per Cl. No. 2.0 of Section C1 & Cl. No. 9.08.04 of section D of this volume. The charges for these shall be included by bidder in his base price, itself.
- 1.4 The miscellaneous pumps and drives covered under this specification for various projects are as per Annexure I. HT drives, wherever applicable and irrespective of motor ratings, shall be issued free of cost by BHEL. The details of pumps with HT drives shall be as per Annexure II.
- The Capacity, Head, Materials of construction, Mandatory spares and other particulars of these pumps, are detailed in Data Sheet-A annexed with Section-D of the specification.
- 1.5 For detailed scope of supply & services refer clause 3.00.00 of Standard technical Specification for Horizontal Centrifugal pumps specified under Section-D of this volume.
- 1.6 Electrical scope between BHEL and Vendor for Miscellaneous pumps and drives of this specification shall be as per annexure I of section C-2 of this volume.

2.0 GENERAL TECHNICAL INSTRUCTIONS

- 2.1 It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship, and shall be capable of performing the required duties in a manner acceptable to Engineer/Owner who will interpret the meaning of drawings and specifications and shall be entitled to reject any component or material, which in his judgement is not in full accordance herewith.

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS SCOPE OF ENQUIRY	VOLUME:	IIB	SECTION:	A
		REV. NO.	0	DATE:	12.08.2014
2.2	The omission of specific reference to any component/accessory necessary for the proper performance of Miscellaneous Pumps and drives shall not relieve the bidder of the responsibility of providing such facilities to complete the supply of equipment at quoted prices.				
2.3	BHEL's / Customer's representative shall be given full access to the shop in which the equipments are being manufactured or tested and all test records shall be made available to him.				
2.4	The equipments covered under this specification shall not be despatched unless the same have been finally inspected, accepted and shipping release issued by BHEL/Customer.				
2.5	<i>In case of any deviation from this technical specification (Vol.IIB) and General Technical Conditions (Vol.II A), the same shall be indicated in the schedule of deviations enclosed in Vol.III. In the absence of duly filled schedules it will be assumed that the bid strictly conforms to the specification.</i>				
2.6	Unpriced copy of the price bid shall be furnished alongwith the technical bid.				


	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	A
	SCOPE OF ENQUIRY	REV. NO.	0	DATE:	12.08.2014

Annexure I

List of Miscellaneous Pumps and drives for :

A. 2x660MW IB Valley TPS, BANHARPALI

Sl. No.	Pump Description	Total Qty.	Type of Pumps
	Horizontal Pumps (Group I)		
1	DMCW TG Aux's Pumps	6 nos.	Horizontal
2	DMCW SG Aux's Pumps	4 nos.	Horizontal
3	ACW Pumps	4 nos.	Horizontal
4	CYCLE MAKE-UP Pumps	3 nos.	Horizontal
5	BOILER FILL Pumps	2 nos.	Horizontal
6	Compressor cooling water pumps	1 nos.	Horizontal


	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	A
	SCOPE OF ENQUIRY	REV. NO.	0	DATE:	12.08.2014

Annexure II

Following HT drives for IB VALLEY TPS, 2x660MW UNITS 3&4, irrespective of Motor ratings shall be issue free, by BHEL:


Horizontal Pumps (Group I)

- 1 DMCW TG Aux's Pumps
- 2 DMCW SG Aux's Pumps
- 3 ACW Pumps

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	B
		REV. NO.	0	DATE:	12.08.2014

SECTION B


PROJECT INFORMATION

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
		VOLUME:	IIB	SECTION:	B1
	MISCELLANEOUS PUMPS	REV. NO.	0	DATE:	12.08.2014

SECTION B1

PROJECT INFORMATION


**IB THERMAL POWER STATION, BANHARPALI
2 X 660 MW UNITS 3&4**


 OPGC Odisha Power Generation Corporation Ltd.	Odisha Power Generation Corporation Ltd.	Technical Specification for Main Plant Package	IB TPS – 2 X 660 MW Units 3 &4, Jharsuguda, Odisha
---	--	--	--

VOLUME: IIA

SECTION-III

PROJECT SYNOPSIS AND GENERAL INFORMATION



 Odisha Power Generation Corporation Ltd.	Technical Specification for Main Plant Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	---

VOLUME : IIA

SECTION-III

PROJECT SYNOPSIS AND GENERAL INFORMATION

1.00.00 INTRODUCTION

The proposed Thermal Power Station comprising of 2 x 660 MW base unit size, Super-Critical Units would be set up by Odisha Power Generation Corporation Limited (OPGCL) in the Jharsuguda district of Odisha, India. OPGCL had already installed two units of 210 MW each adjacent to the proposed units under Phase-I of the project at IB Thermal Power Station and the units have been working for the last fifteen years.

Seller has acquainted himself by visiting to the site, with the conditions prevailing at site. The information given here in under is for general guidance and shall not be contractually binding on the Buyer. All relevant site data /information as may be necessary shall have to be obtained/ collected by the Seller.

2.00.00 APPROACH TO SITE

The project site is located at Banaharpalli in the Jharsuguda district of Odisha on the bank of Hiraakud Reservoir and about 20 km south of Belpahar railway station and 40 km south west of Jharsuguda. The main Howrah-Mumbai railway line passes 20 km north of the plant (at Belpahar). NH-200 (Chandikhole to Raipur) and SH-10 (Sambalpur to Sundergarh) pass through Jharsuguda town.

OPGCL has a private railway siding connecting the plant to the Indian Railways network at Lajkura Railway station.

Nearest Airport – Bhubaneswar.

Nearest Seaport – Paradeep/ Haldia.

3.00.00 LAND

The total land proposed to be required (around 40 Ha) taking into account the locations of various facilities and plant auxiliaries for units 3 & 4 under IB Thermal Power Station 2 x 660 MW units 3 & 4 and also future 2 x 660 MW will be as per the Plot Plan enclosed in Volume II-L. Land for the proposed units have already been acquired and Power block area is fairly flat land sloping towards South to South -West with contour variation from RL 204.00 M to RL 199.00 M. The Seller shall accommodate equipment offered under this specification generally within the spaces allocated for such equipment in the Plot Plan. Specific approval from Consultant shall be taken by the Seller prior to any revision or relocation.





Doc. No. : K8B09-MP-SPC-G-001

V.IIA/S-III : 1

Development Consultants Pvt. Ltd.

(2. K8B09-MP-V-II-A-LEA1_OPGC_CONTRACT-BHEL.docx)



	Odisha Power Generation Corporation Ltd.	Technical Specification for Main Plant Package	IB.TPS – 2 X 660 MW Units 3 &4, Jharsuguda, Odisha
---	--	--	--

4.00.0 SOURCE OF COAL

Coal will be the primary fuel for the proposed project. OPGC has been allotted with two coal blocks (Manoharpur and Dip-side of Manoharpur) in IB valley area with an estimated total reserve of 531.68 Million Metric Tons for captive use of the projects. Manoharpur coal block has been explored fully and has net geological reserves of 181.68 Million Metric Tons and Dip side of Manoharpur (Regionally explored) has geological reserves of 350 Million Metric Tons approximately.

Manoharpur Coal Block is about 45 Km away from Sundargarh Town along Sundargarh – Hemgiri road which passes near the block. It is also connected by black top road with two important towns of Odisha viz. Rourkela (145 Km) and Jharshuguda (75 Km). The nearest Railway station is Hemgiri, lying on the Mumbai – Howrah main line and is about 20 Km away from Manoharpur Block. Coal from the mine to the power plant will be transported by dedicated merry-go-round rail system.

5.00.00 SOURCE OF WATER

Water is drawn from the Hirakud reservoir through a 5.45 Km intake channel. The reservoir has a catchment area of 83.395 sq.km. with a current gross storage capacity of 7189 lakhs m³. The project too will meet its water requirements from the Hirakud reservoir through the existing intake structure, which is sufficient to cater to the proposed project. The project had taken approval from the Water Resources Department of Odisha to draw 5400 m³/hr of water from the reservoir, which will cater the requirement of Phase-I (existing 2 x 210 MW) and the proposed units of 2x660 MW.

The Power station will operate on semi open recirculating condenser cooling system using cooling towers. In addition all water conservation and recycling measures will be adopted to minimize requirement of make up water. The proposed project will adopt zero effluent discharge philosophy.



6.00.00 ASH DISPOSAL AREA

Not Used.

7.00.00 METEOROLOGICAL DATA


7.01.00 For the purpose of equipment design, the following Ambient Conditions / Meteorological data of site (Jharsuguda) shall be taken into consideration:-

Site elevation above MSL	:	199.5 M
Highest temp recorded	:	48.0 °C.
Lowest temp recorded	:	4.0 °C.
Monthly max. dry bulb temp	:	38.9 °C/28.0 °C/33.4 °C (Summer/winter/monsoon)





Doc. No. : K8B09-MP-SPC-G-001	V.IIA/S-III : 2	Development Consultants Pvt. Ltd.
-------------------------------	-----------------	-----------------------------------

(2. K8B09-MP-V-II-A-LEA1_OPGC_CONTRACT-BHEL.docx)

	Odisha Power Generation Corporation Ltd.	Technical Specification for Main Plant Package	IB TPS – 2 X 660 MW Units 3 &4, Jharsuguda, Odisha
---	--	--	--

Monthly min. dry bulb temp	:	25.4 °C/16.7 °C/26.8 °C (Summer/winter/monsoon)
Monthly max. wet bulb temp	:	23.9 °C/17.8 °C/25.5 °C (Summer/winter/monsoon)
Monthly min. wet bulb temp	:	17.6 °C/13.4 °C/25.0 °C (Summer/winter/monsoon)
Maximum Relative Humidity	:	46% / 67% / 87% (Summer/winter/monsoon)
Minimum Relative Humidity	:	21% / 33% / 87% (Summer/winter/monsoon)
Average relative Humidity	:	65%
Average Annual Rainfall	:	1460 mm.
Normal period of rain fall	:	June – September.
Heaviest rainfall in 24 hours	:	257.8 mm
Wind direction	:	South West – North East.
Basic Wind Speed at 10 m Height	:	44 m/sec as per IS:875 Part-3 (1987).
Seismic Zone	:	Zone III as per IS:1893 Part-1 (2002).
Geographical location		: At Latitude 21° 48' North and Longitude 83° 52' East.



Doc. No. : K8B09-MP-SPC-G-001	V.IIA/S-III : 3	Development Consultants Pvt. Ltd.
-------------------------------	-----------------	-----------------------------------




	Odisha Power Generation Corporation Ltd.	Technical Specification for Main Plant Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Odisha
---	--	--	---

TABLE VI
DESIGN CLARIFIED WATER ANALYSIS

CONSTITUENTS	As	CONTENT
Calcium Hardness	CaCO ₃	90 ppm
Magnesium Hardness	CaCO ₃	40 ppm
Sodium and Potassium	CaCO ₃	42 ppm
Iron in Solution.	Fe	0.2 ppm
Hydrogen (FMA)	CaCO ₃	ppm
TOTAL CATIONS (Except iron in solution)	CaCO ₃	172 ppm
Bicarbonate	CaCO ₃	97 ppm
Carbonate	CaCO ₃	- ppm
Hydroxide	CaCO ₃	- ppm
Sulphate	CaCO ₃	60 ppm
Chloride	CaCO ₃	15 ppm
Nitrate	CaCO ₃	- ppm
Fluoride	CaCO ₃	- ppm
TOTAL ANIONS	CaCO ₃	172 ppm
M-Alkalinity	CaCO ₃	97 ppm
P-Alkalinity	CaCO ₃	ppm
Reactive Silica (Dissolved)	SiO ₂	6.0 ppm
Colloidal Silica	SiO ₂	9.0 ppm
Total Iron	Fe	0.2 ppm
Conductivity at 25 ^o C	-	200 Micro siemens/ cm (maximum)
Carbon-di-oxide	CO ₂	
pH value at 25 ^o C	-	7.5-8.5
Total Dissolved solids	-	200 ppm
Total Suspended solids	-	ppm (maximum)
Turbidity		10 NTU (maximum)
Oxygen absorbed at 27 ^o C for 4 hours		Traces ppm



Doc. No. : K8B09-MP-SPC-G-001	V.II/A/S-XII : 5	Development Consultants Pvt. Ltd.
-------------------------------	------------------	-----------------------------------


	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	C
		REV. NO.	0	DATE:	12.08.2014

SECTION C

SPECIFIC TECHNICAL REQUIREMENTS


C1: SPECIFIC TECHNICAL REQUIREMENTS FOR PUMPS


C2: SPECIFIC TECHNICAL REQUIREMENTS FOR MOTORS

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	C1
		REV. NO.	0	DATE:	12.08.2014

SECTION C1

SPECIFIC TECHNICAL REQUIREMENTS FOR PUMPS

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	C1
		REV. NO.	0	DATE:	12.08.2014
<p>1.0 SPECIFIC TECHNICAL REQUIREMENTS:</p> <p><u>DELIVERY:</u> Delivery of miscellaneous pumps shall be as per NIT requirement.</p> <p>2.0 <u>Horizontal Pumps:</u></p> <p>2.1 Horizontal Pumps with Mechanical seal shall be supplied with gland packing arrangement to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be despatched alongwith main supply for this purpose. Shaft sleeve and any other item required for satisfactory operation of Mechanical seal after replacement at site shall be provided by the pump supplier without any cost implication to BHEL.</p> <p>3.0 <u>Important Note:-</u></p> <p>3.1 MDCC after final inspection shall be provided to vendor on the basis of following:-</p> <p>3.1.1 List of items packed in each box with description & quantity.</p> <p>3.1.2 Photograph of each box in open & closed condition.</p> <p>3.2 Bidder to include handling instructions in engineering drg/doc and packing to be done in such a way to avoid damage of items in transit and long storage at site and same shall be approved in contract stage by BHEL/Customer.</p> <p>3.3 For detail despatch instruction, please refer Special Conditions of Contract (SCC) for the project.</p>					

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	C2
		REV. NO.	0	DATE:	12.08.2014

SECTION C2

SPECIFIC TECHNICAL REQUIREMENTS FOR MOTORS



**TECHNICAL SPECIFICATION FOR
MISC. PUMPS
(ELECTRICAL PORTION)**

SPECIFICATION NO.
VOLUME II B
SECTION-C
REV DATE 12.08.2014
PAGE 1 OF 1

SPECIFIC TECHNICAL REQUIREMENTS: ELECTRICAL

1.0 EQUIPMENT & SERVICES TO BE PROVIDED BY BIDDER/ PURCHASER

- 1.1 Scope for supply, and erection & commissioning of various equipment forming part of electrical system for this package shall be as per Annexure-I to Section – C [Scope of Work (Electrical)].
- 1.2 Make of various equipment/ items in the scope of bidder shall be to approval of owner during detailed engineering stage without any commercial implications.
- 1.3 Bidder shall furnish all AC as well as DC loads required for the system at different voltage levels (e.g. 415V AC, 240 V AC, 220 V DC etc.) of all types, such as motor feeders, supply feeders in PEM format along with the offer.
- 1.4 All electrical equipment shall be suitable for the power supplies, fault levels and climatic conditions indicated in project information enclosed with the specification.
- 1.5 All drawings, data sheets, Quality Plan, calculations, test reports, test certificates, etc. shall be submitted during detailed engineering stage as per formats enclosed. The same shall be subject to approval without any commercial implications.
- 1.6 Technical requirements shall be as per specifications listed in Clause 4.1 to 4.5. In case of any discrepancy between Basic technical Feature for HT or LT motors and BHEL standard specification, basic technical feature for HT or LT motors shall prevail.

3.0 DOCUMENTS TO BE SUBMITTED ALONG WITH BID

- 3.1 Bidder shall confirm total compliance to the electrical specification without any deviation from the technical/ quality assurance requirements stipulated. In line with this, the bidder as technical offer shall furnish two signed and stamped copies of the following:
 - a) A copy of this sheet "Electrical Equipment Specification for Misc. Pumps and sheet "Electrical Scope between BHEL and Vendor" with bidder's signature and company stamp.
 - b) List of Erection and Commissioning spares.
 - c) List of Erection & Maintenance tools & tackles.
 - d) Electrical load requirement in the load data format.
- 3.2 No technical submittal such as copies of data sheets, drawings, write-up, quality plans, type test certificates, technical literature, etc, is required during tender stage. Any such submission even if made, shall not be considered as part of offer.

4.0 LIST OF ENCLOSURES

- 4.1 Electrical scope between BHEL & vendor (Annexure-I).
- 4.2 Technical specification no. PE-SS-999-506-E101, Data Sheets (A & C) for 415V Electric Motors.
- 4.3 Quality Plan for motors.
- 4.4 Basic Technical Feature of HT/LT motors.
- 4.5 Load data format (Annexure-II).

ANNEXURE – I TO SECTION – C: STANDARD ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR

PACKAGE: MISC PUMPS

PROJECT: 2X660 MW OPGCL IB Valley TPS

S.NO	DETAILS	SCOPE SUPPLY	SCOPE E&C	REMARKS
1	415V MCC	BHEL ^{\$}	BHEL ^{\$}	1. 415 V AC/240 V AC supply shall be provided by BHEL based on load data provided by vendor at contract stage for all equipment supplied by vendor as part of contract including power supply equipment (battery charger etc) required for the PLC/control panel (as applicable) for the system supplied by vendor. 2. Interposing relays (RE 302 of Jyoti make or equivalent), if required for PLC and microprocessor based systems, shall be provided by BHEL in MCCs. Requirement of these relays shall be furnished by vendor during detailed engineering stage.
2	Local Push Button Station (for motors)	BHEL ^{\$}	BHEL ^{\$}	Located near the motor.
3	Power cables, control cables and screened control cables for a) both end equipment in BHEL's scope b) both end equipment in vendor's scope c) one end equipment in vendor's scope	BHEL ^{\$} Vendor BHEL ^{\$}	BHEL ^{\$} Vendor BHEL ^{\$}	1. Sizes and quantity of cables required shall be informed by vendor at contract stage (based on inputs provided by BHEL). Finalisation of cable sizes shall be done by BHEL. Vendor shall provide lugs & glands accordingly. 2. Laying of cables by BHEL except for cabling in vendor scope. 3. Termination at BHEL equipment terminals by BHEL. 4. Termination at Vendor equipment terminals by Vendor.
4	Any special type of cable like compensating, co-axial, prefab, MICC, fibre optical etc.	Vendor	Vendor	
5	Cable trays, accessories & cable trays supporting system	BHEL ^{\$}	BHEL ^{\$}	
6	Cable glands and lugs for equipments supplied by Vendor	Vendor	Vendor	1. Double compression Ni-Cr plated brass cable glands 2. Solder less crimping type heavy duty tinned copper lugs for power cables 3. Solder less crimping type heavy duty copper lugs for control cables.
7	Conduit and conduit accessories for cabling between equipments supplied by vendor	Vendor	Vendor	Conduits shall be medium duty, hot dip galvanised cold rolled mild steel rigid conduit as per IS: 9537. Makes of conduits shall be subject to customer/ BHEL approval at contract stage.
8	Lighting	BHEL ^{\$}	BHEL ^{\$}	
9	Equipment grounding & lightning protection	BHEL ^{\$}	BHEL ^{\$}	
10	Below grade grounding	BHEL ^{\$}	BHEL ^{\$}	
11	LT Motors with base plate and foundation hardware	Vendor	Vendor	Makes shall be subject to customer/ BHEL approval at contract stage.
12	Mandatory spares	Vendor	-	Vendor to quote as per specification.
13	Recommended O & M spares, E & C spares, erection &	Vendor	-	As per specification

ANNEXURE – I TO SECTION – C: STANDARD ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR

PACKAGE: MISC PUMPS

PROJECT: 2X660 MW OPGCL IB Valley TPS

S.NO	DETAILS	SCOPE SUPPLY	SCOPE E&C	REMARKS
	maintenance tools & tackle.			

NOTES:

1. Make of all electrical equipments/items supplied shall be reputed make & shall be subject to approval of BHEL/customer after award of contract.
2. All QPs shall be subject to approval of BHEL/customer after award of contract without any commercial implication.
3. For skid mounted system, 2 nos. (1W+1S) supply of 415 V, 3 phase, 4 wire AC shall be provided by BHEL/Customer. Complete skid including changeover between feeder/starters/LCP/inter-locks/protection devices / any other supply etc. shall be in bidder's scope only.
4. \$: Shall be in customer scope where equipment are supplied by customer.

2x660 MW IB TPS (UNIT-3 & 4), BANHARPALLI

BASIC TECHNICAL FEATURE FOR HT / LT MOTORS (FOR BHEL-PEM SCOPE PACKAGES)

BHEL DOC. NO. PE-DC-391-565-E003

REVISION 02



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
NOIDA, INDIA**



2x660 MW IB TPS (UNIT-3 & 4)

BANHARPALLI

BASIC TECHNICAL FEATURES FOR HT / LT MOTORS (FOR BHEL-PEM SCOPE PACKAGES)

Doc. No. PE-DC-391-565-E003

Rev. No. 02

Dated 24-12-2013

Page 1 of 6

1.0 This document covers the basic technical features of high tension (HT) and low tension (LT) squirrel cage induction AC motors employed for driving auxiliaries of BHEL-PEM scope packages in 2x660 MW IB TPS (UNIT-3 & 4) BANHARPALLI

2.0 CODES AND STANDARDS

The motors shall generally conform to IS 325/IEC-60034. LT motors of continuous duty (S1) shall be energy efficient IE2 conforming to IS-12615. For HT motors, efficiency (except for Mill motors and BCP) shall exceed 94% for all motors less than 2500HP (1865kW).

3.0 DESIGN REQUIREMENTS

3.1 General Requirements

The design ambient temperature shall be 50 deg C.

3.2 Supply system and rated voltage of motors

KW rating	Supply system	Rated voltage of motor
Above 1500 kW	11 KV	11 KV
Above 200 kW & upto 1500 kW	3.3 KV	3.3 KV
Above 200W and upto 200 kW	415 V	415 V
Upto 200W	240V	240V

3.2.1 Supply voltage & variations shall be as follows:-

Voltage variation (AC Supply) (+/-) 10%
Voltage variation (DC Supply) (+) 10% to (-) 15%
Frequency variation (+) 3% to (-) 5%
Combined V & F variation 10% (sum of absolute values)

3.2.2 Motors shall be capable of running continuously at rated output for each of the conditions specified.

3.3 Motor Rating


Motor ratings shall be adequate to meet the requirements of the drive equipment. Motors shall be continuously rated at the design ambient temperature of 50 deg C. Motor ratings shall have at least a 10% margin over the continuous maximum demand of the driven equipment at duty point or 10% margin over the continuous maximum demand of the driven equipment under entire operating range, whichever is higher.

3.4 Starting Requirements

3.4.1 Motor shall start smoothly and rapidly. Motor characteristics such as speed, starting torque, break away torque and starting time shall be properly co-ordinated with the requirements of driven equipment. The accelerating torque at any speed with the minimum starting voltage shall be at least 10% higher than that of the driven equipment.

3.4.2 Motors shall be capable of starting and accelerating the load with direct on line starting without exceeding acceptable winding temperature.

The limiting value of voltage at rated frequency under which a motor (except Mill Motors) will successfully start and accelerate to rated speed with load shall be taken to be a constant value of 80 (eighty) percent rated voltage.

	2x660 MW IB TPS (UNIT-3 & 4) BANHARPALLI BASIC TECHNICAL FEATURES FOR HT / LT MOTORS (FOR BHEL-PEM SCOPE PACKAGES)	Doc. No.	PE-DC-391-565-E003
		Rev. No.	02
		Dated	24-12-2013
		Page	2 of 6

3.4.3 The locked rotor current of the HT motors (except MDBFP motors & mill motors) shall not exceed six times full load current inclusive of tolerance as per IS:325. For LT motors of continuous duty (S1) type motors, starting current shall be as per IS: 12615.

3.4.4 The following frequency of starts shall apply

- i) Three cold starts in succession with the motor being initially at a temperature not exceeding the ambient temperature.
- ii) The motor shall be capable of two starts in succession with coasting to rest between starts and the motor initially at rated operating temperature.
- iii) Three equally spread starts in an hour the motor being initially at a temperature not exceeding the rated load operating temperature.(not to be repeated in the second successive hour)

3.4.5 Locked motor withstand time of hot motors at 110% rated voltage shall be as follows:

- a) For motors with starting time upto 20 sec.
- at least 2.5 sec. more than starting time.
- b) For motor with starting time above 20 secs
- at least 5.0 sec. more than starting time.

The starting time of the motor referred above is at minimum permissible voltage. For HT motors and in cases where the above requirements are not complied with, speed switches of approved make & type shall be provided to bypass the locked rotor protection for a pre-selected time during starting of motors. The speed switches shall have one NO & one NC contacts having maximum interrupting capacity of 5 Amps at 240V AC and 0.25 amps at 220 V DC.

3.5 Running Requirements

3.5.1 Motors shall run satisfactorily at a supply voltage of 75% of rated voltage for 5 minutes with full load without injurious heating to the motor.


3.5.2 Pull out torque at rated voltage shall not be less than 205% of full load torque. It shall be 275% for crane duty motors.

3.6 Stress During bus Transfer

3.6.1 Motors shall withstand the voltage and torque stress developed due to the application of 150% of the rated voltage for at least 1 sec. caused due to vector difference between the motor residual voltage and the incoming supply voltage during occasional auto bus transfer.

3.6.2 Motor windings shall be adequately braced to satisfactorily withstand the mech. Stresses during above condition.

3.6.3 Motors shall be capable of withstanding heavy in-rush transient current caused by bus transfer without damage.

	2x660 MW IB TPS (UNIT-3 & 4) <u>BANHARPALLI</u> BASIC TECHNICAL FEATURES FOR HT / LT MOTORS (FOR BHEL-PEM SCOPE PACKAGES)	Doc. No.	PE-DC-391-565-E003
		Rev. No.	02
		Dated	24-12-2013
		Page	3 of 6

3.6.4 Motor and driven eqpt. Shafts shall be adequately sized to satisfactorily withstand transient torque under above condition.

3.7 Noise level

Maximum noise level measured at distance of 1.0 metres from the outline of motor shall not exceed 85 db(A) in line with IS 12065.

3.8 Vibration

The max. vibration velocity or double amplitude of motors vibration as measured at motor bearings shall be within the limits specified in IS:12075.

4.0 CONSTRUCTIONAL FEATURES

4.1 Degree of Protection

4.1.1 Indoor motors shall conform to degree of protection IP:54 as per IS:4691. Outdoor or semi-indoor motors shall conform to degree of protection IP:55 as per IS:4691 and shall be of weather-proof construction. The degree of protection for terminal boxes shall be IP 55 as per IS 4691.

4.1.2 The stator laminations shall be made from suitable silicon steel/magnetic steel sheet varnished on both sides and pressed to form a rigid core.

4.1.3 The rotor shall be of rigid cage construction with die cast aluminium / copper alloy / copper bars firmly wedged in bar slots and brazed to the end rings. The rotor cage shall be designed to operate satisfactorily under respective starting and load duty cycle.

4.2 Enclosure and Cooling

4.2.1 Motors shall generally have totally enclosed fan cooled (TEFC) enclosures, the method of cooling conforming to IC-0141 or IC-0151 of IS: 6362. Alternatively, motors may have Closed Air circuit Air (CACA) method of cooling conforming to IC-0161 of IS: 6362 or shall be totally enclosed tube ventilated (TETV) .

4.2.2 Motors shall not be provided with any electric or pneumatic operated external fan for cooling the motors.

4.2.3 Frames shall be designed to avoid collection of moisture and all enclosures shall be provided with facility for drainage at the lowest point.

4.3 Class of Insulation


HT/LT motors shall have class F insulation. The temperature rise of all motors shall be limited to the limits applicable to Class 'B' insulation. In case of continuous operation at extreme voltage limits, 10deg C rise above the temperature limits specified in IS: 325 shall be permissible.

4.4 Bearings

4.4.1 Horizontally mounted motors shall have grease lubricated ball/roller or sleeve bearings. For MV motors, the bearings shall be regreasable type and for LV motors, these bearings can be either sealed life lubricated type or regreasable type as per manufacturer's standard.

	2x660 MW IB TPS (UNIT-3 & 4) <u>BANHARPALLI</u> BASIC TECHNICAL FEATURES FOR HT / LT MOTORS (FOR BHEL-PEM SCOPE PACKAGES)	Doc. No.	PE-DC-391-565-E003
		Rev. No.	02
		Dated	24-12-2013
		Page	4 of 6

- 4.4.2 The vertical motors shall have a combined thrust and guide bearing on top and guide bearing at bottom. If the ball or roller bearings can take vertical thrust, thrust and guide bearing need not be provided.
- 4.4.3 After taking all motor driven eqpt. loads and thrust(if any) into account , the bearings shall be suitable for min. 20,000 working hours. Re-greasable bearings shall be provided with grease nipples and relief holes for on-line re-greasing and shall be suitable for 8000 working hours without changing of the grease.
- 4.4.4 The bearings of solidly coupled motors shall be of the same type as those of the driven equipment.
- 4.4.5 For motors upto 2 kW, double sealed type bearings shall be provided.
- 4.4.6 HT motors shall be provided with insulated end shield on non-driving end to prevent flow of shaft current.
- 4.5 Terminals and Terminal Boxes
- 4.5.1 Motors of rating 100 kW and above will be controlled by circuit breaker. For all motors below 50 kW by MCCB and for motors between 50 KW to 100 KW MCCB with E/F protection shall be used. The terminal box of motors shall be designed for the fault current of 44 kA, 0.25 secs and 50 kA, 0.25 secs for HT & LT motors respectively.
- 4.5.2 Unless otherwise specified or approved, phase terminal boxes of horizontal motors shall be positioned on the left hand side of the motor when viewed from the non-driving end.
- 4.5.3 For MV motors, the main terminal box shall be of phase-segregated type with clamping arrangement for the terminals.
- 4.5.4 Connections shall be such that when the supply leads R, Y & B are connected to motor terminals A B & C or U, V & W respectively, motor shall rotate in an anticlockwise direction when viewed from the non-driving end. Where such motors require clockwise rotation, the supply leads R, Y, B will be connected to motor terminals A,C,B or V, W & U respectively.
- 4.5.5 Permanently attached diagram and instruction plate made preferably of stainless steel shall be mounted inside terminal box cover giving the connection diagram for the desired direction of rotation and reverse rotation.
- 4.5.6 Motor terminals and terminal leads shall be fully insulated with no bar live parts.
- 4.5.7 Separate terminal boxes shall be provided for space heaters and temp. Indicators. If this is not possible in case of LT motors, the space heater terminals shall be adequately segregated from the main terminals in the main terminal box. Detachable gland plates with double compression tinned brass glands shall be provided in terminal boxes.
- 4.5.8 Phase terminal boxes shall be suitable for 360 degree of rotation in steps of 180.
- 4.5.9 Cable glands and cable lugs as per selected cable sizes shall be provided in line with cable erection philosophy. For single core cable termination, gland plates shall be of non-magnetic material.
- 4.6 Grounding

	2x660 MW IB TPS (UNIT-3 & 4) BANHARPALLI BASIC TECHNICAL FEATURES FOR HT / LT MOTORS (FOR BHEL-PEM SCOPE PACKAGES)	Doc. No.	PE-DC-391-565-E003
		Rev. No.	02
		Dated	24-12-2013
		Page	5 of 6

Two separate earthing terminals suitable for connecting G.I. or MS strip grounding conductor shall be provided on opposite sides of motor frame. Each terminal box shall have a grounding terminal.

4.7 General

4.7.1 Motors provided for similar drives shall be interchangeable.

4.7.2 An arrow block shall be screwed on the body of the motors on the non-driving end to indicate the direction of rotation of the motors.

4.7.3 Motors for Fuel oil unloading and drain oil pumps located in hazardous areas shall be with flame-proof enclosures in accordance with IS 2148 / IEC 60079.

5.0 ACCESSORIES

5.1 SPACE HEATERS

All motors rated 30KW and above shall be provided with space heaters to maintain the motor internal air temperature above the dew point. Space heaters shall be suitable for a supply of 240V AC, single phase, 50 Hz.

The leads from space heaters of each motor shall be brought out to a separate terminal Box. Space heaters shall be mounted inside the motor in accessible places so that their removal and replacement is simple.

5.2 RESISTANCE TEMPERATURE DETECTORS (RTDs)

5.2.1 HT motors stator windings shall be provided with 12 nos. (4 per phase) Simplex 3 wire Platinum RTDs with 100 ohms resistance at 0 deg C for remote monitoring of winding temperature. The leads from RTDs of each motor shall be brought out to a separate terminal Box.

5.2.2 For HT motors, each bearing shall be provided with 1 no. Duplex 3 wire Platinum RTDs with 100 ohms resistance at 0 deg C for remote monitoring of bearing temperature. The leads from these RTDs shall be brought out to a separate terminal Box or the terminal box same as for winding RTDs.


5.3 DIAL TYPE TEMP. INDICATORS

5.3.1 For HT motors, each bearing shall be provided with 1 no. Mercury-in-steel Dial type temperature indicator for local indication of bearing temperature. The indicators shall have 2 nos. NO contacts rated for 5A, 240 V AC and 0.5 A, 220 V DC for alarm/trip purpose.

5.4 Vibration monitoring pads


5.4.1 Provision shall be made in all HT motors for mounting vibration detectors.

6.0 NAME PLATE



Motors shall have stainless steel name plate with all particulars as per IS: 325. In addition, the following information shall be shown on motor rating plates:

- i) Temperature rise in deg.C under rated condition and method of measurement

	2x660 MW IB TPS (UNIT-3 & 4) <u>BANHARPALLI</u> BASIC TECHNICAL FEATURES FOR HT / LT MOTORS (FOR BHEL-PEM SCOPE PACKAGES)	Doc. No.	PE-DC-391-565-E003
		Rev. No.	02
		Dated	24-12-2013
		Page	6 of 6

- ii) Degree of protection (IP No.)
- iii) Bearing identification number and recommended lubricant.
- iv) Location of insulated bearings.

7.0 PAINTING

The paint shall be epoxy based. The colour of finish shall be light grey to Shade No. 631 as per IS: 5 for motors.

8.0 TESTING

8.1 Type Tests


For HT motors, type test as per IS: 325 shall be conducted on one motor of each type and rating.

For LT Motors, type test certificates for tests carried out earlier on similar ratings, frame size and make shall be submitted for type tests as per IS:325. However, if such reports are not available, one motor of each type and rating shall be subjected to type tests as per IS: 325.

For DOP test, test certificates for tests carried out earlier on similar equipment shall be submitted.

8.2 Routine Tests

All motors shall be subjected to routine tests as per IS: 325.


	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	D
		REV. NO.	0	DATE:	12.08.2014

SECTION D

STANDARD TECHNICAL SPECIFICATIONS

D1: STANDARD TECHNICAL SPECIFICATIONS FOR PUMPS

D2: STANDARD TECHNICAL SPECIFICATIONS FOR MOTORS

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	D1
		REV. NO.	0	DATE:	12.08.2014


SECTION D1


STANDARD TECHNICAL SPECIFICATIONS FOR HORIZONTAL PUMPS NO. PE TS-179-06


DATA SHEET A ALONGWITH LIST OF MANDATORY SPARES &
WATER ANALYSIS


DATA SHEET C


QUALITY PLAN


	TITLE:	SPECIFICATION NO. PES-179-06	
	STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 1 of 14	
1.00.00	GENERAL INFORMATION		
1.01.00	The general guidelines as illustrated in the subsequent clauses of this section shall be applicable for horizontal centrifugal pumps to be procured under the scope of this package.		
2.00.00	CODES AND STANDARDS		
2.01.00	In addition to the requirements spelt out elsewhere in the specification, the equipment to be provided under this section shall specifically conform to the following codes, standards, specifications and regulations, as applicable, including all the latest amendments subsequent to the year of publication as mentioned below.		
2.01.01	IS-1520/1980:	Horizontal Centrifugal pumps for clear, cold and fresh water.	
2.01.02	IS-5120/1977:	Technical requirements for Rotodynamic special Purpose pumps.	
2.01.03	IS-5639/1970:	Pumps for handling chemicals & corrosive liquids.	
2.01.04	IS-5659/1970:	Pumps for process water.	
2.01.05	IS-6536/1972:	Pumps for handling volatile liquids.	
2.01.06	IS-9137/1978:	Code for acceptance tests for centrifugal, mixed flow and axial flow pumps- Class 'C'.	
2.01.07	ISO 3555/1977: BS 5316/1977 Part 2	Acceptance test for centrifugal, mixed flow and axial flow pumps - Class 'B' tests.	
2.01.08	ISO 2548/1973: BS 5316/1976 Part 1	- Do - Class 'C' tests.	
2.01.09	API-610/1989:	Centrifugal pumps for general refinery services.	
2.01.10	HIS	Hydraulic Institute Standards, USA	
2.01.11	PTC 8.2/1965:	Power Test Codes - Centrifugal pumps.	
2.01.12	ASTM-1-165-55	Standard Methods for Liquid Penetration Inspection.	
2.02.00	In case of any contradiction with the above standards and annexure, the stipulations in the annexure shall prevail and shall be binding on the bidder.		


	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 2 of 14	
3.00.00	SCOPE OF SUPPLY & SERVICES:		
3.01.00	The miscellaneous pumps and drives scope shall be as specified in Data Sheet A /Section A.		
3.02.00	The Capacity, Head, Materials of construction and other particulars of pumps are detailed in Data Sheet A of the specification.		
3.03.00	Accessories:		
	All the pumps under this specification shall be complete with following standard/special accessories.		
3.03.01	Standard accessories:		
	a)	LT Electric drives/motors (as applicable) with cable gland and lugs at motor end. (The bare HT drive motors and LT motors not in bidder's scope of supply, wherever required supplied as free issue by BHEL refer Cl. 5.08.00).	
	b)	Pump motor coupling along with coupling guard.	
	c)	Common base plate for pumps and motor.	
	d)	Self contained lubrication system along with all internal piping, valves, fittings, specialties etc. as required.	
	e)	Counter flanges for suction/ discharge nozzles along with fixing nuts, bolts and gaskets.	
	f)	Anchor bolts, nuts, seating steel works, shims etc. as necessary for mounting the pump-motor unit on Civil foundations.	
	g)	Suitable vent (with valves)/ lifting/ handling attachments for the pump/ motor/ accessories.	
	h)	Suitable drain connections with isolating valves as applicable.	
	i)	Supply of first fill of lubricants with topping requirements for one year of operation after commissioning and handing over of equipment.	
	j)	Set of "Special" Tools & Tackles for Pumps and motors, if any.	
	k)	Erection and commissioning spares, "on as required" basis.	
	l)	Bidder shall provide various drawings, data, calculations, test reports/ certificates, operation and maintenance manuals, As-built drawings, etc. as specified and as necessary.	


	TITLE:	SPECIFICATION NO. PES-179-06	
	STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 3 of 14	
<p>m) Mandatory spares as specified in respective Data Sheet-A of this section.</p> <p>3.04.00 Services included in Bidder's Scope:</p> <p>3.04.01 The pumps shall be guaranteed to meet the performance requirements specified vide Data Sheet -A and also for trouble free operation after commissioning. Schedule of performance guarantees (enclosed in Volume-III) duly filled and signed shall be furnished with the bid.</p> <p>3.04.02 Pumps with Mechanical seal shall be supplied with gland packing arrangement initially to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be dispatched along with main supply for this purpose.</p> <p>3.04.03 The pumps erected by the purchaser shall be checked by the bidder for correctness of their installation, alignment, etc. at site prior to their commissioning.</p> <p>3.04.04 After commissioning of pumps at site, site performance test for Noise, vibration and parallel running of pumps of all pumps for each unit/project will be conducted by BHEL at project site to ensure that the pumps meet the specified requirements. In case of any deficiency, the vendor shall rectify the same at site at no additional cost to BHEL.</p> <p>3.04.05 Performance Guarantees for pumps shall stand valid till the satisfactory completion of performance testing by BHEL and its acceptance by purchaser / customer.</p> <p>3.05.00 Works excluded from Bidder's Scope:</p> <p>a) All HT motors and those LT Motors which are specifically excluded.</p> <p>b) Civil foundation</p> <p>c) Suction/ discharge pipe works</p> <p>d) MCC/ Switchgear/Power supply</p> <p>e) Power and Control Cables, unless specifically specified in Electrical/ Systems portion of the specification.</p> <p>f) Erection of equipments.</p> <p>4.00.00 BID EVALUATION CRITERIA & LIQUIDATED DAMAGES FOR SHORTFALL:</p> <p>4.01.00 The bids received shall be evaluated for power consumption at inlet to the motors, in respect of pumps specified in Data Sheet-A (working pump only viz. not the standby), for the purpose of price comparisons as briefed below:</p> <p>The bid evaluation shall be done at the rate as specified in Data Sheet A per one (1) KW Power consumption, per working pump as follows.</p> $\text{KW} = \frac{Q \times H \times S}{P \times M \times 367.2}$			


	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 4 of 14	
	<p>Where Q = Rated capacity M³/hr H = Rated TDH, MWC P = Pump Efficiency M = Motor Efficiency. S = Specific Gravity of fluid handled</p>		
4.02.00	<p>The efficiencies for pumps and motors for arriving at benchmark power for Bid Evaluation shall be as indicated in Data Sheet A for various pumps.</p> <p>No advantage shall be given to the bidder for Aux. Power quoted lower than the Bench mark values calculated with KW calculation formula at Cl. 4.01.00 above, considering the bid evaluation efficiencies for pump and motor as indicated in Data Sheet-A. However the bids shall be evaluated as above if the Aux. Power quoted are higher than Bench mark values.</p> <p>NOTE: 1. Efficiencies for HT motors and LT motors not in bidder's scope, for bid evaluation purpose shall be taken based on the maximum value as furnished in Data Sheet A. 2. During contract stage the Guaranteed power consumption of Pumps with BHEL supplied drives (HT/LT) for successful bidder shall be reworked by BHEL as below:</p> <p>Revised guarantee power consumption shall be as per KW calculation formula at Cl. 4.01.00 above, where P = pump efficiency guaranteed by bidder and M = motor efficiency as per approved datasheet of the supplied HT/LT motor.</p>		
4.03.00	<p>Liquidated damages for shortfall in Guaranteed KW</p> <p>The above guaranteed power consumption shall be demonstrated by the successful bidder during performance testing at works/ site.</p> <p>For pumps with BHEL supplied drives, the power consumption shall be compared with the reworked guarantee power consumption, defined as per note no. 2 of Cl. 4.02.00 above for the purpose of shortfall.</p> <p>The liquated damages @ twice the bid evaluation rate as above per KW per working pump shall be levied in the event of failure of bidder to demonstrate the guaranteed power consumption.</p>		
5.00.00	TECHNICAL REQUIREMENTS:		
5.01.00	<p>The pumps shall meet the technical requirements of section "D" as well as Data Sheet - A. Wherever there is contradiction between Section D and Data Sheet-A, the latter shall prevail. In the event of any contradiction of section "D" with Section-C, the Section-C will prevail.</p>		
5.02.00	<p>The pumps shall be Electric motor driven.</p>		


	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 5 of 14	
5.03.00	The Pumps shall conform to HIS. It is bare minimum requirement, however, any other equivalent or stringent standard is also acceptable, if, all the requirements of HIS are also met.		
5.04.00	The horizontal pumps shall be Horizontal split casing type with speeds not exceeding 1500 RPM or as indicated in Data Sheet-A.		
5.05.00	No negative tolerance shall be permitted in rated capacity & TDH.		
5.06.00	No negative tolerance shall be permitted in efficiency at rated capacity.		
5.07.00	<p>The shut off head of pumps shall be more than pump rated TDH and percentage variation may vary depending on the specific speed of the pump as under:</p> <ol style="list-style-type: none"> 10-15% for pumps of specific speed up to 1000 US units, 15-20% for pumps of specific speed in the range of 1000 to 2000 US units, 20-40% for pumps of specific speed in the range of 2000 to 4000 US units, Above 50% for pumps of specific speed in the range of 4000 to 7000 US units. 		
5.08.00	<p>All HT motors and those LT motors which are not in bidder's scope of supply : bare motors only, shall be supplied as free issue by BHEL through BHEL, based on ratings and TS (Torque - Speed) curve selected and furnished by the bidders along with their un-priced bid. The responsibility for satisfactory operation for combined performance of pumps & motors shall rest with the bidder only as if, the drive motors also have been supplied by the bidder.</p> <p>Couplings, base plate, foundation bolts, any other fittings, etc. as required shall be supplied by the bidders only. BHEL shall supply one number of each type of drive motors (where drive motor is not in bidder's scope of supply) for shop testing of pumps with job motors. All other motors shall be dispatched by BHEL directly to project sites.</p>		
5.09.00	<p>For all HT motor driven pumps, BHEL has envisaged vibration-monitoring system in their own scope. The bidder shall make provisions for mounting following on the pump/ pump shaft:</p> <ul style="list-style-type: none"> Purchaser's probes in both DE/NDE bearings of pumps Key slots on pump shaft with dimensions as specified in Data Sheet A. Other components as finalized during detailing. For mounting of above on the HT motors, same shall be taken care by BHEL - Bhopal. 		
5.10.00	The pumps shall be capable of developing the required total head at rated capacity for continuous operation. The pumps shall operate satisfactorily at any point on the Q-H characteristic curve over a range of 0% to 130% capacity and shall be suitable for continuous operation between 30% to 130% capacity.		


	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 6 of 14	
5.11.00	Selection of the pumps shall be such that the design point shall be met even with negative manufacturing tolerance.		
5.12.00	The total head capacity curve shall be continuously rising towards the shut off, the pumps shall preferably be non-overloading type and stable.		
5.13.00	The pumps shall be capable of running over the entire range of NPSH conditions required without any noise, vibration or cavitations. The prevailing suction pressures for various pumps are indicated in Data Sheet-A for suitable mechanical design of pumps.		
5.14.00	The pumps shall be of stiff shaft design. The minimum internal clearances should be sufficiently more than the max. static deflection of the shaft. Shaft size selected must take into consideration the critical speed as specified in API-610.		
5.15.00	Pumps and motors shall run smooth without undue noise and vibration. The vibration shall be within vibration norms for testing as per American National Standard for 'Rotodynamics Pump' for Vibration Measurement and allowable values, Doc. ANSI/ HIS 9.6.4-2009. The applicable vibration limits for each pump, shall be indicated in the Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO. The noise level shall be limited to 85 dB at distance of 1.0M.		
5.16.00	Pumps of a particular category shall be identical and shall be suitable for parallel operation with equal load division. Components of identical pumps shall be interchangeable.		
5.17.00	After installation, the guaranteed values of noise, vibration and parallel operation of pumps shall be tested and verified. If the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, at his own cost.		
5.18.00	High reliability of the pumps is an essential requirement and therefore it gets weightage over its efficiency. It is therefore essential that the bidder choose a standard proven model from the range of pumps manufactured.		
5.19.00	The offered pumps shall be of proven design meeting the experience-qualifying requirement of their operation at two sites for a minimum period of two years. Any deviation to this criterion shall be suitably highlighted in the deviations schedule.		
5.20.00	The bearings shall be self-water lubricated, no external water supply shall be available. The cooling/ lubrication water for bearings, etc. shall be tapped from the pump discharge and supplied thru' bidder's integral pipe work.		


	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 7 of 14	
<p>If water handled by pump is dirty/ not suitable for lubrication/ cooling, the bidder shall provide requisite strainer/ filters, tanks, motorized valves, etc. after the tap off for the required service, the arrangement provided shall be subject to Purchaser's approval.</p>			
<p>6.00.00 MANDATORY SPARES:</p>			
6.01.00	Bidder to provide the Mandatory spares listed vide Data Sheet-A. Unit price of mandatory spares shall be furnished in price Schedule.		
6.02.00	Bidder shall include the cost of Mandatory Spares in the base price of the pump, unless specified otherwise in Sec-C of the specification or NIT.		
<p>7.00.00 OTHER REQUIREMENTS:</p>			
7.01.00	The quality of water handled by various pumps shall be as per Data Sheet-A.		
7.02.00	The materials of construction for various components specified are the minimum requirements and materials of construction for other components not specified shall be similarly selected by the bidder for the intended duty.		
7.03.00	The makes of various bought out items of bidder (i.e. motor, bearings, mechanical seal etc.) shall be subject to purchaser's approval in the event of order.		
7.04.00	<p>Painting for Pumps</p> <p>a) The surface of SS, Gun metal, brass, bronze and non-metallic component shall not be applied with any painting.</p> <p>b) The Steel surface to be applied with painting shall be thoroughly cleaned before applying painting by brushing, shop blasting etc. as per the agreed procedure.</p> <p>c) For all the steel surfaces inside the (indoor installation) building, a coat of red oxide primes of min. thickness DFT of 50 microns followed up with under coat of Synthetic Enamel paint of min. thickness DFT of 50 microns shall be applied. The top coat shall consist of two coats each of min. thickness DFT of 50 microns of synthetic enamel paint and thus total DFT shall be min. 200 microns.</p> <p>d) For all the steel surfaces exposed to (outdoor installation) atmosphere, a coat of chlorinated rubber based zinc phosphate primer of min. thickness DFT of 50 microns followed up with under coat of chlorinated rubber paint of min. thickness DFT of 50 microns shall be applied. Then, intermediate coat consisting of one coat of chlorinated rubber based paint pigmented with Titanium di-oxide with min. thickness DFT of 50 microns and top coat shall consist of two coats each of min. thickness DFT of 50</p>		


	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 8 of 14	
<p>microns of chlorinated rubber paint shall be provided. Total DFT of paint system shall be min. 200 microns.</p>			
7.05.00	<p>It is mandatory for the bidder to submit along with the bid, the deviations if any – whether major or minor in the schedule of deviations only. In the absence of deviations listed in the “Schedule of deviations, the offer shall be deemed to be full conformity with the specification, “not-withstanding” anything else stated elsewhere in bidder’s offer. The implied/indirect deviations shall not be binding on the purchaser.</p>		
8.00.00	<p>PERFORMANCE REQUIREMENTS</p>		
8.01.00	<p>Performance requirements for the pumps shall be as guided in Data sheet - A enclosed with this section.</p>		
8.02.00	<p>Pump(s) shall preferably be designed to have the best efficiency at flow within $\pm 10\%$ of the specified duty point flow. The pumps shall be suitable for continuous operation at any point within the “Range of Operation” as stipulated in the Data Sheet - A attached with this section.</p>		
8.03.00	<p>Pump(s) shall preferably have a continuously rising head-capacity characteristics from the specified duty point towards shut-off point, the maximum being at shut-off to enable parallel operation.</p> <p>Under all circumstances, the ‘range of operation’ of the pumps shall exclude any unstable operating zone of the head-capacity curve.</p>		
8.04.00	<p>Wherever specified in the Data Sheet - A attached to this section, pumps of each category shall be suitable for parallel operation. The head vs. capacity, the BHP vs. capacity characteristics etc. shall be identical to ensure equal load sharing and trouble-free operation of any pump when the other pump(s) working in parallel with it trip.</p>		
8.05.00	<p>The pump set along with drive motor shall run smooth without undue noise and vibration. Acceptable vibration limits shall be guided by the HIS of USA. Refer clause 5.15.00 above for permissible limits.</p>		
9.00.00	<p>DESIGN AND CONSTRUCTION</p>		
9.01.00	<p>Pump Casing</p>		
9.01.01	<p>Pump casing shall be provided with adequate number of vents and priming connections with valves unless the pump is made self-venting and priming. Casing drain, as required, shall be provided complete with drain valves. It shall be provided with a connection for suction and discharge pressure gauge as standard feature.</p>		
9.01.02	<p>Pump design must ensure that the nozzles are capable of withstanding external reactions not less than those specified in API-610.</p>		


	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 9 of 14	
9.01.03	<p>In case where an expansion joint is located at pump discharge, the pump assembly will be subjected to an additional thrust which will be transmitted to the foundation. This additional thrust shall be taken into the consideration of pump design.</p>		
9.02.00	<p>Impeller</p>		
9.02.01	<p>The Impeller assembly shall be dynamically balanced and designed with critical speed substantially above the operating speed.</p>		
9.03.00	<p>Wearing Rings</p>		
9.03.01	<p>Replaceable type wearing rings shall be furnished to prevent damage to impeller and casing.</p>		
9.04.00	<p>Shaft</p>		
9.04.01	<p>Shaft size shall be selected considering that the critical speed shall be away from the operating speed as recommended in applicable Code/Standard. The critical speed shall be at least 30% higher than the rated speed.</p>		
9.05.00	<p>Shaft Sleeves</p>		
9.05.01	<p>Renewable type fine finished shaft sleeves shall be provided at the stuffing boxes/mechanical seals. Length of the shaft sleeves must extend beyond the other faces of gland packing or seal end plate so as to distinguish between the leakage past Shaft and shaft sleeve and that past the seals/glands.</p>		
9.05.02	<p>Shaft sleeves shall be properly fastened to the shaft to prevent any leakage or loosening. Shaft sleeve assembly should ensure concentric rotation.</p>		
9.06.00	<p>Bearings</p>		
9.06.01	<p>Bearings shall be easily accessible without disturbing the pump assembly. A drain shall be provided at the bottom of each bearing housing.</p>		
9.06.02	<p>Heavy-duty sleeve/ball/roller type bearings shall be provided to take care of the radial loads.</p>		
9.06.03	<p>In case of sleeve type radial, axial thrust shall be absorbed in suitable hydraulic devices and/or thrust bearings.</p>		
9.06.04	<p>Bearings and hydraulic devices (if provided for balancing axial thrust) shall be of adequate design for taking the entire pump load arising from all probable conditions of continuous operation. Life of the bearings shall be guided by the design standard of the pump. Antifriction bearings of standard type, if provided, shall be selected for a minimum</p>		

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 10 of 14	
	<p>life 20,000 hrs. of continuous operation at maximum axial and radial loads at rated speed. Thrust bearing shall be capable of running continuously at maximum load.</p>		
9.06.05	<p>The bearing shall be oil/grease lubricated. Suitable lubricating arrangement for the bearings shall be furnished with the pump complete with all accessories like pump, filters, piping, fittings, valves, interlocking and supervising instruments etc. as necessary. The design shall be such that the bearing lubricant does not contaminate the liquid being pumped.</p>		
9.06.06	<p>Bearings of reputed makes are to be provided, same shall be indicated in Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO, subject to acceptance of BHEL/ end customer, without any price implication to BHEL.</p>		
9.07.00	<p>Stuffing Boxes</p>		
9.07.01	<p>Stuffing box design shall permit replacement of packing without removing any part other than the gland.</p>		
9.07.02	<p>Stuffing boxes shall be sealed/cooled by the fluid being pumped/external clear water, as specified in the Annexure. All necessary pumps, piping, fittings, valves, instruments etc. as required for safe and trouble-free operation of the pumps and as specified in the Annexure shall be included in the scope of supply.</p>		
9.08.00	<p>Mechanical Seals</p>		
9.08.01	<p>Mechanical seals (cartridge type) shall be provided if specified in the Data Sheet-A of this section. The pump supplier shall co-ordinate with the seal maker in establishing the direct circulation rate for maintaining a stable film at the seal in the chamber. The seal piping system shall form an integral part of the pump assembly.</p>		
9.08.02	<p>When handling liquids near boiling point, suitable arrangement for external cooling shall be provided so as to prevent flashing at the seal faces.</p>		
9.08.03	<p>For the seals under vacuum service, the seal design must ensure sealing against atmospheric pressure, even when the pumps are not operating.</p>		
9.08.04	<p>Pumps with Mechanical seal shall be supplied with gland packing arrangement initially to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be dispatched along with main supply for this purpose. The special tools (if any) required for above shall be arranged by bidder.</p>		
9.08.05	<p>Mechanical seals of reputed makes are to be provided, same shall be indicated in Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO, subject to acceptance of BHEL/ end customer, without any price implication to BHEL.</p>		
9.09.00	<p>Drive Unit</p>		


	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME: II B	
		SECTION: D	
		REV. NO. 03	DATE: 16.07.2012
		SHEET 11 of 14	
9.09.01	The pumps shall be driven by electric motor directly coupled as specified in the Data Sheet-A of this section. A heavy duty coupling along with coupling guard shall be provided between the pump and drive unit.		
9.09.02	Unless otherwise specified in Data Sheet-A of this section, drive unit power rating shall be the maximum of the following requirements.		
	a) 15% margin over the pump shaft input power at the rated duty point.		
	b) 5% margin over the maximum pump shaft input power required within the 'Range of Operation'.		
	c) Pump shaft input power required considering the overloading of the pump assuming single pump operation in the event of tripping of one or more of the pumps operating in parallel.		
9.10.00	Coupling for pump & Motor Shaft		
9.10.01	The pump and motor shafts shall be connected with adequately sized flexible coupling of proven design with spacer to facilitate dismantling of the pump without disturbing the motor. Necessary coupling guard shall be provided.		
9.10.02	No. of coupling holes for joining coupling hubs shall be even in number and preferably in multiples of four.		
10.00.00	INSPECTION AND TESTING		
10.01.00	The Quality Plans enclosed in the specification are for bidder's guidance only. The bidder shall comply with these and other minimum requirements specified in the specification and shall furnish his own quality plan in the event of order based on the guidance given as above, for approval by BHEL/Customer.		
10.02.00	The Bidder shall carry out the following specific tests inspections to ensure that the equipment furnished lies in strict conformance with the specification and also in accordance with applicable codes/standards and good engineering practice.		
	a) Identification and Testing		
	i) All materials used for pump construction shall be of tested quality. Material shall be tested as per the relevant standard and test certificates shall be made available to the Owner.		
	ii) 100% PMI (Process Material Identification) inspection for material grade of pump casing, shaft and impeller shall be done by vendor & certification shall be submitted for review of BHEL. Further BHEL reserves the right to conduct		

	TITLE:	SPECIFICATION NO. PES-179-06
	STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	VOLUME: II B
		SECTION: D
		REV. NO. 03 DATE: 16.07.2012
		SHEET 12 of 14
<p>random & independent PMI inspection on pump casing, shaft and impeller to ascertain the grade of material during inspection at vendor works.</p> <p>iii) Tests for each pump included under this section shall include but not be limited to the following:</p> <ul style="list-style-type: none"> - The entire surface of the impeller / casing / diffuser castings shall be subjected to Dye Penetration Test as per ASTM Specification no.:1-165-65. - Shaft coupling & other active components shall be subjected to Dye Penetration and Ultrasonic Tests. - Wearing rings, shaft sleeves shall be subjected to Dye Penetration Test. - Fabricated components of pumps shall be subjected to Dye Penetration test on weld. - Verification of material, witnessing of pouring, casting and inspection of finished fabricated/castings. - Inspection of finished castings for impeller and verification of materials. - Inspection of pump shaft and verification of material. - Witnessing of NDT/review of NDT reports. - Static balancing test for impeller and dynamic balancing of complete rotating parts as per ISO- 1940 to grade 6.3 or better. - Complete Inspection of assembled pump. <p>b) Hydraulic Testing</p> <p>The pump casing shall be hydrostatically tested at maximum of the following:</p> <ol style="list-style-type: none"> i. 2 times the TDH (Total Dynamic Head) at rated capacity (or) ii. 1.5 times the shut-off pressure (or) iii. System Design pressure indicated in Data Sheet-A of this section. <p>The HT pressure shall be maintained for a period of not less than 30 minutes. During testing there should not be any pressure drop & leakage.</p> <p>c) Performance Test at Shop</p> <p>i) Each pump shall have to be tested to determine the performance curves of the pumps. These tests are to be conducted in presence of Owner's representative as per the requirements of the Standards of Hydraulic Institute</p>		

	TITLE:	SPECIFICATION NO. PES-179-06
	STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	VOLUME: II B
		SECTION: D
		REV. NO. 03 DATE: 16.07.2012
		SHEET 13 of 14
<p>of USA (ASME-Power Test Code PTC 8.2/BS-599) or any other equivalent standard.</p> <p>ii) Performance tests are to be conducted to cover the entire range of operation of the pumps at rated speed. These shall be carried out to span 130% of rated capacity up to pump shut-off condition. A minimum of five combinations of head and capacity are to be achieved during testing to establish the performance curves, including the design capacity point, shut-off point and the two extremities of the range of operation as specified in the annexure. After completion of performance test, all pumps shall be stripped down for inspection of internals.</p> <p>iii) Tests shall be conducted with actual drive motors being furnished.</p> <p>iv) NPSH tests are to be conducted for each type at 3% head drop conditions, if specified in the pump approved QP.</p> <p>v) Mechanical run test shall be carried out on all pumps to determine the vibration levels, noise levels etc. This test shall be conducted at site also. However, test value at site shall be used for the acceptance of the equipment.</p> <p>10.03.00 Inspection of Mandatory/ Recommended spares shall be in line with approved QP for main supply.</p> <p>11.00.00 DRAWINGS/ DOCUMENTS DISTRIBUTION SCHEDULE</p> <p>11.01.00 After award of LOI, the successful bidder shall submit drawings/documents as per Data Sheet-C.</p> <p>11.02.00 The no. of drawings/documents to be submitted shall be as per Annexure to Data Sheet-C.</p> <p>12.00.00 The various Sections-C's & D's along with Data Sheets attached in this specification together with the specification for Miscellaneous Pumps shall be complied with by the bidders.</p> <p>13.00.00 Bidder to submit all drawing/ documents in soft as well as hard copy within 2 weeks from placement of LOI's in the event of order.</p> <p>Within one (1) week of receipt of BHEL comments a technical representative from Bidder's works shall come for meeting with BHEL along with revised documents to resolve all issues and incorporate all comments in the soft copy here only for further submission to customer.</p> <p>Further on receipt of customer's comments on the documents a technical representative from Bidder's works shall come for meeting with Customer to resolve all issues and incorporate all comments in the soft copy here only and further resubmission of same to</p>		

	TITLE:	SPECIFICATION NO. PES-179-06
	STANDARD TECHNICAL SPECIFICATION HORIZONTAL CENTRIFUGAL PUMPS	VOLUME: II B
		SECTION: D
		REV. NO. 03 DATE: 16.07.2012
		SHEET 14 of 14
<p>Customer. The representative shall be available here till Category-I approval of all the drawings and documents.</p> <p>14.00.00 Guarantee for all pumps shall at least remain valid for 18 months from the Unit commissioning date or as specified in NIT.</p> <p>15.00.00 The following documents only shall be furnished by the bidder with his offer:</p> <p>a) Compliance certificate duly signed and stamped (enclosed at Vol. III of specn.).</p> <p>b) GA drawings of pumps and motors with following: (shall be only for reference purpose, same shall not be reviewed/commented by purchaser at this stage and shall be subject to approval only during contract).</p> <ul style="list-style-type: none"> • Civil static & dynamic loads. • Foundation details. <p>c) Guarantee Schedule duly signed and stamped (enclosed at Vol. III of specn.).</p> <p>d) Technical deviation schedule (if reqd.) (enclosed at Vol. III of specn.).</p> <p>e) Data for drive Motor (HT/LT- which is not in bidder's scope of supply - as applicable): Load torque speed curves of the pumps, selected motor rating, rpm, GD² of driven equipment.</p> <p>Apart from above no other Drgs./Docs./Data sheets etc. are required to be submitted at bid stage and even if furnished shall not be taken cognizance of.</p>		


PROJECT/PACKAGE		IB Valley tPS, 2x660MW Units 3&4					
Sl. No.	DESCRIPTION	DMCW TG AUX'S PUMPS	DMCW SG AUX'S PUMPS	Boiler Fill Pumps	Cycle make up pumps	Compressor Cooling Water	ACW Pumps
1.0 SERVICE							
1.1	Total no. of pumps for Project	6	4	2	3	1	4
1.2	No. of working & standby pumps	(2W+1S) per unit	(1W+1S) per unit	(1W+1S) for station	(2W+1S) for station	1W for station	(1W+1S) per unit
1.3	Liquid Handled (ref. water analysis enclosed herein)	PH corrected DM Water	PH corrected DM Water	D.M. Water	D.M. Water	PH corrected DM Water	Clarified water
1.4	Location (Indoor / Outdoor)	Indoor	Indoor	Indoor	Indoor	Outdoor	Indoor
1.5	Duty	Continuous	Continuous	Intermittent	Continuous	Continuous	Continuous
1.6	No. of pumps working in parallel	2	-	-	2	-	-
1.7	Specific gravity	1	1	1	1	1	1
1.8	System design pressure (kg/sqcm)	10	12	25	10	10	7.5
2.0 DESIGN PARAMETERS							
2.1	Design capacity each, M ³ /hr	980	1150	200	60	170	3350
2.2	Total dynamic head (MWC)	40	62	150	55	20	17
2.3	Suction Pressure(MWC)	25	25	←----- Flooded suction ----->			19
2.4	Design Temperature (°C)	60	60	60	60	60	60
2.5	Maximum permissible speed of pump (RPM)	1500	1500	1500	1500	1500	1500
2.6	Max. limit on shut off head Corresponding to pump TDH (MWC) at 51.5 Hz	Not to exceed 65 MWC	Not to exceed 83 MWC	Not to exceed 215 MWC	Not to exceed 80 MWC	Not to exceed 50 MWC	Not to exceed 48 MWC
2.7	Operating range	-----30-130% of design duty point flow-----					
2.8	Motor rating	Motor rating (at 50 deg. C ambient) shall be maximum of followinf:- 1) 15% margin over the pump shaft input power at the rated duty point. 2) 5% margin over the maximum pump shaft input power required on the entire characteristic curve of pump. 3) Pump shaft input power required considering the overloading of the pump assuming the single pump operation in the event of tripping of one or more of the pumps operating in parallel					
2.9	Permissible tolerance in rated capacity & TDH	←----- no negative tolerance ----->					
2.10	Permissible tolerance in efficiency at rated capacity(%)	←----- no negative tolerance ----->					
2.11	Performance/Design Standard	←----- HIS/IS 5120/ Equivalent standard ----->					
3.0 CONSTRUCTION FEATURES							
3.1	Pump type	←----- Horizontal centrifugal type Between Bearing Pump ----->					
3.2	Impeller type	←----- Closed ----->					
3.3	Casing type	←----- Axial split type ----->	←----- Axial split type ----->	←----- Axial/Radially split type ----->	←----- Axial/Radially split type ----->	←----- Axial split type ----->	←----- Axial split type ----->
3.4	Coupling type	←----- Flexible type ----->					
3.5	Sealing arrangement	←----- Gland packing initially & Mechanical seal finally after commisioning ----->			←----- Gland Packing ----->		
3.6	Type of Lubrication	←----- Self Water ----->					
3.7	Pump characteristics	←----- Non Overloading type & stable ----->					
3.8	Drain Plugs, vent, lifting lugs, priming connection	←----- Required ----->					
4.0 MATERIALS OF CONSTRUCTION							
4.1	Casing	←----- ASTM A-296 Gr. CF8M ----->			←----- 2.5% Ni Cl to IS 210 Gr. FG 260 ----->		
4.2	Impeller	←----- ASTM A-296 Gr. CF8M ----->			←----- Bronze/SS-304 ----->		←----- SS-304 ----->
4.3	Shaft	←----- SS-316 ----->		←----- SS-410 ----->			
4.4	Shaft Sleeves	←----- ASTM-A276 Type 316 ----->			←----- SS-410 ----->		
4.5	Impeller Wearing rings	←----- ASTM A-296 Gr. C440 ----->			←----- SS-316 ----->		
4.6	Wetted fasteners	←----- SS 304 ----->					
4.7	Fasteners (others)	←----- High tensile Steel ----->					
4.8	Gland/Seal Cover	←----- ASTM A-296 Gr. CF8M ----->			←----- 2.5% Ni Cl to IS 210 Gr. FG 260 ----->		
4.9	Lantern Ring	←----- SS316 ----->			←----- Bronze/SS-304 ----->		

		DATA SHEET - A			SPECIFICATION NO.:		PE-TS-391-100-N001		47 of 74		
		MISCELLANEOUS PUMPS (HORIZONTAL)			REV. NO.: 00		DATE : 12.08.2014				
		IB VALLEY TPS, 2x660MW Units 3&4			VOLUME : II B		SECTION : D				
PROJECT/PACKAGE		IB Valley tPS, 2x660MW Units 3&4									
Sl. No.	DESCRIPTION	DMCW TG AUX'S PUMPS	DMCW SG AUX'S PUMPS	Boiler Fill Pumps	Cycle make up pumps	Compressor Cooling Water	ACW Pumps				
4.10	Mech. seal	← Manufacturer standard →			← N/A →						
4.11	Gland Packing	← PTFE/ Grafoil initially →			← PTFE/Grafoil →						
4.12	Base Plate	← MS fabricated IS-2062 (min. thk.-10 mm) Epoxy Coated →									
4.13	Stuffing Box	← ASTM A-296 Gr. CF8M →			← 2.5% Ni Cl to IS 210 Gr. FG 260 →						
4.14	Casing Wearing rings (If applicable)	← SS 304 →									
4.15	Connecting Pipe material (for deciding counterflange material)	Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589		SA 312 TP 304 ERW		Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589					
5.0	MANDATORY SPARES										
	Pumps										
5.1	Complete Impeller assembly	1 set	1 set	1 set	1 set	N/A	1 set				
5.2	Key for Impeller	1 no.	1 no.	1 set	1 no.		1 set	1 set			
5.3	Pump Shaft	1 no.	1 no.	1 set	1 no.		1 set	1 set			
5.4	Bearings for pumps (Comprising of Drive & Non drive end)	1 set	1 set	1 set	1 set		1 set	1 set			
5.5	Wear rings for Shaft & Impeller	1 set	1 set	1 set	1 set		1 set	1 set			
5.6	Mechanical seal with Sleeves	1 set	1 set	-	1 set		-	-			
5.7	Coupling	1 no.	1 no.	1 no.	1 no.		-	1 no.			
5.8	Diffuser with guide vanes for 1st stage	-	-	1 set	-		-	1 set			
5.9	Coupling Bolt, Nut & Bush	-	-	1 set	-		-	1 set			
5.10	Mechanical seal	-	-	1 set	-		-	-			
5.11	Bearing Housing (comprising of DE & NDE)	-	-	1 set	-		-	1 set			
5.12	Shaft Sleeves (Suctio & Disc side)	-	-	1 set	-		-	1 set			
	Motors										
5.13	Drive Motor	1 no.	1 no.	1 no.	1 no.		-	1 no.			
5.14	End Shield cover (DE & NDE)	1 set	1 set	1 set	-	-	1 set				
5.15	DE and NDE Bearings	1 set	1 set	1 set	1 set	-	1 set				
5.16	Cooling Fan	1 no.	1 no.	1 no.	1 no.	-	1 no.				
5.17	Motor Terminal Block	1 no.	1 no.	1 no.	1 no.	-	1 no.				
5.18	Complete set of coupling	1 set	1 set	1 set	1 set	-	1 set				
5.19	Motor Space Heater	1 set	1 set	1 set	-	-	1 set				
6.0	BID EVALUATION RATE										
6.1	Bid evaluation rate	← Rs.1.0 Lacs/KW →		N/A		Rs.1.0 Lacs/KW		N/A		Rs.1.0 Lacs/KW	
6.2	Maximum permissible efficiency for Bid evaluation										
6.2.1	Pump Efficiency	85	84	-	72	-	86				
6.2.2	Motor Efficiency	94	94	-	90	-	94				
Notes :											
1	Material of construction for other components not specified above shall be similarly selected in line with the above for the duty intended and subject to approval.										
2	For items stated as not applicable by bidder, shall have to be supplied without any cost implication to BHEL in the event they are found to be applicable during detail engineering stage.										
3	For all HT motor driven pumps (wherever applicable), bidder shall provide key slots of dimensions 30mm Lx15 mm W x3 mmD on each pump shaft or some other suitable location which shall be confirmed during detail engineering by BHEL.										
4	Wherever SS material is coming in contact with non SS material, suitable isolation (rubber etc.) shall be provided to avoid galvanic corrosion.										

	Orissa Power Generation Corporation Ltd.	Technical Specification for Main Plant Package	IB TPS – 2 X 660 MW Units 3 & 4, Jharsuguda, Orissa
--	--	--	---

TABLE VI
DESIGN CLARIFIED WATER ANALYSIS

CONSTITUENTS	As	CONTENT
Calcium Hardness	CaCO ₃	90 ppm
Magnesium Hardness	CaCO ₃	40 ppm
Sodium and Potassium	CaCO ₃	42 ppm
Iron in Solution.	Fe	0.2 ppm
Hydrogen (FMA)	CaCO ₃	ppm
TOTAL CATIONS (Except iron in solution)	CaCO ₃	172 ppm
Bicarbonate	CaCO ₃	97 ppm
Carbonate	CaCO ₃	- ppm
Hydroxide	CaCO ₃	- ppm
Sulphate	CaCO ₃	60 ppm
Chloride	CaCO ₃	15 ppm
Nitrate	CaCO ₃	- ppm
Fluoride	CaCO ₃	- ppm
TOTAL ANIONS	CaCO ₃	172 ppm
M-Alkalinity	CaCO ₃	97 ppm
P-Alkalinity	CaCO ₃	ppm
Reactive Silica (Dissolved)	SiO ₂	6.0 ppm
Colloidal Silica	SiO ₂	9.0 ppm
Total Iron	Fe	0.2 ppm
Conductivity at 25 ^o C	-	200 Micro siemens/ cm (maximum)
Carbon-di-oxide	CO ₂	
pH value at 25 ^o C	-	7.5-8.5
Total Dissolved solids	-	200 ppm
Total Suspended solids	-	ppm (maximum)
Turbidity		10 NTU (maximum)
Oxygen absorbed at 27 ^o C for 4 hours		Traces ppm



Doc. No. : K8B09-MP-SPC-G-001	V.II/A/S-XII : 5	Development Consultants Pvt. Ltd.
-------------------------------	------------------	-----------------------------------


(K8B09-MP-V-II-A-LEA10_OPGC_CONTRACT-BHEL)



TABLE VIII

EXPECTED DM WATER ANALYSIS

- 1. Total Electrolyte : 0.1 ppm, max.
- 2. Total SiO₂ : 0.01 ppm SiO₂, max.
- 3. Iron as Fe : Nil
- 4. Free CO₂ ppm as CO₂ : Nil
- 5. Total Hardness : Nil
- 6. pH value at 25 Deg. C : 6.8 - 7.2
- 7. Conductivity, micro mho/cm : Less than 0.1 at 25 Deg. C



**BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN**

QUALITY PLAN FOR MISCELLANEOUS PUMPS			CUSTOMER			PROJECT TITLE						
SHEET 1 OF 6			SYSTEM			BIDDER/VENDOR			QUALITY PLAN NUMBER		PE-QP-999-100-N004 (For Hor. Pumps) PE-QP-999-100-N004 (For Ver. Pumps)	
						ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1	MATERIALS CONTROL											
1.1	CASINGS (INCLUDING BOWLS, DIFFUSERS, STAGE BODIES, DISCH HEAD (IF CAST)), ETC., - (AS APPLICABLE) AND IMPELLER	MECHANICAL AND CHEMICAL PROPS	CR	MECHANICAL AND CHEM. ANALYSIS	ONE/HEAT/BATCH	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	LAB REPORT/ MTC	3/2.		2,1	
1.2	STUFFING BOX, SUCTION BELL, WEARING RINGS, NECK RINGS, SHAFT SLEEVES	DO-	MA	MECHANICAL AND CHEM. ANALYSIS	ONE/HEAT/BATCH	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	LAB REPORT/ MTC	3/2.		2,1	
		HARDNESS DIFFERENCE BETWEEN CASING / IMPELLER AND WEARING RING	MA	LAB. TEST	100%	APPROVED CS DRAWING/DATA SHEET	50 BHN MIN.	LAB. REPORT	3/2.		2,1	
1.3	BARS/FORGINGS FOR SHAFTS, LINE SHAFTS	1. PHYSICAL & CHEMICAL PROPS	CR	1. MECHANICAL & CHEMICAL ANALYSIS.	1/CAST OR 1/BARS	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	MILL T.C. OR LAB. REPORT	3/2.		2,1	CORRELATION REQUIRED, IDENTIFICATION AS PER TC
		2. DIMENSIONS	CR	2. MEASUREMENT	100%	MFR. DRAWING	MFR. DRAWING	INSP. REPORT	3/2.		2,1	
		3. INTERNAL DEFECTS FOR 40MM & ABOVE DIA SHAFTS.	CR	3. ULTRA SONIC TEST	100%	ASTMA388 BACK WALL ECHO 100%	DEFECT ECHO MAX 20% OF B.W.E. LOSS OF BACK WALL ECHO 20% MAX	NDT CERTIFICATE	3/2.		2,1	
1.4	STRESS RELIEVING/ HEAT TREATMENT OF CASTING OF ALL ABOVE (IF APPLICABLE) / SOLUTION ANNEALING OF SS CASTING	1. VERIFICATION OF HT CHART	MA	VERIFICATION OF SR/HT CHART	ALL BATCHES	RELEVANT MATERIAL SPECN.	DO-	CORRELATED SR/HT.CHARTS	3/2.		2,1	
		2. IGC TEST FOR SS CASTING	MA	LAB. TEST	ONE SAMPLE/ HT BATCH	ASTM A 262	ASTM A 262 Gr A	LAB. REPORT	3/2.		2,1	
1.5	SHAFT ENCLOSING TUBES, COLUMN PIPES & DISCHARGE ELBOW	1. MECHANICAL & CHEMICAL PROPS. 2. DIMENSIONS. 3. SURFACE FINISH	MA	1. MECH & CHEM TEST 2. MEASUREMENT 3. VISUAL EXAM	1/BATCH 100% 100%	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./MAFG./ APPROVED DOCS	MFR T.C OR LAB. REPORT	3/2.		2,1	
BHEL				PARTICULARS			BIDDER / VENDOR					
				NAME								
				SIGNATURE								
				DATE						BIDDER/VENDOR SEAL		

BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN

QUALITY PLAN FOR MISCELLANEOUS PUMPS				CUSTOMER			PROJECT TITLE					
				BIDDER/VENDOR			QUALITY PLAN NUMBER					
SHEET 2 OF 6				SYSTEM			ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)					
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECKED	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.6	PLATE FLANGE, C/FLANGE	1. MECHANICAL & CHEMICAL PROS. 2. DIMENSIONS. 3. SURFACE FINISH	MA	1. MECH & CHEM TEST 2. MEASUREMENT 3. VISUAL EXAM	1/CAST 100% 100%	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./ MFR. DRG./ APPROVED DOC	MILL TC/ LAB REPORT	3/2.		2,1	CORRELATION REQ. FOR MAT OTHER THAN IS 2062
1.7	SUCTION STRAINER (IF APPLICABLE)	MECHANICAL & CHEMICAL PROS.	MI	MECH. & CHEMICAL TEST	1/HEAT	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./ MFR. DRG./ APPROVED DOC	MILL TC/ LAB REPORT	3/2.		2,1	
1.8	MECHANICAL SEAL (IF APPLICABLE)	TYPE, SIZE, MFRS, NO., MAKE	MA	VISUAL EXAM	100%	APPROVED DATASHEET / GA MECH. SEAL	APPROVED DATASHEET		3/2.		2,1	COMPLIANCE TC FOR APPROVED MAKE
1.9	PUMP BEARINGS	TYPE, SIZE, MFRS, NO., MAKE	MA	VISUAL EXAM	100%	APPROVED DATASHEET	APPROVED DATASHEET		3/2.		2,1	COMPLIANCE TC FOR APPROVED MAKE
2.0 IN PROCESS CONTROL												
2.1	ALL COMPONENTS UNDER 1.00 ABOVE	VISUAL DEFECTS, DIMENSIONS	MA	VISUAL EXAM, MEASUREMENT	100%	MFG. DRAWING	MFG. DRAWING	COMPLIANCE TC	3/2.		2,1	
2.2	IMPELLER	CLEANING AND DEBURRING	MA	VISUAL	100%	MFG. DRAWING	MFG. DRAWING		3/2.		2,1	
	IMPELLER	DYNAMIC BALANCING	CR	DYNAMIC BALANCING	100%	ISO 1940	ISO1940 Gr 6.3	BALANCING CERTIFICATE	3/2.	2,1		WITNESSING ONLY FOR SIZE GREATER THAN 10KW
2.3	IMPELLER-ALL ACCESSIBLE SURFACES, DIFFUSERS	DP TEST	MA	DP TEST ON M/CED AREA	100%	APPENDIX 8 OF ASME SEC. VIII DIV. 1		NDT CERTIFICATE	3/2.	2,1		WITNESS BY BHEL & VARIFICATION BY CUSTOMER
2.4	WERING RING, SHAFT SLEEVES, CASING	DP TEST	MA	DP TEST ON M/CED AREA	100%	APPENDIX 8 OF ASME SEC. VIII DIV. 1		NDT CERTIFICATE	3/2.		2,1	
2.5	SHAFT	DP TEST	MA	DP TEST ON M/CED AREA	100%	ASTM E 165	NO RELEVANT INDICATION ALLOWED	NDT CERTIFICATE	3/2.	2,1		WITNESS BY BHEL & VARIFICATION BY CUSTOMER
2.6	CASINGS/ BOWLS, STAGE BODIES, DISCHARGE HEAD (IF CAST), SUCTION HOUSING, COLUMN PIPE DISCHARGE PIPE ETC	LEAK TIGHTNESS	CR	VISUAL	100%	TECHNICAL DATA SHEET AND NOTE 2	NO LEAKAGE FOR TEST DURATION OF 30 MIN.	HT CERTIFICATE	3/2.	2,1		HAMMERING OF CASTINGS WITH WOODEN/ RUBBER Mallet BEFORE HYDRO TEST
BHEL				PARTICULARS			BIDDER / VENDOR					
				NAME								
				SIGNATURE								
				DATE						BIDDER/VENDOR SEAL		

**BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN**

QUALITY PLAN FOR MISCELLANEOUS PUMPS			CUSTOMER			PROJECT TITLE						
			BIDDER/VENDOR			QUALITY PLAN NUMBER						
SHEET 3 OF 6			SYSTEM			ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
2.7	FABRICATED COMPONENTS											
2.7.1	WELDING PROCEDURE SPECIFICATION	CORRECTNESS	MA	EXAM.	100%	ASME SEC.IX	ASME SEC.IX	QW 482 OF ASME SEC.IX	3/2.		2,1	WELDING PROCEDURE APPROVAL BY BHEL ALT. 3RD PARTY (LLYODS,BVQI OR EQ.) IS ACCEPTABLE.
2.7.2	WELDING PROCEDURE QUALIFICATION	WELD SOUNDNESS	MA	VISUAL,PHYS. TESTS RT (AS APPLICABLE)	100%	ASME SEC.IX	ASME SEC.IX	QW 483 OF ASME SEC.IX	3/2.		2,1	
2.7.3	WELDER PERFORMANCE QUALIFICATION	WELD SOUNDNESS	MA	VISUAL,PHYS. TESTS RT (AS APPLICABLE)	100%	ASME SEC.IX	ASME SEC.IX	QW 484 OF ASME SEC.IX	3/2.		2,1	
2.7.4	WELD FIT-UPS	DIMENSION & ALIGNMENT	MA	MEAS.VISUAL EXAM	100%	WPS, MFG . DRAWING	WPS, MFG . DRAWING	IR/LOGBOOK	3/2.			
2.7.5	ROOT RUNS	SURFACE DEFECTS	MA	PENETRANT TEST	100%	ASTM E 165	NO SURFACE DEFECT	DO.	3/2.		2,1	
2.7.6	WELDMENTS	SURFACE DEFECTS	MA	PENETRANT TEST	100%	ASTM E 165	ASME-VIII, DIV I	INSPN REPORT	3/2.		2,1	
BHEL			PARTICULARS			BIDDER / VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER/VENDOR SEAL			

**BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN**


QUALITY PLAN FOR MISCELLANEOUS PUMPS				CUSTOMER		PROJECT TITLE						
				BIDDER/VENDOR		QUALITY PLAN NUMBER						
SHEET 4 OF 6				SYSTEM		ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
2.7.7	BUTT WELDS	INTERNAL DEFECT	MA	UT/RT	100%			IR	3/2.		2.1	
2.7.8	DICHARGE HEAD, COLUMN PIPE, DISCHARGE PIPE, ETC.	1. LEAK TIGHTNESS 2. DIMENSION	CR	1. HYDROTEST 2. MEASUREMENT	100%	TECHNICAL SPEC/ DATA SHEET, MFR DRAWING	1. NO LEAKAGE 2. MFR. DRAWING	IR	3/2.	2.1		
3.0	SUB-ASSEMBLY CONTROL											
3.1	ROTOR ASSEMBLY	ECCENTRICITY	MA	MEASUREMENT	100%	MFR.DRAWING	MFR.DRAWING	IR/LOG BOOK	3/2.		1	
3.2	ROTOR ASSEMBLY RESIDUAL UNBALACE	STATIC & DYNAMIC	CR	STATIC & DYNAMIC BALANCING	100%	ISO 1940	ISO1940 Gr 6.3	BALANCING CERTIFICATE	3/2.	2.1		WTNESSING ONLY FOR SIZE GREATER THAN 10KW
3.3	COMPLETE PUMP ASSEMBLY	COMPLETENESS, CORRECTNESS, CLEANLINES, CLEARANCES, FREENESS, ALIGNMENT	MA	VISUAL EXAM MEASUREMENT	100%	APPROVED DRG & MFG STANDARDS	APPROVED DRG & MFG STANDARDS	I.R. & CHECK LISTS	3/2.		2.1	
BHEL				PARTICULARS			BIDDER / VENDOR					
				NAME								
				SIGNATURE								
				DATE						BIDDER/VENDOR SEAL		

BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN

QUALITY PLAN FOR MISCELLANEOUS PUMPS			CUSTOMER			PROJECT TITLE						
			BIDDER/VENDOR			QUALITY PLAN NUMBER						
SHEET 5 OF 6			SYSTEM			ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
4	FINAL INSPECTION, TESTS & PACKING DESPATCH CONTROL											
4.1	PUMP WITH JOB/SHOP MOTOR ASSEMBLED ON INDIVIDUAL BASE FRAME	1. Q V/S HEAD. 2. Q V/S POWER, 3. Q V/S PUMP EFF. 4. VIBRATION 5. NOISE 6. BEARING TEMP. 7. LEAKAGES	CR	PERFORMANCE TEST	100%	APPD. PERFORMANCE TEST PROCEDURE/ APPD. DATA SHEET/APPD. CURVES <u>FOR VIBRATIONS</u> - AS PER ANSI/HIS 9.6.4-2009 (VALUES AS PER APPROVED DATA SHEET) <u>FOR BEARING TEMP</u> - BEARING HOUSING SHOULD NOT BE UNTOUCHABLY HOT. <u>FOR LEAKAGE</u> - MINOR LEAKAGE (DROP BY DROP) IN CASE OF GLAND PACKING ARRANGEMENT.	I.R., PERF. TEST RECORD, PLOTTED CURVES	3/2.	2.1.			* MINIMUM 7 POINTS FROM SHUT-OFF TO MAX. OPERATING FLOW COVERING ENTIRE OPERATION RANGE OF PUMP SHALL BE TAKEN.
		NPSH/ MIN. SUBMERGENCE REQUIRED	CR	NPSH TEST	1/MODEL	DO.	IR. NPSH/MIN. SUBMERGENCE TEST RECORD, PLOTTED CURVES	3/2.	2.1.			IF SPECIFIED or INSISTED BY CUSTOMER.
4.2	STRIP DOWN AFTER PERFORMANCE TEST	1UNDUE WEAR TEAR AND RUBBING	MA	VISUAL EXAM AFTER STRIPPING	1/MODEL	NO UNDUE WEAR TEAR & RUBBING ON IMPELLER & WEAR RING	INSP. REPORT	3/2.	1			WITNESS REQUIRED ONLY WHEN ABNORMAL SOUND OBSERVED DURING PERFORMING TEST.
4.3	COMPLETE PUMP WITH UNIT MOTOR BASE FRAME, COUNTER FLANGES ETC. INCLUDING ALL ACCESSORIES AS PER SECTION C OF SPECN.	COMPLETENESS, CLEANLINESS, OVERALL DIMENSIONS ORIENTATION, WORKMANSHIP AND FINISH	MA	VISUAL EXAM MEASUREMENT	100%	APPD. G.A DRAWING	APPD. G.A DRAWING	INSP. REPORT	3/2.	1		
BHEL			PARTICULARS			BIDDER / VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER/VENDOR SEAL			

**BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN**


QUALITY PLAN FOR MISCELLANEOUS PUMPS			CUSTOMER			PROJECT TITLE						
SHEET 6 OF 6			BIDDER/VENDOR			QUALITY PLAN NUMBER						
SYSTEM			ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)									
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
4.4	COMPLETION OF ALL STAGES	1.COMPLETION	MA	VERIFICATION OF IR/T.C.ETC.	100%	MFG. DRG./TECHNICAL DOCS.	APPD. MFG. DRG./TECHNICAL DOCS	IR.	3/2.	2,1		WTNESSING ONLY BY BHEL, CUSTOMER VARIIFICATION ONLY BUT CHP
4.5	PAINING	1.SURFACE FINISH, DFT, MARKINGS ETC.	MA	VISUAL EXAM MEASUREMENT AESTHETIC	100%	APPD.DRG.	APPD.DOCS	IR.	3/2.		2	
4.6	PACKING, MARKING	SOUNDNESS OF PACKING	MI	VISUAL AESTHETIC	100%	MFG. STANDARD	MFG. STANDARD		3/2.		2	
<p>MTC -Mill Test Certificate, MA-Major, MI-Minor, TC-Test Certificate, CR-Critical, IGC- Inter Granular Corrosion</p> <p>1.AS CAST HEAT MARKS SHALL BE PROVIDED ON CI CASTING LIKE TOP & BOTTOM CASING.</p> <p>2. HYDRO TEST PRESSURE SHALL BE AT LEAST 2(TWO) TIMES THE DUTY POINT (OR) 1.5 TIMES OF SHUT OFF HEAD (OR) SYSTEM DESIGN PRESSURE, WHICHEVER IS HIGHER.</p> <p>3. THIS QAP IS ALSO APPLICABLE FOR SPARES.</p> <p>4. NO WELD REPAIRS PERMISSIBLE ON CI CASTING.</p> <p>5. MATERIAL SHALL BE AS PER APPROVED CROSS SECTION DRG./ DATA SHEET.</p> <p>6. STRIP TEST- INCASE OF ABNORMAL NOISE OBSERVED DURING PERF. TEST, THOSE PUMP WILL BE STRIPPED DOWN FOR VISUAL INSPECTION OF IMPELLER & WEAR SHALL BE OFFERED FOR VISUAL INSPECTION FOR WEAR /RUBBING MARKS.</p> <p>7. PUMPS WITH MECHANICAL SEAL ARRANGEMENT TO BE TESTED AND SUPPLIED WITH GLAND PACKING ARRANGEMENT. HOWEVER MANUFACTURER TO ENSURE DIMENTIONAL MATCHING OF MECHANICAL SEAL WITH PUMP GA DRAWING.</p> <p>LEGEND : 1- BHEL OR BHEL NOMINATED THIRD PARTY /END CUSTOMER OF BHEL, 2- VENDOR, 3-SUB-VENDOR</p> <p>P- PERFORM, W- WITNESS, V-VERIFICATION</p>												
BHEL			PARTICULARS				BIDDER / VENDOR					
			NAME									
			SIGNATURE									
			DATE							BIDDER/VENDOR SEAL		

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS DATA SHEET - C	VOLUME:	IIB	SECTION:	D1
		REV. NO.	0	DATE:	12.08.2014

Drawings / documents distribution schedule to be followed by successful bidder :

- 1.0 Drawings/documents submission schedule, shall be as per NIT. The successful bidder shall submit following drawings/ documents.
- 1.1 Fully dimensioned outline general arrangement drawings of the pump and motor assembly. This drawing should include foundation base plate and sole plate details as applicable, civil foundation and anchor bolt details and loading data, points of connections of external piping and cables and mounting of devices furnished by the supplier.
- 1.2 Cross sectional drawing of the equipment showing the details of assembly of components and their material of construction with standard applicable codes.
- 1.3 Characteristic curves of pump showing the following:
 - a) Flow Vs Head
 - b) Flow VS Power
 - c) Flow Vs Efficiency
 - d) Flow Vs NPSHR
- 1.4 Operation and maintenance manual
- 1.5 Lubrication arrangement drawings for external lubrication (if applicable).
- 2.0 Within the stipulated time period as per vendor's drawings/ documents schedule as per NIT, the O&M Manual comprising of minimum following shall be submitted
 - a) Drawings of components & details as deemed necessary.
 - b) Instruction manual for erection, operation & maintenance.
 - c) Storage instruction.
- 3.0 Before despatch of the equipment the bidder shall furnish the following.
 - a) Material test certificates.
 - b) Shop test reports & certificates.
 - c) MDCC after final inspection shall be provided to vendor on the basis of following:-
 - c1) List of items packed in each box with description & quantity.
 - c2) Photograph of each box in open & closed condition.
- 4.0 Distribution of drawings / documents for all projects:

The no. of drawing/ documents to be submitted by the successful bidder, after the award of the contract shall be intimated after award of contract.

	TECHNICAL SPECIFICATIONS	SPECIFICATION NO.:	PE-TS-391-100-N001		
	MISCELLANEOUS PUMPS	VOLUME:	IIB	SECTION:	D2
		REV. NO.	0	DATE:	12.08.2014

SECTION D2

STANDARD MOTOR SPECIFICATION STANDARD QUALTY PLAN FOR MOTORS

TITLE :
GENERAL TECHNICAL REQUIREMENTS
FOR
LV MOTORS

SPECIFICATION NO. 58 of 74
PE-SS-999-506-E101
VOLUME NO. : II-B
REV NO. : 00 **DATE :** 29/08/2005
SHEET : 1 OF 1

GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS

SPECIFICATION NO.: PE-SS-999-506-E101 Rev 00



TITLE :
GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS

SPECIFICATION NO.59 of 74
PE-SS-999-506-E101
VOLUME NO. : **II-B**
SECTION : **D**
REV NO. : **00** DATE : 29/08/2005
SHEET : 1 OF 4

1.0 INTENT OF SPECIFICATION

The specification covers the design, materials, constructional features, manufacture, inspection and testing at manufacturer's work, and packing of Low voltage (LV) squirrel cage induction motors along with all accessories for driving auxiliaries in thermal power station.

Motors having a voltage rating of below 1000V are referred to as low voltage (LV) motors.

2.0 CODES AND STANDARDS

Motors shall fully comply with latest edition, including all amendments and revision, of following codes and standards:

IS:325	Three phase Induction motors
IS : 900	Code of practice for installation and maintenance of induction motors
IS: 996	Single phase small AC and universal motors
IS: 4722	Rotating Electrical machines
IS: 4691	Degree of Protection provided by enclosures for rotating electrical machines
IS: 4728	Terminal marking and direction of rotation rotating electrical machines
IS: 1231	Dimensions of three phase foot mounted induction motors
IS: 8789	Values of performance characteristics for three phase induction motors
IS: 13555	Guide for selection and application of 3-phase A.C. induction motors for different types of driven equipment
IS: 2148	Flame proof enclosures for electrical appliance
IS: 5571	Guide for selection of electrical equipment for hazardous areas
IS: 12824	Type of duty and classes of rating assigned
IS: 12802	Temperature rise measurement for rotating electrical machines
IS: 12065	Permissible limits of noise level for rotating electrical machines
IS: 12075	Mechanical vibration of rotating electrical machines

In case of imported motors, motors as per IEC-34 shall also be acceptable.

3.0 DESIGN REQUIREMENTS

3.1 Motors and accessories shall be designed to operate satisfactorily under conditions specified in data sheet-A and Project Information, including voltage & frequency variation of supply system as defined in Data sheet-A

3.2 Motors shall be continuously rated at the design ambient temperature specified in Data Sheet-A and other site conditions specified under Project Information
Motor ratings shall have at least a 15% margin over the continuous maximum demand of the driven equipment, under entire operating range including voltage & frequency variation specified above.

3.3 Starting Requirements

3.3.1 Motor characteristics such as speed, starting torque, break away torque and starting time shall be properly co-ordinated with the requirements of driven equipment. The accelerating torque at any speed with the minimum starting voltage shall be at least 10% higher than that of the driven equipment.

3.3.2 Motors shall be capable of starting and accelerating the load with direct on line starting without exceeding acceptable winding temperature.



TITLE :
GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS

SPECIFICATION NO. 60 of 74
PE-SS-999-506-E101
VOLUME NO. : **II-B**
SECTION : **D**
REV NO. : **00** DATE : 29/08/2005
SHEET : 2 OF 4

The limiting value of voltage at rated frequency under which a motor will successfully start and accelerate to rated speed with load shall be taken to be a constant value as per Data Sheet - A during the starting period of motors.

3.3.3 The following frequency of starts shall apply

- i) Two starts in succession with the motor being initially at a temperature not exceeding the rated load temperature.
- ii) Three equally spread starts in an hour the motor being initially at a temperature not exceeding the rated load operating temperature. (not to be repeated in the second successive hour)
- iii) Motors for coal conveyor and coal crusher application shall be suitable for three consecutive hot starts followed by one hour interval with maximum twenty starts per day and shall be suitable for minimum 20,000 starts during the life time of the motor

3.4 **Running Requirements**

- 3.4.1 Motors shall run satisfactorily at a supply voltage of 75% of rated voltage for 5 minutes with full load without injurious heating to the motor.
- 3.4.2 Motor shall not stall due to voltage dip in the system causing momentary drop in voltage upto 70% of the rated voltage for duration of 2 secs.

3.5 **Stress During bus Transfer**

- 3.5.1 Motors shall withstand the voltage, heavy inrush transient current, mechanical and torque stress developed due to the application of 150% of the rated voltage for at least 1 sec. caused due to vector difference between the motor residual voltage and the incoming supply voltage during occasional auto bus transfer.
- 3.5.2 Motor and driven equipment shafts shall be adequately sized to satisfactorily withstand transient torque under above condition.

3.6 Maximum noise level measured at distance of 1.0 metres from the outline of motor shall not exceed the values specified in IS 12065.

3.7 The max. vibration velocity or double amplitude of motors vibration as measured at motor bearings shall be within the limits specified in IS: 12075.


4.0 **CONSTRUCTIONAL FEATURES**

4.1 Indoor motors shall conform to degree of protection IP: 54 as per IS: 4691. Outdoor or semi-indoor motors shall conform to degree of protection IP: 55 as per IS: 4691 and shall be of weather-proof construction. Outdoor motors shall be installed under a suitable canopy

4.2 Motors upto 160KW shall have Totally Enclosed Fan Cooled (TEFC) enclosures, the method of cooling conforming to IC-0141 or IC-0151 of IS: 6362.

Motors rated above 160 KW shall be Closed Air Circuit Air (CACA) cooled

4.3 Motors shall be designed with cooling fans suitable for both directions of rotation.

	TITLE :	SPECIFICATION NO. 61 of 74
	GENERAL TECHNICAL REQUIREMENTS	PE-SS-999-506-E101
	FOR	VOLUME NO. : II-B
	LV MOTORS	SECTION : D
		REV NO. : 00 DATE : 29/08/2005
		SHEET : 3 OF 4

- 4.4. Motors shall not be provided with any electric or pneumatic operated external fan for cooling the motors.
- 4.5. Frames shall be designed to avoid collection of moisture and all enclosures shall be provided with facility for drainage at the lowest point.
- 4.6. In case Class 'F' insulation is provided for LV motors, temperature rise shall be limited to the limits applicable to Class 'B' insulation.
In case of continuous operation at extreme voltage limits the temperature limits specified in table-1 of IS:325 shall not exceed by more than 10°C.
- 4.7 Terminals and Terminal Boxes**
- 4.7.1 Terminals, terminal leads, terminal boxes, windings tails and associated equipment shall be suitable for connection to a supply system having a short circuit level, specified in the Data Sheet-A.
- Unless otherwise stated in Data Sheet-A, motors of rating 110 kW and above will be controlled by circuit breaker and below 110 kW by switch fuse-contactor. The terminal box of motors shall be designed for the fault current mentioned in data sheet "A".
- 4.7.2 unless otherwise specified or approved, phase terminal boxes of horizontal motors shall be positioned on the left hand side of the motor when viewed from the non-driving end.
- 4.7.3 Connections shall be such that when the supply leads R, Y & B are connected to motor terminals A B & C or U, V & W respectively, motor shall rotate in an anticlockwise direction when viewed from the non-driving end. Where such motors require clockwise rotation, the supply leads R, Y, B will be connected to motor terminals A, C, B or U W & V respectively.
- 4.7.4 Permanently attached diagram and instruction plate made preferably of stainless steel shall be mounted inside terminal box cover giving the connection diagram for the desired direction of rotation and reverse rotation.
- 4.7.5 Motor terminals and terminal leads shall be fully insulated with no bar live parts. Adequate space shall be available inside the terminal box so that no difficulty is encountered for terminating the cable specified in Data Sheet-A.
- 4.7.6 Degree of protection for terminal boxes shall be IP 55 as per IS 4691.
- 4.7.7 Separate terminal boxes shall be provided for space heaters.. If this is not possible in case of LV motors, the space heater terminals shall be adequately segregated from the main terminals in the main terminal box. Detachable gland plates with double compression brass glands shall be provided in terminal boxes.
- 4.7.8. Phase terminal boxes shall be suitable for 360 degree of rotation in steps of 90 degree for LV motors.
- 4.7.9 Cable glands and cable lugs as per cable sizes specified in Data Sheet-A shall be included. Cable lugs shall be of tinned Copper, crimping type.
- 4.8 Two separate earthing terminals suitable for connecting G.I. or MS strip grounding conductor of size given in Data Sheet-A shall be provided on opposite sides of motor frame. Each terminal box shall have a grounding terminal.



TITLE :
GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS

SPECIFICATION NO. 62 of 74
PE-SS-999-506-E101
VOLUME NO. : **II-B**
SECTION : **D**
REV NO. : **00** DATE : 29/08/2005
SHEET : 4 OF 4

- 4.9.1 Motors provided for similar drives shall be interchangeable.
- 4.9.2 Suitable foundation bolts are to be supplied alongwith the motors.
- 4.9.3 Motors shall be provided with eye bolts, or other means to facilitate safe lifting if the weight is 20Kgs. and above.
- 4.9.4 Necessary fitments and accessories shall be provided on motors in accordance with the latest Indian Electricity rules 1956.
- 4.9.5 All motors rated above 30 kW shall be provided with space heaters to maintain the motor internal air temperature above the dew point. Unless otherwise specified, space heaters shall be suitable for a supply of 240V AC, single phase, 50 Hz.
- 4.9.6 Name plate with all particulars as per IS: 325 shall be provided
- 4.9.7 Unless otherwise specified, the colour of finish shall be grey to Shade No. 631 and 632 as per IS:5 for motors installed indoor and outdoor respectively. The paint shall be epoxy based and shall be suitable for withstanding specified site conditions.

5.0 INSPECTION AND TESTING


- 5.1 All materials, components and equipments covered under this specification shall be procured, manufactured, as per the BHEL standard quality plan No. PED-506-00-Q-006/0 and PED-506-00-Q-007/2 enclosed with this specification and which shall be complied.
- 5.2 LV motors of type-tested design shall be provided. Valid type test reports not more than 5 year shall be furnished. In the absence of these, type tests shall have to be conducted by manufacturer without any commercial implication to purchaser.
- 5.3 All motors shall be subjected to routine tests as per IS: 325 and as per BHEL standard quality plan.
- 5.4 Motors shall also be subjected to additional tests, if any, as mentioned in Data Sheet A.


6.0 DRAWINGS TO BE SUBMITTED AFTER AWARD OF CONTRACT


- a) OGA drawing showing the position of terminal boxes, earthing connections etc.
- b) Arrangement drawing of terminal boxes.
- c) Characteristic curves:
(To be given for motor above 55 kW unless otherwise specified in Data Sheet).
 - i) Current vs. time at rated voltage and minimum starting voltage.
 - ii) Speed vs. time at rated voltage and minimum starting voltage.
 - iii) Torque vs. speed at rated voltage and minimum voltage.
For the motors with solid coupling the above curves i), ii), iii) to be furnished for the motors coupled with driven equipment. In case motor is coupled with mechanical equipment by fluid coupling, the above curves shall be furnished with and without coupling.
 - iv) Thermal withstand curve under hot and cold conditions at rated voltage and max. permissible voltage.


SPECIFIC ELECTRICAL REQUIREMENT FOR MISC. PUMPS**DATA SHEET-A**


SL.NO.	PARAMETERS	UNIT	OPGCL
	MOTOR		
1	DESIGN AMBIENT TEMP	DEG. C	50
2	VOLTAGE SUPPLY AND VARIATION	VOLT	415V, \pm 10%
3	FREQUENCY WITH VARIATION	Hz	50 (+) 3% to (-) 5%
4	COMBINED VOLTAGE & FREQUENCY VARIATION		10%
5	MAX ACCEPTABLE RATING OF MOTOR AT 415 V	KW	Above 200W and upto 200 kW
6	SYSTEM FAULT LEVEL AND ITS DURATION	KA	50 KA, 1 Sec
7	SUTABILITY OF TERMINAL BOX FOR FAULT LEVEL AND DURATION		50 KA, 0.25 sec
8	CLASS OF INSULATION & TEMP RISE LIMITED TO		Class-F and temp rise limited to Class-B
9	MIN. STARTING VOLTAGE		80%
10	MOTOR RATING FOR SINGLE PHASE SUPPLY		Upto 200W
11	MAXIMUM LOCKED ROTOR CURRENT	% OF FLC	600% inclusive of 20% IS tolerance
12	LOCKED ROTOR WITHSTAND TIME	SEC	0 TO 22.5 (MAX.)
13	TYPE OF COOLING		TEFC /CACA/ TETV
14	ACCEPTABLE NOISE LEVEL	DB	85dB at 1.0m in line with IS 12065
15	TYPE OF STARTER PROVIDED IN MCC		DOL
16	DOP OF ENCLOSURE		IP:54 for Indoor Motor, IP:55 for Outdoor. Motor for outdoor or semi outdoor service shall be of weather proof construction. DOP for terminal boxes shall be IP 55 as per IS 4691.
17	SPACE HEATER REQUIREMENT		30KW & ABOVE
18	PAINT SHADE		Shall be confirmed during detailed engineering.
19	SPECIAL REQUIREMENT		1) Type test to be conducted on the identical motor in the last 5 years or after the last design change, which ever is earlier. Otherwise, the equipment shall have to be type tested, free of charge, to prove the design. 2) All motors shall be subjected to routine tests as per IS: 325. 3) The motors shall generally conform to IS 325/IEC-60034. LT motors of continuous duty (S1) shall be energy efficient IE2 conforming to IS-12615. 4) Speed switch can be provided to fulfill locked rotor withstand time requirements. 5) Vibration level shall be as per IS 12075


		QUALITY PLAN	CUSTOMER :			PROJECT			SPECIFICATION :			
			BIDDER/ VENDOR :			TITLE			NUMBER :			
SHEET 1 OF 2		SYSTEM			QUALITY PLAN NUMBER PED-506-00-Q-006, REV-01			SPECIFICATION TITLE				
SL. NO.	COMPONENT/OPERATION	CHARACTERISTICS CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	SECTION VOLUME III			
1	2	3	4	5	6	7	8	9	P	W	V	REMARKS
1.0	ASSEMBLY	1.WORKMANSHIP	MA	VISUAL	100%	MANUF'S SPEC	MANUF'S SPEC	-DO-	2	-	-	
		2.DIMENSIONS	MA	-DO-	-DO-	MFG. DRG./MFG. SPEC.	MFG. DRG./MFG. SPEC.	-DO-	2	-	-	
		3.CORRECTNESS COMPLETENESS TERMINATIONS/ MARKING/COLOUR CODE	MA	VISUAL	100%	MFG.SPEC./RELEVANT IS	MFG.SPEC. RELEVANT IS	-DO-	2	-	-	
2.0	PAINTING	1.SHADE	MA	VISUAL	SAMPLE	MANUFR'S SPEC/BHEL SPEC./RELEVANT STANDARD	BHEL SPEC. SAME AS COL.7	LOG BOOK	2	-	-	
3.0	TESTS	1.ROUTINE TEST INCLUDING SPECIAL TEST AS PER BHEL SPEC.	MA	-DO-	100%	IS-325/BHEL SPEC./DATA SHEET	SAME AS COL.7	TEST REPORT	2	1		NOTE -1 & NOTE-3
		2.OVERALL DIMENSIONS & ORIENTATION	MA	MEASUREMENT & VISUAL	100%	APPROVED DRG/DATA SHEET	APPROVED DRG/DATA SHEET & RELEVANT IS	INSPN. REPORT	2	1	-	NOTE -1 & NOTE-3
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									


	QUALITY PLAN		CUSTOMER :			PROJECT			SPECIFICATION :			
	SHEET 2 OF 2		BIDDER/ :			TITLE			NUMBER :			
			VENDOR			QUALITY PLAN			SPECIFICATION :			
		SYSTEM			NUMBER PED-506-00-Q-006, REV-01			TITLE :				
					ITEM AC ELECT. MOTORS BELOW 55KW (LV)			SECTION		VOLUME III		
SL. NO.	COMPONENT/OPERATION	CHARACTERISTICS CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
		3.NAMEPLATE DETAILS	MA	VISUAL	100%	IS-325 & DATA SHEET	IS-325 & DATA SHEET	INSPN. REPORT	2	1	-	
<p>NOTES:</p> <p>1 ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON</p> <p>2 WHERE EVER CUSTOMER IS INVOLVED IN INSPECTION, (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER.</p> <p>3 FOR EXHAUST/VENTILATION FAN MOTORS OF RATING UPTO 1.5KW , ONLY ROUTINE TEST CERTIFICATES SHALL BE FURNISHED FOR SCRUTINY.</p> <p><u>Legends for Inspection agency</u></p> <p>1. BHEL/CUSTOMER 2. VENDOR (MOTOR MANUFACTURER) 3. SUB-VENDOR (RAW MATERIAL/COMPONENTS SUPPLIER)</p> <p>P. PERFORM W. WITNESS V. VERIFY</p>												
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER'S/VENDORS COMPANY SEAL			


		QUALITY PLAN SHEET 1 OF 9				CUSTOMER :			PROJECT			SPECIFICATION :								
						TITLE			NUMBER :											
SL. NO.		COMPONENT/OPERATION		CHARACTERISTIC CHECK		CAT.		TYPE/ METHOD OF CHECK		EXTENT OF CHECK		REFERENCE DOCUMENT		ACCEPTANCE NORM		FORMAT OF RECORD		SPECIFICATION :		
																		TITLE		
1		2		3		4		5		6		7		8		9		SECTION		
																		VOLUME III		
1		2		3		4		5		6		7		8		9		AGENCY		
																		REMARKS		
1		2		3		4		5		6		7		8		9		10		
11																				
1.0	RAW MATERIAL & BOUGHT OUT CONTROL																			
1.1	SHEET STEEL, PLATES, SECTION, EYEBOLTS		1.SURFACE CONDITION		MA	VISUAL		100%	-			FREE FROM BLINKS, CRACKS, WAVINESS ETC	LOG BOOK	3	-	-				
			2.DIMENSIONS		MA	MEASUREMENT		SAMPLE	MANFR'S DRG./SPEC	MANFR'S DRG./SPEC	-DO-	-DO-	INSPEC. REPORT	3	-	-				
			3.PROOF LOAD TEST (EYE BOLT)		MA	MECH. TEST		-DO-	-DO-	-DO-	-DO-	-DO-	INSPEC. REPORT	3	-	2				
1.2	HARDWARES		1.SURFACE CONDITION		MA	VISUAL		100%			FREE FROM CRACKS, UN-EVENNESS ETC.	-DO-	3	-	-					
			2.PROPERTY CLASS		MA	VISUAL		SAMPLES	MANFR'S DRG./SPEC BOOK	RELEVENT IS/SPEC.	SUPPLIERS TC & LOG	3	-	2	PROPERTY CLASS MARKING SHALL BE CHECKED BY THE VENDOR					
1.3	CASTING		1.SURFACE CONDITION		MA	VISUAL		100%			FREE FROM CRACKS, BLOW HOLES ETC.	LOG BOOK	3	-	2					
			2.CHEM. & PHY. PROP.		MA	CHEM & MECH TEST		1/HEAT NO.	MANFR'S DRG./SPEC	RELEVENT IS/	SUPPLIER'S TC	3	-	2	HEAT NO. SHALL BE VERIFIED					
			3.DIMENSIONS		MA	MEASUREMENT		100%	MANUFR'S DRG.	MANUFR'S DRG.	LOG BOOK	3	-	2						
1.4	PAINT & VARNISH		1.MAKE, SHADE, SHELF LIFE & TYPE		MA	VISUAL		100% CONTINUOUS	MANFR'S DRG./SPEC	MANFR'S DRG./SPEC	LOG BOOK	3	-	2						
BHEL					PARTICULARS					BIDDER/VENDOR										
					NAME															
					SIGNATURE															
					DATE										BIDDER'S/VENDORS COMPANY SEAL					


		QUALITY PLAN			CUSTOMER :			PROJECT			SPECIFICATION :		
					BIDDER/ VENDOR			TITLE			NUMBER :		
SHEET 2 OF 9		SYSTEM			QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03			SPECIFICATION : TITLE			SECTION VOLUME III		
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS	
									P	W	V		
1	2	3	4	5	6	7	8	9	10			11	
1.5	SHAFT (FORGED OR ROLLED)	1. SURFACE COND.	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	-	VENDOR'S APPROVAL IDENTIFICATION SHALL BE MAINTAINED	
		2. CHEM. & PHYSICAL PROPERTIES	MA	CHEM. & PHYSICAL TESTS	1/HEAT NO. OR HEAT TREATMENT BATCH NO	MFG. DRG. SPEC.	RELEVANT IS	SUPPLIER'S TC	3	-	2		
		3. DIMENSIONS	MA	MEASUREMENT	100%	-DO-	MANUFR'S DRG.	LOG BOOK	3	-	2		
		4. INTERNAL FLAWS	CR	UT	-DO-	ASTM-A388	MANUFR'S SPEC. BHEL SPEC.	-DO-	3	2	1		FOR DIA OF 55 MM & ABOVE
1.6	SPACE HEATERS, CONNECTORS, TERMINAL BLOCKS, CABLES, CABLE LUGS, CARBON BRUSH TEMP. DETECTORS, RTD, BTD'S	1. MAKE & RATING	MA	VISUAL	-DO-	MANUFR'S DRG. SPEC.	MANUFR'S DRG. SPEC.	-DO-	3	-	2		
		2. PHYSICAL COND.	MA	-DO-	-DO-	-	NO PHYS. DAMAGE, NO ELECTRICAL DISCONTINUITY	-DO-	3	-	2		
		3. DIMENSIONS (WHEREVER APPLICABLE)	MA	MEASUREMENT	SAMPLE	MANUFR'S DRG./ SPEC.	MANUFR'S DRG. / SPEC.	-DO-	3	-	2		
		4. PERFORMANCE/ CALIBRATION	MA	TEST	100%	-DO-	-DO-	INSP. REPORT	3	-	2		
BHEL			PARTICULARS			BIDDER/VENDOR							
			NAME										
			SIGNATURE										
			DATE						BIDDER'S/VENDORS COMPANY SEAL				


		QUALITY PLAN			CUSTOMER :			PROJECT			SPECIFICATION :		
					BIDDER/ VENDOR			TITLE			NUMBER :		
SHEET 3 OF 9		SYSTEM			ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)			SECTION			VOLUME III		
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS	
									P	W	V		
1	2	3	4	5	6	7	8	9	10			11	
1.7	OTHER INSULATING MATERIALS LIKE SLEEVES, BINDINGS CORDS, PAPERS, PRESS BOARDS ETC.	1. SURFACE COND. ETC. 2. OTHER CHARACTERISTICS	MA MA	VISUAL TEST	100% SAMPLE	- MANUF'S SPEC.	NO VISUAL DEFECTS MANUF'S SPEC.	INSPT. REPORT LOG BOOK AND OR SUPPLIER'S TC	3 3	- -	2 2		
1.8	SHEET STAMPING (PUNCHED)	1. SURFACE COND. 2. DIMENSIONS INCLUDING BURS HEIGHT 3. ACCEPTANCE TESTS	MA MA MA	VISUAL MEASUREMENT ELECT. & MECH TESTS	100% SAMPLE -DO-	- MANUFR'S DRG. . MANUF'S SPEC./ RELEVANT IS	NO VISUAL DEFECTS (FREE FROM BURS) MANUFR'S DRG. RELEVANT IS	LOG BOOK -DO- SUPPLIER'S TC	3 3 3	- -	- 2 2		
1.9	CONDUCTORS	1. SURFACE FINISH 2. ELECT. PROP, & MECH. PROP	MA MA	VISUAL ELECT. & MECH. TEST	100% SAMPLES	- RELEVANT IS/ BS OR OTHER STANDARDS	FREE FROM VISUAL DEFECTS RELEVANT IS/ BS OR OTHER STANDARDS	LOG BOOK SUPPLIERS TC & VENDOR'S INSPN. REPORTS	3* 3	- -	2* 2	* MOTOR MANUFACTURER TO CONDUCT VISUAL CHECK FOR SURFACE FINISH ON RANDOM BASIS (10% SAMPLE) AT HIS WORKS AND MAINTAIN RECORD FOR VERIFICATION BY BHEL/CUSTOMER.	
BHEL			PARTICULARS			BIDDER/VENDOR							
			NAME										
			SIGNATURE										
			DATE			BIDDER'S/VENDORS COMPANY SEAL							


		QUALITY PLAN			CUSTOMER :		PROJECT		SPECIFICATION :			
					BIDDER/ VENDOR :		TITLE		NUMBER :			
SHEET 4 OF 9		SYSTEM		ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)		SECTION		VOLUME III				
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.10	BEARINGS	3.DIMENSIONS	MA	MEASUREMENT	-DO-	-DO-	-DO-	Log Book	3	-	2	
		1.MAKE & TYPE	MA	VISUAL	100%	MANFR'S DRG./ APPROVED DATASHEET	MANFR'S DRG./ APPROVED DATASHEET	-DO-	3	-	2	
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	BHEL DATA SHEET	BHEL DATA SHEET BEARING MANUF'S CATALOGUES	-DO-	3	-	2	
		3.SURFACE FINISH	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	2	
1.11	SLIP RING (WHEREVER APPLICABLE)	1.SURFACE COND.	MA	VISUAL	100%	-	-DO-	-DO-	3	-	-	
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	MANUF'S DRG	MANUF'S DRG	-DO-	3	-	-	
		3.TEMP.WITH-STAND CAPACITY	MA	ELECT.TEST	-DO-	MANUF'S SPEC./ BHEL SPEC.	MANUF'S SPEC./ BHEL SPEC.	-DO-	3	-	2	
		4.HV/IR	MA	-DO-	100%	-DO-	-DO-	-DO-	3	-	2	
1.12	OIL SEALS & GASKETS	1.MATERIAL OF GASKET	MA	VISUAL	100%	MANUF'S DRG/SPECS	MANUF'S DRG./ SPECS.	-DO-	3	-	-	
		2.SURFACE COND.	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	-	
		3.DIMENSIONS	MA	MEASUREMENT	SAMPLE	MANUF'S DRG	MANUF'S DRG	-DO-	3	-	-	
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER'S/VENDORS COMPANY SEAL			

		QUALITY PLAN			CUSTOMER :			PROJECT			SPECIFICATION :		
					BIDDER/ VENDOR :			TITLE			NUMBER :		
SHEET 5 OF 9		SYSTEM			QUALITY PLAN			SPECIFICATION :					
		ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)			NUMBER PED-506-00-Q-007, REV-03			TITLE					
		SECTION			VOLUME III								
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS	
									P	W	V		
1	2	3	4	5	6	7	8	9	10			11	
2.0	IN PROCESS												
2.1	STATOR FRAME WELDING (IN CASE OF FABRICATED STATOR)	1.WORKMANSHIP & CLEANNESS	MA	VISUAL	100%	-DO-	GOOD FINISH	LOG BOOK	3/2	2	-		
		2.DIMENSIONS	MA	MEASUREMENT	-DO-	MANUF'S DRG	MANUF'S DRG	-DO-	2	-	-		
2.2	MACHINING	1.FINISH	MA	VISUAL	100%	-DO-	GOOD FINISH	LOG BOOK	2	-	-		
		2.DIMENSIONS	MA	MEASUREMENT	-DO-	MANUF'S DRG	MANUF'S DRG	-DO-	2	-	-		
		3.SHAFT SURFACE FLOWS	MA	PT	-DO-	RELEVANT SPEC./ ASTM-E165	MANUF'R'S SPEC./ BHEL SPEC./	-DO-	2	-	1		
2.3	PAINING	1.SURFACE PREPARATION	MA	VISUAL	100%	MANFR'S SPEC/BHEL SPEC./ RELEVANT STAND	BHEL SPEC. SAME AS COL.7	LOG BOOK	2	-	-		
		2.PAINT THICKNESS (BOTH PRIMER & FINISH COAT)	MA	MEASUREMENT BY ELCOMETER	SAMPLE	-DO-	-DO-	-DO-	2	-	-		
		3.SHADE	MA	VISUAL	-DO-	-DO-	-DO-	Log Book	2	-	-		
		4.ADHESION	MA	CROSS CUTTING & TAPE TEST	-DO-	-DO-	-DO-	Log Book	2	-	-		
BHEL			PARTICULARS			BIDDER/VENDOR							
			NAME										
			SIGNATURE										
			DATE						BIDDER'S/VENDORS COMPANY SEAL				

		QUALITY PLAN SHEET 6 OF 9			CUSTOMER :			PROJECT TITLE			SPECIFICATION NUMBER :		
					BIDDER/ VENDOR			QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03			SPECIFICATION TITLE		
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	SECTION VOLUME III			REMARKS	
1	2	3	4	5	6	7	8	9	10			11	
P	W	V											
2.4	SHEET STACKING	1.COMPLETENESS	MA	MEASUREMENT	SAMPLE	MANUFR'S SPEC.	MANUFR'S SPEC.	Log Book	2	-	-	(FOR MOTORS OF 2MW AND ABOVE) * ON 10% RANDOM SAMPLE	
		2.COMPRESSION & TIGHTENING	MA	MEASUREMENT	100%	-DO-	-DO-	Log Book	2	-	-		
		3.CORE LOSS & HOTSPOT	MA	ELECT.TEST	-DO-	-DO-	-DO-	Log Book	2	1*	1		
2.5	WINDING	1.COMPLETENESS	CR	VISUAL	100%	MANUFR'S SPEC./BHEL SPEC.	MANUFR'S SPEC./BHEL SPEC.	Log Book	2	-	-	FOR MV MOTOR	
		2.CLEANLINESS	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	-		
		3.IR-HV-IR	CR	ELECT. TEST	-DO-	-DO-	-DO-	Log Book	2	-	1		
		4.RESISTANCE	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1		
		5.INTERTURN INSULATION	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	-		
		6.SURGE WITH STAND AND TAN. DELTA TEST	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1		
2.6	IMPREGNATION	1.VISCOSITY	MA	PHY. TEST	AT STARTING	-DO-	-DO-	Log Book	2	-	-	THREE DIPS TO BE GIVEN	
		2.TEMP. PRESSURE VACCUM	MA	PROCESS CHECK	CONTINUOUS	-DO-	-DO-	Log Book	2	-	-		
		3.NO. OF DIPS	MA	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1		
BHEL			PARTICULARS			BIDDER/VENDOR							
			NAME										
			SIGNATURE										
			DATE						BIDDER'S/VENDORS COMPANY SEAL				

		QUALITY PLAN			CUSTOMER :			PROJECT TITLE			SPECIFICATION : NUMBER :		
SHEET 7 OF 9		BIDDER/ VENDOR			SYSTEM			QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03			SPECIFICATION : TITLE		
ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)		SECTION			VOLUME III								
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS	
1	2	3	4	5	6	7	8	9	P	W	V	11	
2.7	COMPLETE STATOR ASSEMBLY	4.DURATION	MA	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1		
2.8	BRAZING/COMPRESSION JOINT	1.COMPACTNESS & CLEANLINESS	MA	VISUAL	100%	-DO-	-DO-	Log Book	2	-	-		
2.9	COMPLETE ROTOR ASSEMBLY	1.COMPLETENESS	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	-		
		2.SOUNDNESS	CR	MALLET TEST & UT	-DO-	-DO-	-DO-	Log Book	2		1		
		3.HV	MA	ELECT. TEST	-DO-	-DO-	-DO-	Log Book	2		1		
2.10	ASSEMBLY	1.RESIDUAL UNBALANCE	CR	DYN. BALANCE	-DO-	MFG SPEC./ ISO 1940	MFG. DWG.	Log Book	2		1	VERIFICATION FOR MV MOTOR ONLY	
		2.SOUNDNESS OF DIE CASTING	CR	ELECT. (GROWLER TEST)	-DO-	MFG. SPEC.	MFG. SPEC.	Log Book	2		1		
2.10	ASSEMBLY	1.ALIGNMENT	MA	MEAS.	-DO-	-DO-	-DO-	Log Book	2	-	-		
		2.WORKMANSHIP	MA	VISUAL	-DO-	-DO-	-DO-	Log Book	2	-	-		
		3.AXIAL PLAY	MA	MEAS.	-DO-	-DO-	-DO-	Log Book	2	-	1		
		4.DIMENSIONS	MA	-DO-	-DO-	MFG.DRG./ MFG SPEC.	MFG. DRG/ RELEVANT IS	Log Book	2	-	-		
		5.CORRECTNESS, COMPLETENESS TERMINATIONS/ MARKING/ COLOUR CODE	MA	VISUAL	100%	MFG SPEC. RELEVANT IS	MFG SPEC. RELEVANT IS	Log Book	2	-	-		
		6. RTD, BTD & SPACE HEATER MOUNTING.	MA	VISUAL	100%	MFG SPEC. RELEVANT IS	MFG SPEC. RELEVANT IS	Log Book	2		1		
BHEL			PARTICULARS			BIDDER/VENDOR							
			NAME										
			SIGNATURE										
			DATE									BIDDER'S/VENDORS COMPANY SEAL	

		QUALITY PLAN			CUSTOMER :		PROJECT		SPECIFICATION :			
					BIDDER/ VENDOR :		TITLE		NUMBER :			
		SHEET 8 OF 9		SYSTEM		QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03		SPECIFICATION : TITLE				
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	SECTION VOLUME III			
1	2	3	4	5	6	7	8	9	P	W	V	REMARKS
3.0	TESTS	1.TYPE TESTS INCLUDING SPECIAL TESTS AS PER BHEL SPEC.	MA	ELECT.TEST	1/TYPE/SIZE	IS-325/ BHEL SPEC./ DATA SHEET	IS-325/ BHEL SPEC./ DATA SHEET	TEST REPORT	2	1*	1	* NOTE - 1
		2.ROUTINE TESTS INCLUDING SPECIAL TEST AS PER BHEL SPEC.	MA	-DO-	100%	-DO-	-DO-	-DO-	2	1 ^{\$}	1	^{\$} NOTE - 2
		3.VIBRATION & NOISE LEVEL	MA	-DO-	100%	IS-12075 & IS-12065	IS-12075 & IS-12065	-DO-	2	1 ^{\$}	1	^{\$} NOTE - 2
		4.OVERALL DIMENSIONS AND ORIENTATION	MA	MEASUREMENT & VISUAL	100%	APPROVED DRG/DATA SHEET	APPROVED DRG/DATA SHEET & RELEVANT IS	INSPC. REPORT	2	1	-	
		5.DEGREE OF PROTECTION	MA	ELECT. & MECH. TEST	1/TYPE/ SIZE	RELEVANT IS	BHEL SPEC. AND DATA SHEET	TC	2	-	1	TC FROM AN INDEPENDENT LABORATORY, REFER NOTE-3
		6. MEASUREMENT OF RESISTANCE OF RTD & BTD	MA	-DO-	100%	-DO-	-DO-	-DO-	2	1 ^{\$}	1	^{\$} NOTE - 2
		7. MEASUREMENT OF RESISTANCE, IR OF SPACE HEATER	MA	-DO-	100%	-DO-	-DO-	-DO-	2	1 ^{\$}	1	^{\$} NOTE - 2
		8. NAMEPLATE DETAILS	MA	VISUAL	100%	IS-325 & DATA SHEET	IS-325 & DATA SHEET	INSPC. REPORT	2	1 ^{\$}	1	^{\$} NOTE - 2
		9.EXPLOSION FLAME PROOF NESS (IF SPECIFIED)	MA	EXPLOSION FLAME PROOF TEST	1/TYPE	IS-3682 IS-8239 IS-8240	IS-3682 IS-8239 IS-8240	TC	2	-	1	TC FROM AN INDEPENDENT LABORATORY, REFER NOTE-3
		10. PAINT SHADE, THICKNESS & FINISH	MA	VISUAL & MEASUREMENT BY ELKOMETER	SAMPLE	BHEL SPEC. & DATA SHEET	BHEL SPEC. & DATA SHEET	TC	2	1 ^{\$}	1	SAMPLING PLAN TO BE DECIDED BY INSPECTION AGENCY ^{\$} NOTE - 2
BHEL			PARTICULARS		BIDDER/VENDOR							
			NAME									
			SIGNATURE									
			DATE					BIDDER'S/VENDORS COMPANY SEAL				

		QUALITY PLAN			CUSTOMER :			PROJECT TITLE			SPECIFICATION : NUMBER :		
		SHEET 9 OF 9			BIDDER/ VENDOR :			QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03			SPECIFICATION : TITLE		
SL. NO.		COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	SECTION VOLUME III			REMARKS
1		2	3	4	5	6	7	8	9	10			11
<p>NOTES:</p> <p>1 DEPENDING UPON THE SIZE AND CRITICALLY, WITNESSING BY BHEL SHALL BE DECIDED.</p> <p>2 ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON.</p> <p>3 IN CASE TEST CERTIFICATES FOR THESE TESTS ON SIMILAR TYPE, SIZE AND DESIGN OF MOTOR FROM INDEPENDENT LABORATORY ARE AVAILABLE, THESE TEST MAY NOT BE REPEATED.</p> <p>4 WHEREVER CUSTOMER IS INVOLVED IN INSPECTION, AGENCY (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER.</p> <p><u>Legends for Inspection agency</u></p> <p>1. BHEL/CUSTOMER 2. VENDOR (MOTOR MANUFACTURER) 3. SUB-VENDOR (RAW MATERIAL/COMPONENTS SUPPLIER)</p> <p>P. PERFORM W. WITNESS V. VERIFY</p>													
BHEL				PARTICULARS				BIDDER/VENDOR					
				NAME									
				SIGNATURE									
				DATE								BIDDER'S/VENDORS COMPANY SEAL	

**IB THERMAL POWER STATION, BANHARPALI
2 X 660 MW UNITS 3&4**

VOLUME -III

**TECHNICAL SPECIFICATION
FOR
MISCELLANEOUS PUMPS**

Specification No. : PE-TS-391-100-N001 (REV. 0)



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
PPEI BUILDING, SECTOR 16 A
NOIDA - 201301**



PREAMBLE

SPECN. NO.:

PE-TS-391-100-N001

REV. NO.

0

DATE:

12.08.14

1.0 The tender document contains three (3) volumes. The bidder shall meet the requirements of all the three volumes.

1.1 Volume - I CONDITIONS OF CONTRACT

This consists of four parts as below:

Volume - I A : This part contains instructions to bidders for making bids to BHEL.

Volume - I B : This part contains general commercial conditions of the tender and include provision that vendor shall be responsible for the quality of item supplied by their sub-vendors.

Volume - I C : This part contains special conditions of contract.

Volume - I D : This part contains commercial conditions for erection and commissioning site work, as applicable.

1.2 Volume - TECHNICAL SPECIFICATIONS

Technical requirements are stipulated in Volume II which comprises of:

Volume - II A : General Technical Conditions

Volume - II B : Technical specification including drawings, if any

1.2.1 Volume - II B :

This volume is sub-divided into following sections:

Section - A : This section outlines the scope of enquiry.

Section - B : This section provides "Project Information"

Section - C : This section indicates technical requirements specific to the contract, not covered in Section-D.

Section - D : This section comprises of technical specifications of equipments complete with data sheet A, B & C.

Data sheet - A specifies data and other requirements pertaining to the equipment.


Data sheet - B specifies data to be filled by the bidder (Data Sheet B is contained in Volume - III)

Data sheet - C indicates data documents to be furnished after the award of contract as per agreed schedule by the vendor (as applicable).

1.2.2 Volume - III TECHNICAL SCHEDULES

This volume contains technical schedules and Data Sheets - B, which are to be duly filled by the bidder and the same shall be furnished with the technical bid as per checklist, sec B7 in vol III

2.0 The requirements mentioned in Section C/Data Sheets-A of Section-D shall prevail and govern in case of conflict between the same and the corresponding requirements mentioned in the descriptive portion in Section - D.

	TECHNICAL SPECIFICATIONS	SPECN. NO.:	PE-TS-391-100-N001	
	MISCELLANEOUS PUMPS	VOLUME:	III	SECTION:
		REV. NO.	0	DATE:

INDEX

SECTION	TITLE
A	DOCUMENTS TO BE SUBMITTED ALONG WITH THE OFFER
A.1	COMPLIANCE CERTIFICATE
A.2	SCHEDULE OF DEVIATIONS
A.3	SCHEDULE OF PERFORMANCE GUARANTEE
A.4	SCHEDULE OF PRICES
A.5	SCHEDULE OF UNIT PRICES
A.6	INPUTS FOR HT MOTORS
A.7	GENERAL ARRANGEMENT DRAWING
B	DOCUMENTS TO BE SUBMITTED ON PLACEMENT OF LOI
B.1	PUMP DATA SHEET -B ALONG WITH PERFORMANCE CURVE
B.2	GA & CROSS SECTIONAL DRAWING
B.3	PUMP QAP
B.4	MOTOR DATASHEET -C ALONG WITH OTHER MOTOR DOCUMENTS
B.5	MOTOR QAP
B.6	ELECTRICAL LOAD DATA
B.7	SCHEDULE AS PER LIST



TECHNICAL SPECIFICATIONS

SPECN. NO.:

PE-TS-391-100-N001

MISCELLANEOUS PUMPS

VOLUME:

III

SECTION:

A

REV. NO.


0

DATE:

12.08.14

DOCUMENTS TO BE SUBMITTED ALONG WITH THE OFFER

- A1 COMPLIANCE CERTIFICATE
- A2 SCHEDULE OF DEVIATIONS
- A3 SCHEDULE OF PERFORMANCE GUARANTEES
- A4 SCHEDULE OF PRICES
- A5 SCHEDULE OF UNIT PRICES
- A6 INPUTS FOR HT MOTORS
- A7 GENERAL ARRANGEMENT DRAWING

	TECHNICAL SPECIFICATIONS	SPECN. NO.: PE-TS-391-100-N001			
	MISCELLANEOUS PUMPS COMPLIANCE CERTIFICATE	VOLUME:	III	SECTION:	A1
		REV. NO.	0	DATE:	12.08.14
<p>The bidder shall confirm compliance with following by signing/ stamping this compliance certificate and furnish same with the offer.</p> <p>a) The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions/ deviations with regard to same.</p> <p>b) QP/ test procedures shall be submitted in the event of order based on the guidelines given in the specification & QP enclosed therein.</p> <p>QP will be subject to BHEL/ CONSULTANT/ CUSTOMER approval in the event of order & customer hold points for inspection/ testing shall be marked in the QP at the contract stage. Inspection/ testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc.</p> <p>c) All drawings/data – sheets etc. to be submitted during contract shall be subject to BHEL/ CONSULTANT/ CUSTOMER approval.</p> <p>d) There are no other deviation with respect to specification other than those furnished in the ‘Schedule of Deviations’.</p> <p>e) Mandatory spares as indicated in Datasheet A shall be included in the base price</p> <p>Any mandatory spares stated as not applicable, shall have to be supplied without any cost implication to BHEL in the event they are found to be applicable during detail engineering stage.</p> <p>f) The offered materials should be either equivalent or superior to those specified. Also for components where material is not specified it shall be suitable for intended duty. All materials shall be subject to approval in the event of order.</p> <p>g) Prices for recommended spares (if any) for 3 years operation shall be furnished separately & not included in the base price.</p> <p>h) The commissioning spares (if any) are supplied on ‘As Required Basis’ & prices for same included in the base price (If bidders reply to this is “No commissioning spares are required” and if some spares are actually required during commissioning same shall be supplied by bidder without any cost to BHEL).</p> <p>i) All sub vendors shall be as per BHEL/CONSULTANT/CUSTOMER approved list.</p> <p>j) Tests for noise, vibration, parallel running etc. for pumps shall be conducted at site by BHEL and if the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, at his own cost.</p> <p>k) Any special tools & tackles, if required, shall be in bidder’s scope.</p> <p>l) All models offered have been supplied by bidder in the past and are meeting the experience qualifying criteria of BHEL/CONSULTANT/CUSTOMER (viz. offered model is successfully operating in two separate stations for at least two years as on the date of submission of the offer). Any deviation to this criteria shall be suitably highlighted in deviation schedule.</p> <p>m) All selected motor ratings have minimum margins as per Datasheet A, Section D1 of Vol IIB</p> <p>We the undersigned hereby undertake to meet the compliance requirements as listed above on the conditions as elsewhere specified.</p>					
PARTICULARS OF BIDDER/ AUTHORISED REPRESENTATIVE					
NAME	DESIGNATION	SIGNATURE	DATE	COMPANY SEAL	

**SCHEDULE OF PERFORMANCE GUARANTEES****2 X 660 MW IB VALLEY TPS, BANHARPALI**

SPECN. NO.:	PE-TS-391-100-N001		
VOLUME:	III	SECTION:	A3 Sheet 1 of 2
REV. NO.	0	DATE:	12.08.2014

Following parameters are guaranteed for following pumps

Sl. No.	Pump Description	Guaranteed Capacity	Guaranteed TDH	Guaranteed Pump Eff.	Guaranteed Motor Eff.	Guaranteed Power consumption at inlet to motor terminals	Pump model	Motor Rating	Pump GD ² Value for HT motor driven pump only	Pump RPM	Pump T/S Curve attached for HT motor selection
		(M3/Hr)	(MWC)	%	%	(KW)		(KW)			
Horizontal pumps (Group I)											
1	# DMCW TG AUX PUMPS	980	40		94						YES
2	# DMCW SG AUX PUMPS	1150	62		94						YES
3	# ACW PUMPS	3350	17		94						YES
4	# CYCLE MAKE UP PUMPS	60	55								
5	BOILER FILL PUMPS	200	150								
6	COMPRESSOR COOLING WATER PUMPS	170	20								

Note: 1 # Bid evaluation and LD is applicable for these pumps only as per clause 4.00.00 of std technical specn for pumps, section D1, Volume IIB.

We the undersigned hereby undertake to meet the performance guarantees as listed in the table above on the conditions as elsewhere specified. Any variation of the specified conditions during official tests will be taken in account by the customer

PARTICULARS OF BIDDER/ AUTHORISED REPRESENTATIVE

NAME	DESIGNATION	SIGNATURE	DATE	COMPANY SEAL
------	-------------	-----------	------	--------------

FORM No. PLM - 6036-0



TITLE

• SCHEDULE OF DEVIATIONS

- () From Conditions of Contract (Volume - I)
- () From General Technical Conditions (Volume - II A)
- () From Technical Specifications (Volume - II B)

SPECIFICATION NUMBER PE-TS-250-165-N001

VOLUME III SECTION A-2

SHEET . . . OF

Tick the applicable


Some items of deviation shall be listed in a separate sheet

We the undersigned hereby certify that the above mentioned are the only deviations.

PARTICULARS OF BIDDER / AUTHORIZED REPRESENTATIVE

PARTICULARS OF BIDDER / AUTHORIZED REPRESENTATIVE				
NAME	DESIGNATION	SIGNATURE	DATE	COMPANY SEAL

	TITLE:		SPECIFICATION NO.		PE-TS-391-100-N001																				
	SCHEDULE OF PRICES		VOLUME		III																				
			SECTION		A 4																				
	2 X 660 MW IB VALLEY TPS, BANHARPALI		REV. NO.		00																				
		DATE		12.08.14																					
		SHEET		1 OF 2																					
SL. No.	DESCRIPTIONS OF WORKS OR EQUIPMENT																								
1.0	<p>Total price for design, manufacture, assembly, inspection, testing, properly packed for transportation and delivery of Misc. pumps including motors, special tools/tackles, commissioning spares, installation checks and replacement of gland packing with mechanical seal arrangement (if applicable) at site, all accessories, auxiliaries etc and mandatory spares as specified in Technical specification for :</p> <p style="text-align: center;">Horizontal Pumps (Group I)</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 5%;">i)</td> <td style="width: 45%;">DMCW TG AUX PUMPS</td> <td style="width: 20%;">SIX (6) Nos.</td> <td rowspan="6" style="width: 10%; text-align: center; vertical-align: middle;">} Total Rs.</td> </tr> <tr> <td>ii)</td> <td>DMCW SG AUX PUMPS</td> <td>FOUR (4) Nos.</td> </tr> <tr> <td>iii)</td> <td>ACW PUMPS</td> <td>FOUR (4) Nos.</td> </tr> <tr> <td>iv)</td> <td>CYCLE MAKE UP PUMPS</td> <td>THREE (3) Nos.</td> </tr> <tr> <td>v)</td> <td>BOILER FILL PUMPS</td> <td>TWO (2) Nos.</td> </tr> <tr> <td>iv)</td> <td>COMPRESSOR COOLING WATER PUMPS</td> <td>ONE (1) No.</td> </tr> </table>						i)	DMCW TG AUX PUMPS	SIX (6) Nos.	} Total Rs.	ii)	DMCW SG AUX PUMPS	FOUR (4) Nos.	iii)	ACW PUMPS	FOUR (4) Nos.	iv)	CYCLE MAKE UP PUMPS	THREE (3) Nos.	v)	BOILER FILL PUMPS	TWO (2) Nos.	iv)	COMPRESSOR COOLING WATER PUMPS	ONE (1) No.
i)	DMCW TG AUX PUMPS	SIX (6) Nos.	} Total Rs.																						
ii)	DMCW SG AUX PUMPS	FOUR (4) Nos.																							
iii)	ACW PUMPS	FOUR (4) Nos.																							
iv)	CYCLE MAKE UP PUMPS	THREE (3) Nos.																							
v)	BOILER FILL PUMPS	TWO (2) Nos.																							
iv)	COMPRESSOR COOLING WATER PUMPS	ONE (1) No.																							
2.0	Price for site visit (per manday basis) (Optional and additional , apart from that included in 1.0 above))					Rs.																			
NOTE:	<p>1. Indicate all duties, taxes etc. stating whether included/ excluded in above price.</p> <p>2. Bidder to include cost of three site visits for three days each for installation check & replacement of gland packing with Mechanical seal (if applicable), in their base price in 1.0 above. Further optional & additional prices for site visit are to be quoted as per 2.0 above.</p>																								
Bidder shall furnish this price Schedule in his price offer only																									
PARTICULARS OF BIDDER/ AUTHORISED REPRESENTATIVE																									
NAME	SIGNATURE	DATE	COMPANY SEAL																						

	TITLE:	SPECIFICATION NO.	PE-TS-391-100-N001	
	SCHEDULE OF UNIT PRICES	VOLUME	III	
		SECTION	A 5	DATE 12.08.14
	2 X 660 MW IB VALLEY TPS, BANHARPALI	REV. NO.	0	SHEET 1 of 1
SL. No.	DESCRIPTIONS OF WORKS OR EQUIPMENT	PRICE (In Rs.)		
1.0	Unit price for Design, manufacture, inspection and testing, properly packed for transportation and delivery for following Pumps as specified in the Technical specification covering complete scope including installation checks and replacement of gland packing with mechanical seal arrangement (if applicable) at site, accessories etc.			
1.1	Pumps and Motor Unit price (Horizontal Pumps Group I):			
(i)	DMCW TG AUX PUMPS Pump price: Motor price: Pump/ Motor accessories (As applicable) Mandatory Spares	Rs. Rs. Rs. Rs.		HT MOTOR IN BHEL'S SCOPE
(ii)	DMCW SG AUX PUMPS Pump price: Motor price: Pump/ Motor accessories (As applicable) Mandatory Spares	Rs. Rs. Rs. Rs.		HT MOTOR IN BHEL'S SCOPE
(iii)	ACW PUMPS Pump price: Motor price: Pump/ Motor accessories (As applicable) Mandatory Spares	Rs. Rs. Rs. Rs.		HT MOTOR IN BHEL'S SCOPE
(iv)	CYCLE MAKE UP PUMPS Pump price: Motor price: Pump/ Motor accessories (As applicable) Mandatory Spares	Rs. Rs. Rs. Rs.		
(v)	BOILER FILL PUMPS Pump price: Motor price: Pump/ Motor accessories (As applicable) Mandatory Spares	Rs. Rs. Rs. Rs.		
(vi)	COMPRESSOR COOLING WATER PUMPS Pump price: Motor price: Pump/ Motor accessories (As applicable)	Rs. Rs. Rs.		
(VII)	Cost of Site visits for Installation checks and replacement of Gland packing with Mechanical seal (As applicable)	Rs.		
2.0	NOTES: a) Total price of Unit Prices given above should tally with Total price given in Sl. No. (1) of "Schedule of Prices" . In case of discrepancy, the lowest of two shall be considered for ordering. Bidder to note that prices mentioned in the "Schedule of prices" and "Schedule of Unit Prices" shall be binding for evaluation purposes. b) Unit price quoted by bidder, as above, shall be binding for any quantity variation, which is at the discretion of purchaser. c) Price of commissioning & erection spares and other accessories not listed above shall be included in the price of pump & shall be supplied with the pump. d) Indicate all taxes, duties etc. stating whether included/ excluded in above prices.			
Bidder shall furnish this price Schedule in his price offer only				
	NAME	DESIGNATION	SIGNATURE	DATE
				COMPANY SEAL



TECHNICAL SPECIFICATIONS

SPECN. NO.:

PE-TS-391-100-N001

MISCELLANEOUS PUMPS

VOLUME:

III

SECTION:

B

REV. NO.


0


DATE:


12.08.14


DOCUMENTS TO BE SUBMITTED ON PLACEMENT OF LOI

- B.1 PUMP DATA SHEET -B ALONG WITH PERFORMANCE CURVE
- B.2 GA & CROSS SECTIONAL DRAWING
- B.3 PUMP QAP (REFER STANDARD PUMP QP ATTACHED AT SECTION D OF VOL II B)
- B.4 MOTOR DATASHEET -C ALONG WITH OTHER MOTOR DOCUMENTS
- B.5 MOTOR QAP (REFER STANDARD MOTOR QP ATTACHED AT SECTION D OF VOL II B)
- B.6 ELECTRICAL LOAD DATA
- B.7 SCHEDULE AS PER LIST

		PROJECT:		VENDOR DOC. NO.	REV NO.
		MISCELLANEOUS PUMPS DATASHEET - B		BHEL DOC. NO.	REV NO.
SL.	DESCRIPTION	UOM	PUMP DATA	PUMP DATA	PUMP DATA
1.0	GENERAL				
1.1	Designation of the Pump				
1.2	Manufacturer				
1.3	Model No.				
1.4	No. of pumps	Nos.			
1.5	System Design Pressure	Kg/cm ²			
1.6	Specific Gravity of fluid to be handled	-			
2.0	PERFORMANCE PARAMETERS				
2.1	Performance standard				
2.2	Rated capacity. (No negative tolerance)	M ³ /hr			
2.3	Total Dynamic Head (TDH) at rated capacity (No negative tolerance)	MWC			
2.4	Shut off head	MWC			
2.5	Range of Operation of the Pump				
	a) Min.Flow	M ³ /hr			
	b) Max.Flow	M ³ /hr			
2.6	The pumps offered have continuously rising head capacity curves from the duty point towards shut off point.				
2.7	The pumps offered have stable rising H-Q curves within the "Range of Operation"				
2.8	Pump rated speed	RPM			
2.9	Vibration measurements				
2.9.1	Max.value of vibration on any pump /motor bearing w.r.t. velocity (Vrms) as per ANSI/ HIS 9.6.4 for speed > 600 RPM				
	a) Guaranteed at manufacturer's works	mm/s			
	b) Guaranteed at site	mm/s			
2.9.2	Max.value of vibration on any pump /motor bearing w.r.t. peak to peak amplitude as per ANSI/ HIS 9.6.4 for speed <= 600 RPM				
	a) Guaranteed at manufacturer's works	microns			
	b) Guaranteed at site	microns			
2.10	Max. noise Level (Guaranteed at site)	dB			
2.11	Guaranteed Pump efficiency at rated head & rated capacity without -ve tolerance	%			
2.12	Power consumption				
	a) Guaranteed pump input power at duty point	KW			
	b) Guaranteed max. Pump input power within range of operation.	KW			
	c) Max. pump input power at shut off	KW			
	d) Guranteed power at motor input	KW			
2.13	NPSH required at rated capacity	MWC			
3.0	DESIGN & CONSTRUCTION FEATURES				
3.1	Type of pump casing				
3.2	Pump duty				
3.3	Type of Impeller				
3.4	Location				
3.5	Pump suitable for parallel operation				
3.6	Torque speed curve of the pump & drive motor furnished for pumps with drive motor rating of 100 KW and above.				
3.7	Pump number of stages				


		PROJECT:		VENDOR DOC. NO.	REV NO.
		MISCELLANEOUS PUMPS DATASHEET - B		BHEL DOC. NO.	REV NO.
SL.	DESCRIPTION	UOM	PUMP DATA	PUMP DATA	PUMP DATA
3.8	Specific speed $N = \text{RPM} \times (\text{Flow in USGPM})^{1/2}$ (Head in Ft.) ^{3/4}				
3.9	Minimum suction head required in MLC for pump operation at maximum discharge point within the 'Range of Operation' specified (NPSHR at max. flow).				
3.10	Whether pump is suitable/ designed so that pump internals can be attended without disturbing suction and discharge piping.				
3.11	Type of coupling between pump & motor				
3.12	Bearing (DE & NDE)				
	a) Type and manufacturer				
	b) Bearing no.				
	c) Type of lubrication				
	d) Design life (Hrs.)				
3.13	Shaft Sealing arrangement				
	a) Type and manufacturer				
	b) Sealing liquid				
	c) Requirement of external water if any				
	i) Quality				
	ii) Quantity/ Pump	M ³ /hr			
3.14	In case separate oil/grease/water pump or any such equipment required for bearing lubrication/stuffing box gland sealing, furnish full technical details of these equipment and their drive.				
4.0	MATERIAL OF CONSTRUCTION (Indicate applicable code/ standard)				
4.1	Casing				
4.2	Impeller				
4.3	Shaft				
4.4	Shaft sleeves				
4.5	Wear ring				
4.6	fasteners				
4.7	Gland				
4.8	Lantern ring				
4.9	Mechanical seals (faces)/				
	Gland packing				
4.10	Base plate				
5.0	CONNECTIONS AND OTHER DIMENSIONAL DETAILS				
5.1	Impeller diameter	mm			
6.0	DRIVE DATA				
6.1	Drive unit output at 50°C ambient condition	KW/ P			
7.0	INSPECTION & TESTING				
7.1	Material test				
7.2	Hydrostatic test pressure	Kg/cm ²			
7.3	Hydrostatic test duration	Min.			
7.4	Performance test on pump at shop				
7.5	Dyanamic balance test				
8.0	WEIGHT AND LOADING DATA				
8.1	Weight of the pump & drive assembly	Kg			
8.2	Weight of the heaviest piece to be handled	Kg			

		PROJECT:		VENDOR DOC. NO.	REV NO.
		MISCELLANEOUS PUMPS DATASHEET - B		BHEL DOC. NO.	REV NO.
SL.	DESCRIPTION	UOM	PUMP DATA	PUMP DATA	PUMP DATA
8.3	Size of base plate (length x width)	mm			
9.0 ADDITIONAL INFORMATION FOR VERTICAL PUMPS					
9.1	Type of pump				
9.2	No. of stages for Vertical Turbine Pump	Nos.			
9.3	Bowl Head	MLC			
9.4	Bowl Efficiency	%			
9.5	Setting Length	m			
9.6	Column pipe OD X Thickness	mm X mm			
9.7	No of column pieces	Nos.			
9.8	No of intermediate shafts	Nos.			
9.9	No of bearings	Nos.			
9.10	Type & make of Bearing				
9.11	Sealing/lubrication arrangement of bearings				
9.12	Capacity of overhead forced lubrication tank	m ³			
9.13	Nos of forced lubrication pumps	Nos.			
9.14	Capacity of forced lubrication pumps	m ³ /Hr			
9.15	TDH of forced lubrication pumps	MLC			

	TITLE	SPECIFICATION NO.
	MOTOR DATA SHEET - C	VOLUME Iii
		SECTION B
		REV NO. 00 DATE 12/08/2014
		SHEET 1 OF 2

S. No.	Description	Data to be filled by successful bidder
A.	General	
1	Manufacturer & country of origin	
2	Motor type	
3	Type of starting	
4	Name of the equipment driven by motor & Quantity	
5	Maximum Power requirement of driven equipment	
6	Rated speed of Driven Equipment	
7	Design ambient temperature	
B.	Design and Performance Data	
1	Frame size & type designation	
2	Type of duty	
3	Rated Voltage	
4	Permissible variation for	
5	a) Voltage	
6	b) Frequency	
7	c) Combined voltage & frequency	
8	Rated output at design ambient temp (by resistance method)	
9	Synchronous speed & Rated slip	
10	Minimum permissible starting voltage	
11	Starting time in sec with mechanism coupled	
12	a) At rated voltage	
13	b) At min starting voltage	
14	Locked rotor current as percentage of FLC (including IS tolerance)	
15	Torque	
	a) Starting	
	b) Maximum	
16	Permissible temp rise at rated output over ambient temp & method	
17	Noise level at 1.0 m (dB)	
18	Amplitude of vibration	
19	Efficiency & P.F. at rated voltage & frequency	
	a) At 100% load	
	c) At 75% load	

NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			

	TITLE	SPECIFICATION NO.
	MOTOR DATA SHEET - C	VOLUME Iii
		SECTION B
		REV NO. 00 DATE 12/08/2014
		SHEET 2 OF 2

S. No.	Description	Data to be filled by successful bidder
	c) At starting	
C.	Constructional Features	
1	Method of connection of motor driven equipment	
2	Applicable Standard	
3	DOP of Enclosure	
4	Method of cooling	
5	Class of insulation	
6	Main terminal box	
	a) Type	
	b) Power Cable details (Conductor, size, armour/unarmour)	
	c) Cable Gland & lugs details (Size, type & material)	
	d) Permissible Fault level (kArms & duration in sec)	
7	Space heater details (Voltage & watts)	
8	Flame proof motor details (if applicable)	
	a) Enclosure	
	b) suitability for hazardous area	
	i Zone	O / I / II
	ii Group	IIA / IIB / IIC
9	No. of Stator winding	
10	Winding connection	
11	Kind of rotor winding	
12	Kind of bearings	
13	Direction of rotation when viewed from NDE	
14	Paint Shade & type	
15	Net weight of motor	
16	Outline mounting drawing No (To be enclosed as annexure)	
D.	Characteristic curves/ drawings (To be enclosed for motors of rating \geq 55KW)	
	a) Torque speed characteristic	
	b) Thermal withstand characteristic	
	c) Current vs time	
	d) Speed vs time	

NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			

LOAD TITLE	RATING (KW / A)		UNIT (U)/STN (S)	Nos.		VOLTAGE CODE*	FEEDER CODE**	EMER. LOAD (Y)	CONT.(C)/ INTT.(I)	STARTING TIME >5 SEC (Y)	LOCATION	BOARD NO.	CABLE		BLOCK CABLE DRG. No.	CONTROL CODE	REMARKS	LOAD No.
	NAME PLATE	MAX. CONT. DEMAND (MCR)		RUNNING	STANDBY								SIZE CODE	Nos				
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19

ANNEXURE-II

NOTES: 1. COLUMN 1 TO 12 & 18 SHALL BE FILLED BY THE REQUISITIONER (ORIGINATING AGENCY); REMAINING COLUMNS ARE TO BE FILLED UP BY PEM (ELECTRICAL)
2. ABBREVIATIONS : * VOLTAGE CODE (7):- (ac) A=11 KV, B=6.6 KV, C=3.3 KV, D=415 V, E=240 V (1 PH), F=110 V (cc): G=220 V, H=110 V, J=48 V, K=+24V, L=-24 V
: ** FEEDER CODE (8):- U=UNIDIRECTIONAL STARTER, B=BI-DIRECTIONAL STARTER, S=SUPPLY FEEDER, D=SUPPLY FEEDER (CONTACTER CONTROLLED)



**LOAD DATA
(ELECTRICAL)**

JOB NO.	391	ORIGINATING AGENCY	PEM (ELECTRICAL)
PROJECT TITLE	2X660 MW IB VALLEY TPS, BANHARPALLI OPGCL	NAME	DATA FILLED UP ON
SYSTEM	MISC. PUMPS	SIGN.	DATA ENTERED ON
DEPTT. / SECTION	ELECTRICAL	SHEET 1 OF 1	REV. 00
			DE'S SIGN. & DATE

CHECKLIST — LIST OF SCHEDULES

Sl. No.	Form No.	Description	Tick Applicable Forms
1.	PEM-6024	Schedule of Drawings / Catalogues submitted with Bid	✓
2.	PEM-6025@	Schedule of Occurance of Key Events of Delivery, Erection & Commissioning	
3.	PEM-6026	Schedule of Equipment Manufacture, Despatch and Shipment to Site.	✓
4.	PEM-6027	Schedule of Weights & Dimensions	
5.	PEM-6028@	Schedule of Performance Guarantee	
6.	PEM-6030	Inspection Schedule	✓
7.	PEM-6031	Schedule of Cement and Steel and Quarterly Cement Requirement	
8.	PEM-6032	Schedule of Quarterly Requirement of Reinforcing Bars and Structural Steel	
9.	PEM-6033@	Bill of Quantities (Civil Works)	
10.	PEM-6035	Schedule of Bidder's Proposed Construction / Site Fabrication Facilities.	
11.	PEM-6036	Schedule of Deviations	✓
12.	PEM-6040	Schedule of Declaration	✓
13.	PEM-6041	Quality Plan	✓
14.	PEM-6042	Vendor's Drawings / Documents Schedule	✓
15.	PEM-6043@	Schedule of Occurance of Key Events for Civil / Structural Works	
16.	PEM-6046	Inspection Request	✓
17.	PEM-6051	Schedule of Prices	✓
18.	PEM-6052@	Schedule of Unit Prices	✓
19.	PEM-6053	Schedule of Prices for Commissioning & Mandatory Spares	✓
20.	PEM-6054	Schedule of Prices for Recommended Spares	✓
21.	PEM-6055	Schedule Prices for Erection and Maintenance Tools & Tackles	✓
22.	PEM-6056	Schedule of Bidder's Man-power for Supervision of E & C and their Charges.	✓
23.	PEM-6057	Schedule of Daily & Overtime Rates	
24.	PEM-6058	Schedule of Hire-charges for Construction / Site Fabrication Facilities	
For Forms marked with @ certain information to be filled by DEs - before issuing to bidder.			

FORM No. PEM - 6024-0



TITLE

**SCHEDULE OF DRAWINGS /
CATALOGUES SUBMITTED WITH BID**

SPECIFICATION NUMBER

VOLUME III PART - A

SHEET

Section C/D enclosed with the specification indicate the drawings / catalogues to be furnished with the bid. The bidder in addition to furnishing the same, can also include any other drawings / catalogues which he may desire to submit with the bid. This schedule duly lists out such drawings as enclosed by the bidder with the bid.

DRAWING / CATALOGUE NUMBER	DESCRIPTION	NUMBER OF SHEETS

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE

NAME	DESIGNATION	SIGNATURE	DATE	COMPANY SEAL



TITLE :
SCHEDULE OF OCCURRENCE OF KEY EVENTS
OF DELIVERY ERECTION AND
COMMISSIONING

SPECIFICATION NUMBER:

VOLUME III PART-A

Sheet of

EQUIPMENT/SYSTEM.	DESCRIPTION OF KEY EVENTS	MONTHS FROM (DATE OF LOI)

We the undersigned hereby undertake to meet the schedule of occurrence of the key event as listed above regarding the delivery, Erection & Commissioning of Equipment/System

PARTICULARS OF BIDDER/ AUTHORISED REPRESENTATIVE

FORM No. PEM - 6026-0



TITLE

**SCHEDULE OF EQUIPMENT,
MANUFACTURE, DESPATCH AND
SHIPMENT TO SITE**

SPECIFICATION NUMBER

VOLUME III PART - A

SHEET OF

Equipment / Major Bought-out Items	Time for Manufacture/ Procurement from Date of Issue of Letter of Intent (Weeks)	Time for Test, Dismantling Packing & Ready for Despatch (Weeks)	Time required for Shipment to Site (Weeks)	Total Time from Date of Issue of Letter of Intent to Shipment to Site (Weeks)

We, the undersigned hereby undertake to meet the above time schedule in weeks for manufacture, despatch and shipment of each equipment and procurement of major boughtout items as listed above.

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE

--	--	--	--

FORM No. PEM - 6027-0



TITLE

SCHEDULE OF WEIGHTS & DIMENSIONS

SPECIFICATION NUMBER

VOLUME III PART - A

SHEET _____ OF _____

The bidder shall state below the weights and dimensions of various packages for shipment covering the complete scope.

Description of Package(s)	Dimensions (in meters)	Weight (in tonnes)

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE

NAME	DESIGNATION	SIGNATURE	DATE	COMPANY SEAL

5

FORM No. PEM - 6030-0



INSPECTION SCHEDULE

SPECIFICATION NUMBER _____

P.O. NUMBER _____

VOLUME - PART-A

SHEET OF _____

S. No.	ITEM/COMPONENT	PLACE & ADDRESS OF TEST / INSPECTION	Scheduled Date of Inspection	Duration of Test / Inspection (in days)

This schedule shall be in line with specification and quality plan requirements. The information in this form shall be furnished after receipt of LOI / PO.

PARTICULARS OF VENDOR'S / AUTHORISED REPRESENTATIVE			
NAME	SIGNATURE	DATE	COMPANY SEAL

FORM No. PEM - 6040-0



TITLE

*** SCHEDULE OF DECLARATION**

SPECIFICATION NUMBER

VOLUME III PART - A

SHEET OF

DECLARATION

I.....certify that all the technical data and information pertaining to this specification are correct and are true representation of the equipment/system covered by our formal proposal number Dated..... and there is no deviation to the specification.

I hereby certify that I am duly authorised representative of the Bidder's company whose name appears above my signature.

Bidders Company Name

.....

Authorised representative's
Signature

.....

Name

.....

Bidder's Intent

The bidder hereby agrees to fully comply with the requirements and intent of this specifications for the price indicated.

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE

NAME	DESIGNATION	ADDRESS	TELEPHONE	COMPANY SEAL

* Bidder shall include this schedule both in technical and Price offers



QUALITY PLAN

COMPONENT / OPERATION	SHEET		OF		CUSTOMER		PROJECT TITLE		PACKAGE		
	CHARACTERISTIC CHECK	CAT.	TYPE / METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY		SECTION	VOLUME III
								P	W		
2	3	4	5	6	7	8	9	10			
											11
<p>BIBEL.</p> <p>PARTICULARS</p> <p>NAME</p> <p>SIGNATURE</p> <p>DATE</p> <p>BIDDER / VENDOR</p> <p>BIDDER'S / VENDORS COMPANY SEAL</p>											

INSTRUCTIONS FOR FILLING QUALITY PLAN
(Form No. PEM-6042-0)

The Quality Plan shall include all the Quality Control Measures and Checks adopted by the Vendor to ensure that the material/component/assembly/services supplied by him meet/will meet the requirements as per specifications and good practices. They shall include all stages of operation such as materials, processes, manufacture, assembly, packing and despatch. The following guide lines may be noted:

- Column 1- Serial Number
- Column 2- Component/Operation- The component and/or operation being checked shall be given here.
- Column 3- Characteristics check- The characteristics being checked shall be given here. e.g., chemical composition, mechanical properties, leak tightness, surface defects etc..
- Column 4- Category - 'CR' stands for critical characteristic - affecting safety of equipment and personnel
'MA' stands for major Characteristic - affecting safety of equipment and personnel
'MI' stands for minor characteristic - affecting appearance etc.
- Column 5- Type/Method of check e.g. chemical analysis tensile testing, hydraulic test, visual examination radiography etc.
- Column 6- Extent of check, such as, 100, 10, 1 per heat etc.
- Column 7- Reference Documents - Documents, such as technical specification, drawings, standard specifications (IS, BS ETC.) procedure, etc. according to which check is done.
- Column 8- Acceptance Norms - Standards etc. according to which acceptability or otherwise of the characteristics being checked is decided.
- Column 9- Format of Record - Formats, log sheets, reports, etc. in which the observations are recorded. Standard log sheets, reports, formats etc. of the Vendors shall be numbered and such reference numbers shall be included here.
- Column 10- Agency - The agency which performs the test/instruction shall be written in sub-column 'W'
The agency which verifies test certificates/inspection records and carries out audit check of the components/operation shall be written in sub-column 'V'
The agencies are codified '1' stands for (BHEL)
as 1,2 & 3 '1*' means the operation shall be cleared by BHEL before the start of the next operation.
'2' Stands for Vendor
'3' stands for sub-Vendor of the Vendor and so on.

Example :

- Entry '3' in column 'P' means test/inspection to be performed by sub-Vendor's QC
- Entry '2' in column 'W' means test/inspection to be witnessed by Vendor's QC
- Entry '1' in column 'V' means verification shall be done by BHEL and next stage to be started only after the hold point is cleared by BHEL
- Column II- Remarks - Any special remarks shall be given here.

NOTES :

1. In absence of correlation with the test certificate(s) (e.g. material identification) samples shall be drawn by BHEL and all tests as per relevant specifications shall be carried out in their presence or in recognized Government Laboratory.
2. When materials and components are initially identified and stamped by BHEL QS engineer, the identification marks shall be preserved till despatch. Wherever this is not possible, the identification mark shall be transferred to the components in the presence of BHEL QS Engineer unless otherwise agreed.
3. For castings and forgings integral test specimens shall be provided. When this is not possible for casting, they shall be poured in the presence of BHEL QS Engineer unless otherwise, if witnessing of test by BHEL is called for.
4. When welders qualified by reputed inspection agencies or statutory bodies are not available, qualification tests shall be conducted in the presence of BHEL QS Engineer.
5. This Quality Plan is liable to be modified as per the requirements of approved drawings and changes in technical specifications/drawings. If there are contradictions in respect of column 7 & 8 between this Quality Plan and the approved drawings specifications, the latter shall prevail.
6. Wherever inspection by BHEL's Purchaser/Third Party/Statutory authorities are mandatory, this shall be complied with.
7. Inspection reports, log sheets, test reports/certificate, etc. shall be furnished to BHEL at the appropriate stage or at the time of final inspection, as required.
8. This Quality Plan is also applicable to spares, if any, under scope of supply of Vendor.
9. The quality plan shall be submitted in septuplicate (7 Copies).



**VENDOR'S
DRAWINGS/DOCUMENTS SCHEDULE**
(Information in this form is to be furnished
only after receipt of LOI/IPO)

SPECIFICATION NO	
VOLUME	III
SECTION	PART-A
REV NO.	0
SHEET 1 OF 1	

TITLE OF SPECIFICATION

S. NO.	Vendor's Drawing/Document No. (VDN)	PEM's Drawing/Document No. (PDN)	First Submission Date
	TITLE		Final Approval Date
	VDN	PDN	
	TITLE		
	VDN	PDN	
	TITLE		
	VDN	PDN	
	TITLE		
	VDN	PDN	
	TITLE		
	VDN	PDN	
	TITLE		
	VDN	PDN	
	TITLE		
	VDN	PDN	
	TITLE		

PARTICULARS OF VENDOR'S/AUTHORISED REPRESENTATIVE			
NAME	SIGNATURE	DATE	COMPANY SEAL



VENDOR's
DRAWINGS/DOCUMENTS SCHEDULE
(Information in this form is to be furnished
only after receipt of LOI/IPO)

SPECIFICATION NO

VOLUME III

SECTION PART-A

REV NO. 0

SHEET 1 OF 1

INSPECTION REQUEST
(From Vendor to BHEL Inspection Agency)

1. PROJECT TITLE

2. NAME OF VENDOR

3. BHEL'S LOI/PO NO

DATE

4. SYSTEM/ITEM DESCRIPTION

5. ITEM BEING OFFERED FOR INSPECTION WITH SL. NO. AS PER LOI/PO/BILLING SCHEDULE

6. DESCRIPTION AND SL. NO. OF INSPECTION AS PER QUALITY PLAN

7. QUANTITY OFFERED FOR INSPECTION

8. PLACE OF INSPECTION (FULL ADDRESS AND NAME OF SUB-VENDOR, IF ANY)

PLACE

ADDRESS

.....

9. CONTACT PERSON (FOR SL. NO. 8 ABOVE)-

NAME DESIGNATION

TELEPHONE FAX TELEGRAM TELEX

10. THE FOLLOWING DOCUMENTS ARE APPROVED BY BHEL AND AVAILABLE AT PLACE OF INSPECTION :

- (A). QUALITY PLAN (B) DRAWINGS (C) DATA SHEETS, CHARACTERISTIC CURVES ETC.
(D). PLANT STANDARDS

11. REQUIRED DATE OF INSPECTION : LIKELY DURATION(No.of working days).....
WEEKLY OFF DAY WORKING HOURS

(At least 15 days prior notice shall be given by the Vendor to Inspection Agency)

We hereby certify that the above items are complete in all respects and have been fully inspected/tested by us and are found to be as per technical specification/approved drawings/data sheets/characteristic curves and are acceptable to our QC department. The detailed inspection and test reports of our QC department are enclosed.

VENDOR'S PARTICULARS

Name	Designation	Signature	Place	Date	Seal

FORM No. PEM - 6053-0



TITLE

*** SCHEDULE OF PRICES FOR
COMMISSIONING AND MANDATORY
SPARES**

SPECIFICATION NUMBER

VOLUME III

SHEET OF

The bidder shall indicate here the quantity required for erection / commissioning and mandatory spares for equipment as listed in Section-C / Section - D. If the listed spares are not adequate, then the bidder shall indicate those and additional spares considered necessary by him.

Type	Manufacturer's Drawing No. / Part of spare	Description	Material	Quantity per Unit / Equipment	Quantity Required	If set. Nos Per set	Delivery period (Weeks)	Unit Price (Rs.)	Total Price (Rs.)
Erection and Commissioning									
Mandatory Spares									
Additional Spares Mandatory Erection / Commissioning									

* Unpriced schedule shall also be furnished along with Part-A Schedule in Technical Bid.

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE

NAME									
------	--	--	--	--	--	--	--	--	--

COMPANY SEAL

FORM No. PEM - 6054-D



TITLE

*** SCHEDULE OF PRICES FOR RECOMMENDED SPARES**

SPECIFICATION NUMBER

VOLUME III

SHEET _____ OF _____

The bidder shall give below a list of spares recommended for three years (or as otherwise specified in section - C) for trouble free performance of the equipment / system offered.

S. No.	Manufacturer's Drawing No. / Part of spare	Description	Material	Quantity per Unit / Equipment	Quantity recommended	If set. Nos. Per set	Delivery period (Weeks)	Unit Price (Rs.)	Total Price (Rs.)
PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE									
NAME		DESIGNATION		SIGNATURE		DATE		COMPANY SEAL	

* Unpriced schedule shall also be furnished along with Part-A Schedule in Technical Bid.



TITLE
**SCHEDULE OF PRICE FOR ERECTION
 AND MAINTENANCE TOOLS & TACKLES**

SPECIFICATION NUMBER

 VOLUME III
 SHEET _____ OF _____

The bidder shall give below the list of erection and maintenance tools and tackles as offered by him. This shall also include the customer's list of maintenance tools, if specified in Section - C / Section - D.

S. No	Description of Tools & Tackles	Quantity offered	Unit Price (Rs.)	Total Price (Rs.)

NOTE : The hire charges for vendor's equipment called for in this schedule shall include the cost of consumables, operation services, depreciation, wear and tear as well as vendor's over head and profit. (These rates will be payable by customer to the vendor, only if the customer's requires the use of this equipment for carrying out his own work out side the scope of this contract.)

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE				
NAME	DESIGNATION	SIGNATURE	DATE	COMPANY SEAL

FORM No. PEM - 6056-D



TITLE
**SCHEDULE OF BIDDER'S MAN POWER
 FOR SUPERVISION OF E & C
 AND THEIR CHARGES**

SPECIFICATION NUMBER
 VOLUME III
 SHEET OF

The bidder shall indicate below, designation-wise, the personnel required for supervision of erection and commissioning and their charges.

SUPERVISION OF ERECTION

Sl. No.	Designation	Normal rate per day of 8 hours	Overtime rate per hour

SUPERVISION OF COMMISSIONING

Sl. No.	Designation	Normal rate per day of 8 hours	Overtime rate per hour

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE

--	--	--	--