

- NOTE :**
- 1.NO OF LCB JB'S IN EACH CRATE SHALL BE:4NOS
  - 2.OVERALL DIMENSIONS OF WOODEN CRATE:  
1100(L)X540(W)X1400(H)- app
  - 3.WOODEN PLANK LUMBER PART WIDTH:  
80MM TO 100MM. (THESE LUMBER PIECES WILL BE JOINT TOGETHER WITH LITTLE GAP FOR EXPANSION TO FORM THE SIDES OF THE CRATE)
  - 4.REINFORCEMENT PLANK SIZE: 50MM
  - 5.THICKNESS OF THE WOODEN PLANK: 20MM
  - 6.SPACE BETWEEN PLANKS: 45MM
  - 7.MATERIAL OF WOODEN PLANK:MIXED JUNGLE WOOD/BATTEN-WOODEN PACKING GRADE.
  - 8.EACH LCB JUNCTION BOX WILL BE WRAPPED IN A POLYTHENE BAG AND THEN PACKED IN A 3PLY/5PLY CARDBOARD BOX.
  9. FOUR SUCH BOXES WILL BE KEPT IN EACH WOODEN CRATE.
  - 10.THE INSIDE WALLS OF THE CRATE WILL BE PROVIDED WITH THERMOCOLE SHEETS. IN ADDITION THERMOCOLE SHEETS WILL BE PROVIDED IN BETWEEN INDIVIDUAL JUNCTION BOXES.
  - 11.SUITABLE PACKING STRIPS WILL BE USED INSIDE THE CRATE FOR THE BOXES.
  12. VENDOR SHALL SUBMIT A PACKING DRAWING FOR APPROVAL IN THE EVENT OF PO.

**PACKING DETAILS**

**NATIONAL THERMAL POWER CORPORATION LTD.  
STANDARD DRAWING**




BHARAT HEAVY ELECTRICALS LIMITED,  
UNIT: BOILER AUXILIARIES PLANT,  
RANIPET:632 406.

DEPT CODE	NAME	SIGN	DATE
DESN	E.ARULSELVI	<i>[Signature]</i>	08.03.16
CHD	E.ARULSELVI	<i>[Signature]</i>	08.03.16
APPD	MJM	<i>[Signature]</i>	08.03.16

REV	DATE	CHD	APPD

**TITLE  
PACKING DRAWING FOR JUNCTION BOX – RECOMMENDED**

SCALE : NTS



BHEL/BAP DRG NO.

**4-00-114-32201**

**REV 00**