

BHEL PEM-ELECTRICAL

PRE-QUALIFYING REQUIREMENTS FOR SCREENED CONTROL CABLES DOC. NO. PE-PQ-999-507-E016, REV. 2, dated 17.12.15

ITEMS : Screened control cables

SCOPE: Supply : YES; Erection & Commissioning : NO;

A) GENERAL CRITERIA FOR EVALUATION


1. Vendor should be a manufacturer of screened/ instrumentation control cables.
2. Availability of test reports of tests carried out at vendor's works to establish in-house capability to carry out all routine, type & acceptance as per relevant IS/ International standards on FRLS screened control cables (except UV radiation & hydraulic stability test which can be conducted at Govt. Lab/ Govt. approved Independent lab).
3. Capacity of manufacturing 200 km of screened control cables per month.
4. Manufactured and supplied at least one (1) km of FRLS cables.
5. Manufactured and supplied screened control cables upto 20 pairs.
6. Manufactured & supplied at least 1000 km of screened control cables in one or more orders and at least 200 km in one single order.
7. Minimum two (2) nos. purchase orders for screened control cables shall be submitted which should not be more than ten (10) years old from the date of application for registration or date of techno-commercial bid opening (as applicable) for establishing continuity in business.


Note :


Vendor(s) should submit relevant documents in support of above mentioned General Criteria.


B) PROJECT SPECIFIC CRITERIA AGAINST ENQUIRY


1. After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.
2. Consideration of offer will be subject to customer's approval of bidder (if applicable).
3. Any other project specific requirement shall be as per Annexure-I and bidder shall submit relevant supporting documents.


Manish Shukla 17/12/2015
[Technical Convenor]


SK Gurumukhi
[SH-E02]


Rajnish Goyal
[SH-E03]


Praveen Dutta
[SH-E01]


Meena Kesri
[DH-Electrical]

BHEL PEM-ELECTRICAL
PRE-QUALIFYING REQUIREMENTS FOR SCREENED CONTROL CABLES

ANNEXURE - I

PROJECT SPECIFIC CRITERIA AGAINST ENQUIRY

PROJECT: 1x800MW KOTHAGUDEM TPS

- NIL -

Priyanka
17.12.15

Priyanka Agrawal
Sr. Engineer

— on tour —

Subhash Singh
DGM

S.K. Gurumukhi
17/12/15
AGM

Meena Kesri
17.12.15
Meena Kesri
DH-Electrical