



SECTION A-A'

NOTE:-

1. Insulator tube assembly shall be compatible to SF6 gas.
2. Flanges (I and II) shall be machined to suit to insulating tube.
3. Parallelity of Flange assembly shall be maintained within 0.1 mm.
4. The Face of Flange-I and Flange-II Assembly shall be grounded to RAO.8 on Either side.

VAR ID	REMARKS	VAR ITEM NO	DESCRIPTION	DRAWING NO	ITNO	MATL CODE	MATL SPECN	UNIT	QTY
03	FLANGE-II	RD DG 4 35 0417 6113	AL ALLOY					06	
02	FLANGE-I	RD DG 4 35 0417 6112	AL ALLOY					06	
01	TUBE	RD DG 4 35 0417 6111	ASSEMBLY TESTED KEMAR BIERBY					06	

TYPE OF PRODUCT
NAME OF CUSTOMER
CGSM 145

BHARAT HEAVY ELECTRICALS LTD.
HYDERABAD

DEPT CODE	GRADE OF	SCALE	WEIGHT(KG)	DRAWING NO.	NO. OF
35	35	NTS		RD DG 4 35 0417 6110	0
TITLE					
INSULATING TUBE ASSY.					

REV.	DATE	ALTERED	REV.	DATE	ALTERED
		CHECKED			CHECKED

INVENTORY NO.	SIGN. AND DATE	REF. DRG. NO.
---------------	----------------	---------------