



Ref: BHE/PW/PUR/SKT- CVL/564 /Amd-01 (Page-1/3)

Dated: 02/02/2008

To,

ALL BIDDERS

Dear Sir,

SUB : AMENDMENT- 01- REG

NAME OF THE WORK: CIVIL, STRUCTURAL & ARCHITECTURAL WORK FOR MAIN POWER BLOCK ALONG WITH ITS AUXILIARIES AND BALANCE OF PLANT FOR 2x250 MW EXPANSION PROJECT (UNIT Nos. 3 & 4) AT SIKKA THERMAL POWER STATION, GUJARAT STATE ELECTRICITY CORPORATION LIMITED, DISTT. JAMNAGAR, GUJARAT

T. S. No. – BHE/PW/PUR/SKT- CVL/564

For the subject tender following amendments are issued :

1) Bidder may refer CI No : 5.1 (a,b,c,d,e & f) of Section-5 of Technical Bid- part-I – The existing clause stands deleted and is being superceded by the amendment as follows.

5.1 ACCOMMODATION, DRINKING WATER & LOCAL TRANSPORTATION FOR THE LABOURER

BHEL/Client will not provide any space or accommodation for Contractor's labourers. Contractor shall make his own arrangements for required accommodation of his labourers including arrangements for drinking water and transportation for the labourers.

2) Bidder may refer Price Bid –Part-II (Rate Schedule Item No. 2318): Supply of SS liner plates is being excluded from bidder's scope. These plates will be supplied free of cost by BHEL. Contractor's responsibilities with regard to collection from BHEL stores, return of excess materials & scrap etc for other free issue materials shall also be applicable for these liner plates.

Bidders may please note that supply of all other materials and consumables as required for carrying out this item of work is retained in bidder's scope. The amended item of work is as follows.

Bidders are requested to quote the rate for this item 2318 in the Price Bid- Part- II considering this amendment

SUB : AMENDMENT- 01- REG

2318 (Rev-01)	Fabrication and erection of 3.15 mm thick stainless steel liner of grade AISI-304; Finish Grade 2B (Cold rolled, Annealed & Pickled and Skin passed) on M.S. plate for inside surfaces of hopper & mouth of hopper of bunkers as directed by the Engineer including <u>supply</u> and fixing with stainless steel studs & bolts (including countersunk), welding etc. complete as per specifications and IS standards. Electrode classification shall be E308L for welding of stainless steel to stainless steel and E309 for stainless steel to mild steel etc. complete as per specifications, drawings and instructions of the Engineer.	MT	165
------------------	--	----	-----

3) Bidder may refer Clause 5.11.0 Section-5 of Technical Bid- part-I (Return of Materials)

This clause shall generally be applicable in respect of SS liner plates (free supply by BHEL) and the applicable penal rate for excess wastage of materials shall be Rs. 2,50,000/- per MT.

4) Some bidders asked clarification which are replied as below :

- a) Que : Spliting of the work
Ans : Not Permitted.
- b) Que : For Structural Steel Staging Work of TG Deck slabs we shall be allowed to use material issued to us by free of Charges
Ans : NOT Permitted.
- c) Increase in Taxes and duties
Ans : Bidder may pl refer CI No : 5.29.5 for this matter.

The amendment/clarification as mentioned above shall be a part of this tender specification. As such bidders are requested to consider above amendment/clarification while submitting their offers.

Bidders may please download these documents from web and enclose print out of same with technical bid duly counter signed by your authorized signatory and stamped with official seal as a token of your unqualified acceptance of this amendment.

All other terms & condition of the tender specification shall remain unchanged unless and otherwise expressly amended by BHEL.

Thanking you.

Yours faithfully

SR. MANAGER (PURCHASE)