



Ref: BHE/PW/PUR/RILNG - CVL/560./AMD-01 (Page-1/ 2) Dated: 18/02/2008

To,

ALL BIDDERS

Dear Sir,

SUB : AMENDMENT - 01 REG

NAME OF THE WORK: CIVIL, STRUCTURAL & ARCHITECTURAL WORK FOR MAIN POWER BLOCK COMRISES OF GT, GTG, STG, HRSG INCLUDING ITS AUXILIRIES AND BOP FOR 1x345.60 MW COMBINED CYCLE POWER PLANT AT RIL NAGOTHANE , Dist (Raigarh) M.S. **REF: SPECIFICATION NO. BHE/PW/PUR/RILNG - CVL/560.**

Bidder may refer "Part-II (Volume-III) Price Bid" issued against this tender. In BOQ, we have now included some new items and also revised some items considering bidders clarification. As such we are now issuing "Revised Price Bid- Part-II (Volume-II) –Revision-01"

Therefore earlier price bid "Part-II (Volume-III) Price Bid" shall be null & void. Bidders are hence requested to quote their prices in Revised Price Bid- Revision-01 enclosed with this amendment.

In case bidder quotes their price in earlier price bid, same shall not be considered as valid for price evaluation.

In this revised price bid we have considered bidder clarification and accordingly respective items have been revised /added. As such for earlier raised bidders clarifications shall not replied separately.

In case bidder has specific clarification on this Revised BOQ, same shall be clarified if bidder submitted their clarification **on or before 22/01/2008**. Any clarification after 22/01/2008 shall not be considered by us.

Some other clarifications are replied as below:

Que :1) Soil Investigation report, Tender Drawing

Ans : We are enclosing Plot Plan for the subject work. This drawing is indicative only, as such revised drawing shall be provided during execution of contract. At present soil investigation report is not ready hence cannot be provided. However the BOQ has been revised on the basis of soil investigation data as received from site .

Que:2) Royalty of excavated materials

Ans : Royalty is not applicable for excavated material generated from the Plat Area.

Que : 3) G.A. drawing for stop log gates, stationary Screen,

Ans: Design of these items are in bidder scope.

Cont...2

Ref: BHE/PW/PUR/RILNG - CVL/560./AMD-01 (Page-2/2) Dated: 18/02/2008
SUB : AMENDMENT - 01 REG

Que 4) MS Channel in structural item

Ans : MS Channel shall be provided by BHEL free of cost under the structural item.

Que : 5) Regarding Blasting

Ans : Only Controlled Blasting is allowed.

Que : 7) For Structural Steel work of GTG Dock Slab, bidder shall be allowed to use material issued by BHEL free of cost.

Ans : BHEL will not provide free issue material for above.

The answers/replies furnished above on bidders questions and amendment as mentioned above shall be a part of this tender specification. As such bidders are requested to consider above clarification/amendment while submitting their offers.

Bidders may please download these documents from web and enclose print out of same with technical bid duly counter signed by your authorized signatory and stamped with official seal as a token of your unqualified acceptance of this amendment.

The Last Date for offer submission for the subject tender is **28/02/2008**. **Bidders are requested to submit their most competitive offer on or before 6:00 pm (18:00 Hrs) of 28/02/2008 at our office**. The Technical Bids will be opened on 29/01/2008 at 11:00 am in our office. BHEL will not give any further extension for offer submission.

All other terms & condition of the tender specification shall remain unchanged unless and otherwise expressly amended by BHEL.

Thanking you.

Yours faithfully

SR. MANAGER (PURCHASE)

Encls : "Revised Price Bid- Part-II (Volume-II) –Revision-01" (One Book)