



AMENDMENT ON TECHNICAL SPECIFICATION FOR FUEL OIL HANDLING SYSTEM
1X800 MW KOTHAGUDEM TPS

SPECIFICATION NO.: PE-TS-410-166-A001

AMENDMENT NO # 4

REV. NO. 00

DATE: 20/07//2015

Page 1 of 1

The following modifications with respect to Technical Specification for **Fuel Oil Handling System** BHEL's Technical specification no **PE-TS-410-166-A001** shall apply. Bidder to note that existing clauses/details as appearing in the specification stands deleted and clauses/details as mentioned in "Modified to or Read as" column shall be applicable and complied by the bidder.

MODIFIED CLAUSES/PAGE NUMBERS.

SL NO.	VOL. NO.	SECTION/ DESCRIPTION	CLAUSE NO	PAGE NO	EXISTING CLAUSE/DETAILS	MODIFIED TO OR READ AS
1.	IIB	SECTION- C2A	6.02.16	42 OF 406	<u>Surface preparation and painting</u> And that for external shall be synthetic red lead. Finish coat for both internal and external surface shall be of synthetic enamel.	Specification for application of paints for external surfaces protection of Tank shall be as per clause no. 4.03.02, page no. 349 of 406. Final coat of paint on all the equipment's / item covered under the package shall be done at the time of handing over of package
2.	IIB	SECTION – C2A ANNEXURE-I	-	44 OF 406	-	Additional Requirement - Floor Coil heater in HFO tank Floor coil heater pipe slope inside the tank shall be restricted to 1:500. Accordingly, no. of sections to be decided.