

**CORPORATE PURCHASING SPECIFICATION**

AA 106 30

Rev. No. 10

PAGE 1 OF 2

**SEAMLESS FERRITIC ALLOY STEEL PIPES (Gr: P 22) FOR
HIGH TEMPERATURE SERVICE****ORDERING DESCRIPTION FOR ASME SA 335, P 22****1.0 GENERAL:**

The pipes shall conform to the latest version for ASME SA 335, Gr:P 22 and comply with the following additional requirements.

2.0 APPLICATION:

For high temperature service at stress levels and temperatures allowed by ASME Boiler & Pressure Vessel Code, Section I & Indian Boiler Regulations.

3.0 CONDITION OF MANUFACTURING:

Either hot finished or cold drawn, plain ends, unless other wise specified in BHEL order. ↑

4.0 TOLERANCES:

On outside diameter : $\pm 1\%$
Other tolerances : As per ASME SA 530.

5.0 HYDROSTATIC TEST / NDT:

Each length of pipe shall be subjected to Hydrostatic test as per ASME SA 530.

As an alternative to the Hydrostatic test, each length of pipe shall be subjected to NDT as given below:

- a) For thickness upto 3.6mm, inclusive, Eddy current test as per ASME SE 309 or for thickness upto 12mm, inclusive Flux leakage test can also be conducted as per ASME SE 570.

or

- b) Ultrasonic test as per ASME SE 213.

Norms of acceptance shall be as specified in the respective standards mentioned above.

Revisions :**Cl: 31.7.4 of MOM of MRC-FCF+HTM****APPROVED :****INTERPLANT MATERIAL RATIONALISATION
COMMITTEE-MRC (FCF+HTM)****Rev. No. 10****Amd.No.****Reaffirmed****Prepared****Issued****Dt. of 1st Issue****Dt: 25.05.2007****Dt :****Year :****HYDERABAD****Corp. R&D****July 1978**



6.0 INSPECTION AT SUPPLIER'S WORKS

BHEL's representative shall have free access at all times to all parts of the manufacture's works, until the work on the contract of BHEL is being performed. The manufacturer shall offer BHEL's representative all reasonable facilities, without charge, to satisfy the latter that the material is being furnished in accordance with the specification.

7.0 REPAIRS

7.1 Repairs involving fusion welding is prohibited.

7.2 When defects are repaired by mechanical means, the wall thickness requirements shall be satisfactorily met with and the surfaces shall be smoothly dressed up without any sharp edges.

8.0 CERTIFICATION

Test certificate shall be provided as per IBR FORM-III D issued by WELL KNOWN PIPE MAKER who is recognised by Central Boiler Board. Copy of certification of recognition as Well Known Pipe Maker in FORM XVI - G shall also be enclosed along with the test certificate.

Note: In lieu of IBR form III-D, the manufacturer can also submit test certificate in IBR form III-A duly inspected by IBR approved agency with prior written permission from BHEL."

9.0 PACKING AND MARKING

As per BHEL Standard AA 049 00 01.

10.0 REJECTION AND REPLACEMENT

If each length of pipe does not comply with the requirements of this specification during receipt inspection at BHEL or if any defect is found during further processing of pipes BHEL reserves the right to reject the whole consignment and the supplier shall replace the material free of cost. The rejected material shall be taken back by the supplier after fulfilling the commercial terms and conditions.



CORPORATE PURCHASING SPECIFICATION

AA 106 32

Rev. No. 06

PAGE 1 OF 2

**SEAMLESS FERRITIC ALLOY STEEL PIPES (Gr:P 11) FOR
HIGH TEMPERATURE SERVICE**

ORDERING DESCRIPTION FOR ASME SA 335, P 11

1.0 GENERAL:

The pipes shall conform to the latest version for ASME SA 335, Gr: P 11, and comply with the following additional requirements.

2.0 APPLICATION:

For high temperature service at stress levels and temperatures allowed by ASME Boiler & Pressure Vessel Code, Section I & Indian Boiler Regulations.

3.0 CONDITION OF DELIVERY:

Either hot finished seamless or cold drawn seamless, plain ends, unless other wise specified on BHEL order.

4.0 DIMENSIONS AND TOLERANCES:

4.1 Sizes:

Pipe OD X Thickness shall be as specified in BHEL order. Unless other wise specified, pipes shall be supplied in single random lengths of 5 to 7 metres.

4.2 Tolerances:

On outside diameter : $\pm 1\%$

Other tolerances : As per ASME SA 530

5.0 HYDROSTATIC TEST / NDT:

Each length of pipe shall be subjected to Hydrostatic test as per ASME SA 530.

As an alternative to the Hydrostatic test, each length of pipe shall be subjected to NDT as given below:

- a) For thickness upto 3.6mm, inclusive, Eddy current test as per ASME SE 309 or for thickness upto 12mm, inclusive Flux leakage test.

or

- b) Ultrasonic test as per ASME SE 213.

Norms of acceptance shall be as specified in the respective standards mentioned above.

Revisions :

Cl: 28.8.12 of MOM of MRC-FCF+HTM

APPROVED :

**INTERPLANT MATERIAL RATIONALISATION
COMMITTEE-MRC (FCF+HTM)**

Rev. No. 06

Amd.No.

Reaffirmed

Prepared

Issued

Dt. of 1st Issue

Dt: 01.01.2004

Dt :

Year :

HYDERABAD

Corp. R&D

April, 1986

**6.0 INSPECTION AT SUPPLIER'S WORKS:**

BHEL's representative shall have free access at all times to all parts of the manufacture's works, until the work on the contract of BHEL is being performed. The manufacturer shall offer BHEL's representative all reasonable facilities, without charge, to satisfy the latter that the material is being furnished in accordance with the specification.

7.0 REPAIRS:

Fusion welding is prohibited.

When done by mechanical means, the wall thickness is to be met with and the surfaces to be smoothly dressed up from any sharp edges.

8.0 CERTIFICATION:

Test certificate shall be provided as per IBR FORM-III D issued by WELL KNOWN PIPE MAKER who is recognised by Central Boiler Board. Copy of certification of recognition as Well Known Pipe Maker in FORM XVI - G shall also be enclosed along with the test certificate.

Note: In lieu of IBR form III-D, the manufacturer can also submit test certificate in IBR form III-A duly inspected by IBR approved agency with prior written permission from BHEL."

9.0 PACKING AND MARKING:

As per BHEL Standard AA 049 00 01.

10.0 REJECTION AND REPLACEMENT:

If each length of pipe does not comply with the requirements of this specification during receipt inspection at BHEL or if any defect is found during further processing of pipes BHEL reserves the right to reject the whole consignment and the supplier shall replace the material free of cost. The rejected material shall be taken back by the supplier after fulfilling the commercial terms and conditions.



CORPORATE STANDARD

AA 049 00 01

Rev. No. 04

PAGE 1 OF 3

PROCEDURE FOR MARKING AND PACKING OF SEAMLESS STEEL TUBES & PIPES

1.0 SCOPE

This standard specifies the requirements for marking and packing of seamless steel tubes and pipes.

2.0 MARKING

Sl. No.	Particulars	Upto & incl. 33.4 OD and thickness < 6 mm	Above 33.4 and up to & incl. 114.3 OD and thickness < 6 mm	Other sizes and thickness not covered in columns. (3) & (4)
(1)	(2)	(3)	(4)	(5)

I. DETAILS TO BE IDENTIFIED

1.	Purchase order No.	1 to 7 to be stamped	2,3,4 & 5 only to	3, 4, & 7 to be hard
2.	Marker's emblem	on aluminium metal	be paint stenciled	stamped on the
3.	Specn.No.& grade	tag and securely	on each tube.	body of pipes 2, 5
4.	Melt Number	attached to each	1 to 7 to be stamped	and 7 to be paint
5.	Size (OD X TK X length)	bundle	on aluminium metal	stenciled on the
6.	No. of tubes/pipes		tag and securely	pipes. (Alternatively
7.	Inspector's seal		attached to each	paint stenciled is
			bundle.	permitted on mutual
				agreement for 3, 4 & 7 only)

II	COLOUR CODING:	Circumferentially/ Longitudinally	Circumferentially/ Longitudinally	Circumferentially/ Longitudinally
----	-----------------------	--------------------------------------	--------------------------------------	--------------------------------------

Note: If specified on order, the colour code on pipes and tubes shall be as per Annexure - I

- 2.1** Stamping shall be done at about 100mm from the ends of the pipe with rounded letters and depth of stamping shall not exceed 0.5 mm.
- 2.2** Stainless steel tubes/pipes shall be paint stenciled only and the paint shall be free from corrosion promoting agents like sulphur and chlorine.
- 2.3** Marking shall be legibly done in ENGLISH language only, preferably with a stencil of 20 mm.

Revisions :

Cl. 27.6.2 of MRC – FCF+HTM

APPROVED :

INTERPLANT RATIONALIZATION
COMMITTEE-MRC (FCF+HTM)

Rev. No. 04

Amd.No.

Reaffirmed

Prepared
HYDERABAD

Issued
Corp. R&D

Dt. of 1st Issue
JUNE, 1978

Dt: 15.11.2002

Dt :

Year :



3.0 PRESERVATION

- 3.1 All painted details shall be protected with one coat of transparent rust preventive.
- 3.2 Other than stainless steel, all tubes and pipes shall be applied with rust preventive coating on the outside and either with a rust preventive coating or rust inhibitor on the inside **to provide protection against corrosion for a period of 3 months for out door storage in marine / industrial atmospheres.** For heat exchanger tubes, rust preventive coating shall given dry or wet type as specified in BHEL order.
- 3.3 The ends of the tubes/pipes shall be closed with end caps made of PVC /plastic which should be securely held so that it will not fall off during transit.

Note: The supplier must specify the type of rust preventive at the time of supply and also the method of its easy removal.

4.0 PACKING

- 4.1
- Tubes and pipes upto and including 33.4 mm OD and smaller shall be supplied in bundles.
 - Tubes and pipes above 33.4 to 114.3 OD shall also be supplied in bundles, whenever the wall thickness is less than 6.0 mm.
 - Tubes and pipes of OD above 33.4 mm and wall thickness above 6.0 mm shall be supplied loose.
- 4.2
- Weight of each bundle shall not exceed 1 metric ton.
 - No wooden pellets should be used to cover the tubes.
 - The bundle must be fastened by using galvanized wire / metal straps.
 - Two straps must be fastened one at each end of the bundle at one metre from the ends. For the balance length, there shall be a wire bundling at reasonable intervals.
- 4.3 All the tubes of wall thickness 3.2 mm and below shall be properly packed in wooden crates to avoid any dent formation and other transit damages to the tubes.
- 4.4 A packing list, sealed in a thick polythene cover, shall be sent along with each consignment with the following details:
- BHEL order number:
 - Number of bundles (including serial number also):
 - Material specification No. and grade:
 - Size of tube/pipe
 - Customer's Name



CORPORATE STANDARD

AA 049 00 01

Rev. No. 04

PAGE 3 OF 3

COLOUR CODES FOR TUBES AND PIPES

ANNEXURE - I

Specification	Colour - 1	Colour - 2	Colour - 3
13 x 1 MF	RED	YELLOW	-
13 Cr Mo 44	ALUMINIUM	BLACK	-
A 200 Gr. T5	ALUMINIUM	RED	YELLOW
A 200 Gr. T9	ALUMINIUM	GREEN	YELLOW
AISI 602	WHITE	YELLOW	-
API 5L Gr. B	ALUMINIUM	-	-
BS 3059 PART2 CDS /HFS 360	ALUMINIUM	BLACK	BROWN
BS 3602 PART 1 CDS 360	ALUMINIUM	BLACK	BLUE
NFA 49 - 213 42 C	ALUMINIUM	BLUE	BROWN
NFA49 - 213 TU 10 CD 9.10	ALUMINIUM	BLUE	RED
NFA49 - 213 TU 15 CD 2.05	ALUMINIUM	BLUE	GREEN
NFA49 - 213 TU Z10 CD 9	ALUMINIUM	BLUE	YELLOW
NFA49 - 213 TU Z10C VNSB 09.01	ALUMINIUM	GREEN	RED
SA 106 Gr. B	RED	-	-
SA 106 Gr. C	BLUE	-	-
SA 179	BLACK	BLUE	GREEN
SA 192	WHITE	-	-
SA 199 T5	BLUE	BROWN	RED
SA 209 Gr. T1	ALUMINIUM	RED	-
SA 210 Gr. A1	YELLOW	-	-
SA 210 Gr. C	BLUE	GREEN	-
SA 213 Gr. T11	ALUMINIUM	YELLOW	-
SA 213 Gr. T12	BROWN	YELLOW	-
SA 213 Gr. T2	BROWN	GREEN	-
SA 213 Gr. T22	GREEN	RED	-
SA 213 Gr. T5	BLACK	BROWN	GREEN
SA 213 Gr. T9	BROWN	WHITE	-
SA 213 Gr. T91	GREEN	YELLOW	-
SA 213 Gr. TP 304	BLUE	GREEN	YELLOW
SA 213 Gr. TP 304 H	BLACK	BLUE	YELLOW
SA 213 Gr. TP 304 L	BLUE	WHITE	YELLOW
SA 213 Gr. TP 304 M	BLACK	BROWN	YELLOW
SA 213 Gr. TP 316	BROWN	-	-
SA 213 Gr. TP 316 Ti	BLACK	BLUE	-
SA 213 Gr. TP 316L	BLUE	BROWN	YELLOW
SA 213 Gr. TP 321	BLUE	WHITE	-
SA 213 Gr. TP 321H	BLACK	WHITE	-
SA 213 Gr. TP 347H	BLACK	YELLOW	-
SA 268 Gr. TP 405	ALUMINIUM	GREEN	-
SA 268 Gr. TP 410	BROWN	RED	YELLOW
SA 268 Gr. TP 443	BLUE	GREEN	WHITE
SA 269 TP 315	GREEN	RED	YELLOW
SA 312 Gr. TP 304	BLUE	YELLOW	-
SA 312 Gr. TP 304L	BLUE	RED	YELLOW
SA 312 Gr. TP 316	BLACK	GREEN	-
SA 312 Gr. TP 304L	BLACK	BLUE	BROWN
SA 312 Gr. TP 321	BLUE	BROWN	-
SA 312 Gr. TP 3347	BLUE	RED	WHITE
SA 333 Gr. 1	BLACK	BROWN	RED
SA 333 Gr. 3	BLACK	GREEN	RED
SA 333 Gr. 6	BLUE	GREEN	RED
SA 334 Gr. 1	BROWN	GREEN	RED
SA 334 Gr. 3	BLACK	RED	YELLOW
SA 334 Gr. 6	BLACK	BLUE	RED
SA 335 Gr. P1	BROWN	GREEN	YELLOW
SA 335 Gr. P11	GREEN	WHITE	-
SA 335 Gr. P12	BLACK	RED	-
SA 335 Gr. P2	BLUE	BROWN	GREEN
SA 335 Gr. P22	BLUE	RED	-
SA 335 Gr. P5	BLACK	BROWN	-
SA 335 Gr. P29	ALUMINIUM	BROWN	-
SA 335 Gr. P291	BROWN	RED	-
SB 163 Incono1	BLACK	GREEN	YELLOW
ST 35.4	ALUMINIUM	BLUE	-
STEEL 20	GREEN	-	-
Structural Tubes & Pipes	BLUE	BROWN	WHITE
X20 Cr Mo V 121	BLACK	-	-

PIPESTECHNICAL BID

SL.NO	CONDITION	REQUIREMENT	SUPPLIERS REMARKS (YES / NO)
1. 1.1	Technical	Conforming in all respects to specification as per Enquiry. Mills Test Certificate shall be furnished as per BHEL Specification.	
2.	Length	The length of each pipe should as per Enquiry. All pipes should confirm to one length only.(BHEL reserves the right to accept or reject alternative length at its discretion)	
3	Minimum order quantity	Minimum order quantity is not acceptable. However on case to case basis, BHEL may consider at its discretion.	
4	Inspection Charges	Inspection charges to be included in the price. Do not mention Inspection charges as "Extra" or actuals. Such offers will be rejected.	
5	Name of Inspection Agency	As per BHEL Specification / Additional requirement as per Enquiry.	
6. 6.1 6.2	Mill details	Name of mill. Whether IBR approved (If Applicable)	
7	Mills T.C incase of ex-stock supplies	Copies to be furnished. Offers without TCs will be rejected. In case of ex-stock supplies.BHEL reserves the right to accept based on its experience with the mill.	
8	Ex- stock	Incase of ex-stock supplies, please confirm availability of entire enquiry quantity.	

COMMERCIAL BID

SL.NO	CONDITION	REQUIREMENT	SUPPLIERS REMARKS (YES / NO)
1	P & F Charges as per Specification	To be included in Price.	
2	Penalty	Penalty will be levied @ 1/2% per week for the quantity/ value of the undelivered portion of the order subject to a maximum of 10% of undelivered quantity/ value of order.	
3	Terms of Delivery	FOR-Destination for indigenous vendors CFR - Mumbai for imported vendors (The prices quoted should be inclusive of freight charges,insurance and inspection charges.Do not give break up of prices.Offer not coming to above will be rejected.	
4 4.1 4.2	Payment terms For indigenous vendors For foreign supplier:-	a) 100% payment on receipt and acceptance of material within 90 days from the dispatch/invoice (for other than SSI units)only. b) 100%payment on receipt and acceptance of material within 45 days from the date of despatch/invoice (for SSI units) only. c)Letter of Credit will be established 1 month prior to dispatch and valid for 3 months Bank charges. d) Bank charges: Your Bank Charges to your account and our Bank Charges to our account. NOTE: In case of deviation loading will be done @18% per annum.	

PIPES**TECHNICAL BID**

SL.NO	CONDITION	REQUIREMENT	SUPPLIERS REMARKS (YES / NO)
5	Validity	The offer should be valid for 90 days from the date of Price Bid opening.	
6	Guarantee	The material shall be guaranteed for a period of 12 months after putting into service or 24 months after despatch, whichever is later.	
7	Delivery	Delivery period from date of P.O. BHEL reserves the right to reject offers with unsuitable deliveries. No of weeks to be specified (Range is not acceptable).	
8	Rejection Replacement	In case of any rejections the supplier will be arranged immediate replacement.In case of imported supplies,all charges including clearing by customs documents this include CD + CVD etc. will be in the suppliers scope.	
9	Offers from other than registered vendors.	Vendors who are not registered with BHEL Hyderabad, should alongwith their offers, furnish complete information regarding their Mills, product range, available facilities, client list (especially of multinationals and public sector units in India) and financial statements.BHEL will scrutinise the documents submitted and will at its discretion accept or reject the offer. Clearance for dispatches will be given only after review of Test Certificates.	

NOTE:

1. BHEL Terms and Conditions of Contract (attached) are applicable.
2. BHEL reserves the right to reject incomplete / ambiguous offers without assigning any reason thereof.
3. The tenderer should only submit Technical / Commercial Bid and Price Bid only as per this format. Do not submit your offer on any other sheet.
4. Offers not meeting our requirement because of long delivery period are liable to be rejected by BHEL at its discretion.
5. Offers indicating "extra" or "at actuals" are not acceptable and are liable to be rejected.
6. The lowest bidder will be determined by Reverse Auction unless otherwise intimated.
7. Offers shall be submitted by manufacturers or their marketing agents. In case of offers through agent an authorisation letter with suitable validity should be furnished.
8. Orders will be finalised on lowest technically suitable offer basis item wise.
9. Prices should be firm till completion of supplies.
10. Tenderers who would like to register with BHEL as approved may fill up the questionnaire available in www.bhel.com and furnish separately.

Signature & Seal of tenderer
Date.