

ADDENDUM-005

Enquiry No- 77/15/6294/SK

Item: Clarifier Package for 2X660 MW Suratgarh project.

1. Extension of due date for submission of offers
2. Bidders queries and clarifications.

Due date for submission of Offer has been extended till 01.06.2016

Submission of offer by 02:00 PM on 01.06.2016

Opening of Techno commercial bid at 03:00 PM on 01.06.2016

Any further addendum such issued carry part of the bidding documents and this will be available at the web site from where the original documents have been received / downloaded by the bidder. Hence, bidders are requested to visit the web site on regular basis.

For Further Queries if any, Contact:

For Commercial:

Sh. Sushil Kumar

Sr. Engineer / Purchase
BHEL-ISG,
Prof.C.N.R.Rao Circle,
Bangalore-560 012
Off: 080 2218 4527,
E-mail: sk@bhelisg.com

For Technical (Mechanical):

Sh. Amit Gupta

Dy Manager / PE / Mech
BHEL-ISG,
Prof.C.N.R.Rao Circle,
Bangalore-560 012
Off: 080 2218 4282,
E-mail: amit@bhelisg.com

For Technical (Electrical):

Sh Venkateshwar Rao Vangla

Sr. Engineer/ PE/ Elec
BHEL-ISG
Prof.C.N.R.Rao Circle
Bangalore-560 012
Off: 080 2218 4077
E-mail: vvr@bhelisg.com

SI No	Bidders Query	BHEL-ISG Reply
1	The clarified water overhead storage tank MOC is given as PVC in document number IS-4-ES-844-300-MOO3, page 3 of 12, point no. 11. Please confirm.	Clarified water overhead tank shall be PVC.
2	Lime dosing system is not included in scope of supply. Please confirm. If required please suggest the dosage ppm of lime. Also please specify the preparation tank quantity & MOC and dosing pump quantity & MOC.	Chemical dosing shall be comprised of "Alum Dosing" & "Poly Electrolyte (PE) Dosing". Lime dosing not applicable.
3	Please confirm whether commissioning chemicals will be procured by you or not.	Commissioning chemical shall be in the bidder's scope for 07 days of requirement as clearly indicated in BOQ.