

Addendum-1:

| SI No | Bidder's Query | BHEL-ISG Reply |
|-------|---|---|
| 1 | DBR indicating the system capacity and quantity for each system along with P&I diagram, | DBR indicated for DE system capacity requirement. Preparation of P&ID and required system to full fill is in bidders scope as per spec requirement. |
| 2 | Capacity of compressor for DE system and scope of supply | plz note that as per tender scope compressor drier receiver are in bidders scope. Bidder to decide based on bag filter sizing. Please see the scope of work and price format before quote |