

ADDENDUM-4

DATE: 20-01-2016

Wagon Tippler, Side Arm Charger and Apron Feeder Package for 5X800 MW Yadadri TPS

Tender Ref : 77/15/6233/RCD

1. Pre-bid Queries & clarifications have been uploaded on the web.
2. Any further addendum such issued carry part of the bidding documents and this will be available at the website from where the original documents have been received / downloaded by the bidder. Hence bidders are requested to visit the website <https://bheleps.buyjunction.in> on regular basis.

For Further Queries if any, Contact:

For commercial :

Sh. Anand Aman

Sr. Engineer, Purchase/Works-1
BHEL-ISG,
Prof.C.N.R.Rao Circle,
Bangalore-560 012
Off: 080 2218 4134,
e-mail : ana@bhelisg.com

For Technical :

Sh. Umesh D

Engineer / PE / Mech
BHEL-ISG,
Prof.C.N.R.Rao Circle,
Bangalore-560 012
Off: 080 2218 4037,
e-mail : ud@bhelisg.com

Enquiry No: 77/15/6233/RCD

Wagon Tippler, Side Arm Charger, Apron Feeder Package for 5x800 MW Yadadri TPS of TSGENCO

Sr. No.	Clause Ref	Clause Description	Clarification	BHEL's reply
1	Doc. TSG/YTPS/WTPACKAGE, Sr. No. 15 sheet 25 of 38		Cables connecting from PLC JB to DCS is excluded from bidder's scope. Please confirm	Control and instrumentation cables between CHP DCS and WT PLC is excluded from bidders scope. However Bidder to note that the any cables (Like FO cable) which is required for establishing successful communication between main CHP DCS and WT PLC is under bidders scope as per enquiry specification. Please refer to sl no 15 ,sheet 25 of 38 for detailed split/scope matrix of cables between bidder & BHEL.
2	Doc. TSG/YTPS/WTPACKAGE, Sr. No. 15 b sheet 26 of 38		Control and instrumentation cable between WT MCC to WT PLC for all drive / equipments is in BHEL scope.	ok. However bidder to refer sl no 15 ,sheet 25 of 38 for detailed split/scope matrix of cables between bidder & BHEL.
3			We presume that PA System is excluded from bidder's scope.	Ok.
4			We presume that CCTV System is excluded from bidder's scope.	Ok.
5			We presume that fire detection and alarm system is excluded from bidder's scope.	Ok.
6	Doc. TSG/YTPS/WTPACKAGE, Sr. No. 15 f sheet 27 of 38		cable trays and accessories except for cable supplied by bidder is excluded from bidder's scope.	As per specification
7	Doc. TSG/YTPS/WTPACKAGE, Sr. No. 2 sheet 30 of 38		For deciding PLC configuration please confirm the no. of control room for WT machine. It has to be decided at bidding stage because this will have huge price implication. Also, there is no provision of optional price in the price bid for considering different PLC configuration.	Bidder to refer sl no 2 of additional notes page 30 of 38 of electrical scope for wagon tippler control room. Please note that as per specification design of control room is under bidders scope only . Bidder to note that Each Wagon Tippler machine shall be provided with its own PLC , control desk, engg and operator work stations, networking elements/links, UPS, printer, servers, etc. as clearly mentioned in specifications irrespective of no of control rooms.

8			We presume that SLDB and any type of transformer (HT, LT, Lighting and auxiliary) is excluded from bidder's scope.	transformers required for Bidders equipment such as power distribution board for conversion from three phase to single phase is in bidders scope. aslo PDB is in bidders scope. kindly adhere to the specification. HT/LT transformers for 3.3kV switchbard and LT MCC is in BHEL's scope.
9	Doc. TSG/YTPS/WTPACKAGE, Sr. No. 40 sheet 17 of 38	Arranging the empty wagon..... bidder.	This clause has to be excluded from bidder's scope as done in WT package of kothagudem and bhadradri.	Bidder to refer addendums issued earlier.