



TD-201 Rev No. 00	Form No.	 HYDERABAD	PRODUCT STANDARD PROJECT ENGINEERING & SYSTEMS DIVISION HYDERABAD		Amendment -1 to PY56182																							
				Rev No. 00																								
				Page 1 of 2																								
<p><u>AMENDMENT -1 TO TECHNICAL SPECIFICATION FOR FIRE DETECTION & ALARM SYSTEM (SPEC NO PY 56182 Rev 00)</u></p> <p>1. ANNEXURE-C OF PY56182 i.e. BOM for FDA items shall be read as:</p> <table border="1" data-bbox="298 506 1414 827"> <thead> <tr> <th>Ref S.No</th> <th>Description</th> <th>Quantity</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>9</td> <td>Optical LHS cable</td> <td>0 Mts</td> <td>Earlier requirement of 30000 mts is withdrawn & hence no LHS cable is to be considered in the offer.</td> </tr> <tr> <td>11</td> <td>Optical LHS controller</td> <td>0 Nos.</td> <td>Earlier requirement of 2 Nos are withdrawn & hence no LHS controllers are to be considered in the offer.</td> </tr> </tbody> </table> <p>2. ANNEXURE-D OF PY56182i.e. Mandatory spare list items shall be read as:</p> <table border="1" data-bbox="298 989 1414 1386"> <thead> <tr> <th>Ref S.No</th> <th>Description</th> <th>Quantity</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>3</td> <td>Optical LHS cable</td> <td>0 Mts</td> <td>Earlier requirement of 3000 mts is withdrawn & hence no LHS cable as mandatory spare is to be considered in the offer.</td> </tr> <tr> <td>8</td> <td>Field mounted Optical/Electronic Items/Accessories for Linear Heat Sensing Cable</td> <td>0 %.</td> <td>Earlier requirement of 10% of each type is withdrawn & hence no mandatory spares for LHS are to be considered in the offer.</td> </tr> </tbody> </table>					Ref S.No	Description	Quantity	Remarks	9	Optical LHS cable	0 Mts	Earlier requirement of 30000 mts is withdrawn & hence no LHS cable is to be considered in the offer.	11	Optical LHS controller	0 Nos.	Earlier requirement of 2 Nos are withdrawn & hence no LHS controllers are to be considered in the offer.	Ref S.No	Description	Quantity	Remarks	3	Optical LHS cable	0 Mts	Earlier requirement of 3000 mts is withdrawn & hence no LHS cable as mandatory spare is to be considered in the offer.	8	Field mounted Optical/Electronic Items/Accessories for Linear Heat Sensing Cable	0 %.	Earlier requirement of 10% of each type is withdrawn & hence no mandatory spares for LHS are to be considered in the offer.
Ref S.No	Description	Quantity	Remarks																									
9	Optical LHS cable	0 Mts	Earlier requirement of 30000 mts is withdrawn & hence no LHS cable is to be considered in the offer.																									
11	Optical LHS controller	0 Nos.	Earlier requirement of 2 Nos are withdrawn & hence no LHS controllers are to be considered in the offer.																									
Ref S.No	Description	Quantity	Remarks																									
3	Optical LHS cable	0 Mts	Earlier requirement of 3000 mts is withdrawn & hence no LHS cable as mandatory spare is to be considered in the offer.																									
8	Field mounted Optical/Electronic Items/Accessories for Linear Heat Sensing Cable	0 %.	Earlier requirement of 10% of each type is withdrawn & hence no mandatory spares for LHS are to be considered in the offer.																									
Ref. Doc	Revisions : Refer to record of revisions :	Prepared : KV	Checked : BNK	Approved : PCS	Date : 11.07.16																							

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED, It must not be used directly or indirectly in any way detrimental to the interest of the company.

 HYDERABAD	PRODUCT STANDARD PROJECT ENGINEERING & SYSTEMS DIVISION HYDERABAD		Amendment -1 to PY56182		
			Rev No. 00		
			Page 2 of 2		
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED . It must not be used directly or indirectly in any way detrimental to the interest of the company.	RECORD OF AMMENDMENTS				
	AMEN DMEN T NO.	Date	Revision Details	Revised	Approved
	00	20.04.16	Original Issue	-	PCS
	01	11.07.16	Generally Revised	BNK	PCS
	Ref. Doc				