

DATE - 18-01-2016

Sr no	BHEL Amendment -2 , Additional scope.
1	Toilet ventilation for PCH-1, PCH-21, SCH-1, SCH-21 and inmotion weigh bridge -1 , 2 shall be added extra from the DBR. Total 6 nos of exhaust fans of each 1000 m3/h shall be included for CHP rooms.
2	Hydraulic power pack room shall be provided with 8 nos of exhaust fan of each 1000 m3/h .
3	Each fan capacity for AHP MCC 1 (compressor house) may be considered as 58000 m3/hr instead of 32000 m3/hr , quantity is same as 02 nos.
4	Each fan capacity for AHP MCC 2 (silo area) may be considered as 29000 m3/hr instead of 19000 m3/hr; quantity is same as 02 nos.