

Bharat Heavy Electricals Limited

(A Govt. Of India Undertaking)

Project Engineering
Management



Ref. No. PE/PG/OP1/E-4616/2014-01
Enquiry No.: PE/PG/OP1/E-4616/14
Date: 13/11/2014

2X660 MW IB, BANHARPALLI UNITS 3 & 4
HEAT EXCHANGERS (PLATE TYPE)

CORRIGENDA/ADDENDA-1

Dear Sirs,

Please find enclosed Amendment -1 to Technical Specification for subject enquiry. Bidders are requested to quote accordingly.

Thanking you,
Yours faithfully,
For and on behalf of BHEL

ROHIT JUNEJA
(ENGINEER/Project Group-II-1)

#

ROHIT JUNEJA
ENGINEER/PG-II-1,
BHEL/PS-PEM
POWER PROJECT ENGINEERING INSTITUTE,
PLOT NO. 25, SECTOR - 16A, NOIDA (UP)
(OFF) 0120-4368848.

Regd. Office:
BHEL House
Siri Fort
New Delhi-110049

AMENDMENT-1 dated 13.11.2014

Volume	Section	Clause				Present		Amendment	
						TG Aux.'s	SG Aux.'s	TG Aux.'s	SG Aux.'s
IIB	C1 (Data sheet-A)	3.2	Inlet temperature	(DMCW Side)	°C	42.54	44.1	44.54	46.1
				(ACW Side)	°C	36	36	36	36
IIB	C1 (Data sheet-A)	3.3	Outlet temp	(DMCW Side)	°C	38	38	38	38
				(ACW Side)	°C	44.54	46.1	42.54	44.1