

**Annexure – C to tender BAP/CAP/2013-14/OT-15**

**AIRCONDITIONING OF ADMIN CANTEEN**

<b>S.No</b>	<b>Description</b>	<b>Quantity</b>	<b>Vendor's confirmation</b>	<b>Rate</b>	<b>Amount</b>
1	Supply, installation, testing and commissioning of high wall mounted 2.0 TR capacity (3 star & above) Split air-conditioner units at Admin canteen of BHEL Ranipet. The Split AC shall consist of cordless remote controller, indoor unit (IDU) and outdoor unit (ODU) with Rotary/Scroll /Inverter compressor having R-22/R410a/non-CFC based refrigerant gas, refrigerant grade copper piping (suction & discharge, standard length- 4 mtrs) with insulation as per manufacturer's recommendation and suitable interconnecting communication cabling (standard length- 4 mtrs) between Indoor & Outdoor units.  Make: Voltas, Bluestar, Carrier, Hitachi, O'General, Daikin, Panasonic, LG, Samsung, Onida, Videocon.	20 Nos		To be indicated only in price bid	To be indicated only in price bid

Note: Only the lowest offer will be considered while finalizing the tender