

ANNEXURE TO CORRIGENDUM –II

Ref Enq: NKR0000033 dt. 31.08.15

1. Due date of tender submission is extended upto 13.00Hrs on 12.10.15 and tender will be opened at 13.30Hrs. on 12.10.15.
2. Clarification for clause 8 of Special commercial condition- BHEL Duty free import license cannot be parted with vendors for import of Raw materials by vendors. Hence vendors have to import raw materials with applicable custom duty. Hence Clause 8 of Special commercial condition is not applicable for the tender.
3. PAC, Mega power project certificate and PAC amendment with PO details will be provided for availing Duty/Tax exemption.
4. One set of Foundation Field Bus System is required for each unit of Gadawara project. Hence total two sets are required for Gadawara project. Signals listed in annexure-2 of Specification PS4102025 are applicable for one unit only and same should be considered for second unit also.
5. Annexure 2 of PS/409/1582 (Unchahar Project) mentioned as East Package is same as TG package.
6. Customer has approved some vendors for this project and item. After receipt of offers from vendor, who are not approved by customer, efforts will be made by BHEL with customer for approval of additional vendors who have submitted offer. Even after BHEL efforts, if customer does not approve additional vendor, then offers of those vendors who are not approved by customer, will not be evaluated and price offers in sealed condition will be returned back as per our policies and guidelines.