

BHEL reply to Pre bid clarifications

S.N	Volume / Sec. No.	Page No.	Clause No.	TECHNICAL SPECIFICATION / TENDER DOCUMENT	COMPLETE DESCRIPTION OF Clarifications	BHEL REPLY
1	Volume - IIB, SECTION C1-A (SPECIFIC TECHNICAL REQUIREMENT)	18	3.1.8	EOT Crane of 8T capacity	Cranes / Hoist are part of Exclusions as per clause no. 3.5 of Volume - II B Section - C1 A. Please clarify	EOT crane, 8T cap. is excluded from bidder's scope.
2	SECTION C2 TECHNICAL SPECIFICATION FOR COMPRESSED AIR SYSTEM (ELECTRICAL PORTION)	142	12	ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR (FOR EPC PROJECTS) Motors with base plate and foundation hardware Scope of Supply and E&C is in Vendor Scope	As per clause no. 1.1.14 of Volume - II B Section - C1 A, Page no. 11 - All HT motors which are not in bidder's scope of supply, bare motors only shall be supplied as free issue by BHEL to successful bidder based on motor inputs furnished by bidder, like motor rating and TS (Torque - Speed) curve. Please clarify the scope of Supply of Motor	All HT motors are excluded from bidder's scope.
3		170	14	415V, 3 ϕ AC supply shall be provided by BHEL at a single point, further distribution to various instruments / equipments of the CAS shall be in Bidder's scope. Bidder to include the necessary power distribution board in his scope. Any power supply other than the above, if required for any instrument / equipment has to be derived from the above supply & all the necessary hardware for the same shall be in Bidder's scope	ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR (FOR EPC PROJECTS), S. No. 1, any 6.6 KV / 415 V Switchgear scope of supply with E&C are in BHEL scope Please clarify Power Distribution Board scope	Specification is clear. 415V, 3 phase supply shall be provided by BHEL at a point, further distribution to various instruments / equipments of the CAS shall be in Bidder's scope. Bidder to include the necessary power distribution board in his scope
4	Addendum -1		S. no. 8	4 nos. microprocessor controller shall be supplied as loose	please clarify if its required as spares	Bidder's query cannot be entertained, as scope is clearly defined.
5	Addendum -1		S. no. 10	5 sets of instruments located within compressor skid for protection purpose shall be provided as loose	please clarify which instruments are required for protection purpose	Bidder's query cannot be entertained, as scope is clearly defined.
6	Addendum -1		S. no. 12	Flow Transmitter in cooling water return line of each compressor	please clarify which type of Flow transmitter	Bidder to supply flow transmitter to suit application. Specific type will be decided during detailed engineering.
7	Price format			type of Dryer unit	please clarify the tupe of air dryer required	'Refrigerant type' mentioned in price format is on account of typographical mirror. Bidder's to refer to cl. No.1.1.12 (page 10 of 324) and P&ID released with addendum and offer HOC Twin Tower or Rotary Drum type Dryer.