

### Pre bid clarifications

Sr No	Volume / Sec. No.	Page No.	Clause No.	TECHNICAL SPECIFICATION / TENDER DOCUMENT	COMPLETE DESCRIPTION OF Clarifications
1	Volume - IIB, SECTION C1-A (SPECIFIC	18	3.1.8	EOT Crane of 8T capacity	Cranes / Hoist are part of Exclusions as per clause no. 3.5 of Volume - II B Section - C1 A. Please clarify
5	SECTION C2 TECHNICAL SPECIFICATION FOR COMPRESSED AIR SYSTEM (ELECTRICAL PORTION)	142	12	<b>ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR (FOR EPC PROJECTS)</b> Motors with base plate and foundation hardware Scope of Supply and E&C is in Vendor Scope	As per clause no. 1.1.14 of Volume - II B Section - C1 A, Page no. 11 - All HT motors which are not in bidder's scope of supply, bare motors only shall be supplied as free issue by BHEL to successful bidder based on motor inputs furnished by bidder, like motor rating and TS (Torque - Speed) curve. <b>Please clarify the scope of Supply of Motor</b>
8		170	14	415V, 3 $\phi$ AC supply shall be provided by BHEL at a single point, further distribution to various instruments / equipments of the CAS shall be in Bidder's scope. Bidder to include the necessary power distribution board in his scope. Any power supply other than the above, if required for any instrument / equipment has to be derived from the above supply & all the necessary hardware for the same shall be in Bidder's scope	ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR (FOR EPC PROJECTS), S. No. 1, any 6.6 KV / 415 V Switchgear scope of supply with E&C are in BHEL scope <b>Please clarify Power Distribution Board scope</b>