

SUMEET SAHAY - PG-I-2

From: SUMEET SAHAY - PG-I-2
Sent: 30 March 2016 18:50
Cc: HEMANT KUMAR KAUSHIK - PG-I-2; SANJAY KUMAR DUBEY - PG-I-2; D SAHA - DH(PG-I-2); JC SHARMA - GM(PG-I)
Subject: FW: OUR TENDER ENQUIRY NO PE/PG/YE1/E-5147/2015, DTD-31.12.2015 FOR COOLING TOWER (IDCT) AS PER TECHNICAL SPECIFICATION NO. PE-TS-409-165-N001 FOR 1X370MW KPCL YALAHANKA CCPP
Attachments: CORRIGENDA-08-COOLING TOWER-YELAHANKA.pdf

Bid queries are as follows:-

Sl No	Bid Query	Clarification
1	As per NIT, Structural steel would be free issue item. Please specify if the plates required for hot water piping would also be supplied by BHEL as free issue items. Please also confirm if the pipes can be fabricated at site.	As per Cl. 2.01.01 (c), section-C, Vol-IIB (book 1 of 2), the hot water piping shall be in bidder's scope of supply. Plates required for hot water piping shall not be free issue by BHEL
2	As per section C-2, electrical scope, sl.no.12, it is indicated that aviation lighting is in bidder's scope. Kindly clarify if this is applicable as it is only for NDCT's.	Not applicable for IDCT.
3	As per vol IIB, section C1, datasheet – A, sl.no.8.2 specifies that the buried piping has to be wound with anti-corrosive tape and RCC encasement of 250 mm thickness. In our opinion, both the protection is not required. Kindly clarify which is to be followed.	Bid specification stands

Thanks & Regards

SUMEET SAHAY, SR ENGINEER, PG-I-2, PS-PEM, BHEL, PPEI BUILDING, PLOT NO-25, SECTOR-16A, NOIDA-201301 (UP), sumeetsahay@bhhelpem.co.in, EXTN-3532, PH-0120-4213532, FAX-0120-4329045, MOB--91 9999498202



From: SUMEET SAHAY - PG-I-2
Sent: 29 March 2016 19:16
Cc: HEMANT KUMAR KAUSHIK - PG-I-2; SANJAY KUMAR DUBEY - PG-I-2; D SAHA - DH(PG-I-2); JC SHARMA - GM(PG-I)
Subject: RE: OUR TENDER ENQUIRY NO PE/PG/YE1/E-5147/2015, DTD-31.12.2015 FOR COOLING TOWER (IDCT) AS PER TECHNICAL SPECIFICATION NO. PE-TS-409-165-N001 FOR 1X370MW KPCL YALAHANKA CCPP

Dear Sir

Please find Corrigenda 08 for the subject NIT. Please note that Due Date of opening of Part I bid is extended from 30.03.2016, 10.00AM to 12.04.2016, 10.00AM.

All future amendment/ corrigenda and due date extension, if any, for this tender shall be hosted only on above website.

Thanks & Regards

SUMEET SAHAY, SR ENGINEER, PG-1-2, PS-PEM, BHEL, PPEI BUILDING, PLOT NO-25, SECTOR-16A, NOIDA-201301 (UP), sumeetsahay@bhelpem.co.in, EXTN-3532, PH-0120-4213532, FAX-0120-4329045, MOB--91 9999498202

