

SUPPLY OF 1*630 KVA DG SET FOR KOSTI TPS SUDAN

BHEL-ISG ENQUIRY NO: 77/15/6105/ANA DATED 19.08.2015

Clarification Date : 15.09.2015

SI NO.	Bidder's queries	BHEL-ISG REPLY
1	Tender specification demands for MTU 12V2000G23 3A power (continuous application), please advise if we can quote with MTU 12V2000G25(3B power) and Stamford HCI 544F which is the upgraded version.	Minor type variation is acceptable, provided power output is same and the DG shall fit into the existing acoustic enclosure.