

Sl. No.	Clause No	Bidder's Query	BHEL Reply
Technical			
1	G(b) Data sheets of equipment (page no. 39 of 40 TSG/YTPS/S/R)	We understand that there is no blank Technical Datasheet to be filled & submitted with Tender Documents.	Bidder shall prepare the datasheet and submit along with the offer AND ENSURE THAT TECHNICAL DETAILS ARE IN LINE WITH NIT SPEC.
2	E (36) Drawings of all the equipment shall be furnished in editable AutoCAD format (page no. 22 of 40 TSG/YTPS/S/R).	Only G.A. Drawing of equipment shall be furnished in AutoCAD format during detail engineering.	AutoCAD format of all basic drawing like GA drawing of equipment, Stockyard layout etc. shall be furnished by bidder during detail engineering.
3	B (1) Remarks for Stacker: 2000 MTPH (rated) 2200 MTPH (design) Boom length- 41 m Hydraulic drive for luffing, slewing and bucket wheel (page no. 4 of 40 TSG/YTPS/S/R).	We understand that Bucket wheel Drive shall not applicable for Stacker machine.	Agreed. Bucket wheel Drive shall not be applicable for Stacker machine.
4	EQUIPMENT DESIGN DATA - C. DESIGN PARAMETERS FOR STACKER MACHINES: Slewing mechanism of boom: Shall consist of horizontal ring bearing with geared rim. Slewing shall also be done by hydraulic drive. Drive for bucket wheel and slewing of Stacker shall be through hydraulic motor without gearbox & coupling and directly coupled to driven shaft (page no. 12 of 40 TSG/YTPS/S/R).	We understand that Bucket wheel Drive shall not applicable for Stacker machine.	Agreed. Bucket wheel Drive shall not be applicable for Stacker machine.
5	TECHNICAL PARAMETERS - C. DESIGN PARAMETERS FOR STACKER MACHINES: Stock pile length: As per stockpile calculation enclosed (page no. 10 of 40 TSG/YTPS/S/R).	We could not found Stockpile calculation, please provide the same.	As enclosed .Stockpile length shall be 442 m. However it shall be finalized during detailed engineering.
6	EQUIPMENT DESIGN DATA - Operator's cabin: Shall be provided with all standard accessories including fan, light etc. as per manufacturer's recommendation. Operator's cabin shall be located near bucket wheel (approx. 10m from wheel for ease of operation) (page no. 12 of 40 TSG/YTPS/S/R).	Please clarify the location of Operator's cabin for Stacker Machine.	It shall be placed near the discharge end (non drive end) of the boom conveyor for stacker machine.

7	NOTE No 11 - Successful Bidder shall procure and ensure that belt weigher for Boom conveyor is of same make & type as other belt weighers procured for main conveyors system (which will be executed by BHEL's other contractor). Necessary information will be provided by BHEL during detail engg. so, bidder to consider accordingly (page no. 16 of 40 TSG/YTPS/S/R).	Please provide list of Approved vendor's for Belt weigher.	Kindly find the attached approved vendor list in addition to the list attached along with the enquiry.
8	Annexure – 2 Kothagudem TPS CHP - Mechanical Vendor List	Provided vendor list is incomplete. i.e. As per vendor list, All vendor of Gearbox are not approved. Kindly provide complete vendor list for all major mechanical items.	Kindly find the attached approved vendor list in addition to the list attached along with the enquiry.
9		Kindly let us know height of the brick cladding for the construction of storage shade	The closed shed shall be prepared considering following: 1. RCC column shall be provided with max. span 6 metres 2. RCC beams at every 3m height from finished floor level 3. In between brick infill upto total height of shed Windows and access door in addition to rolling shutter shall also be suitably provided.
Commercial Terms and Conditions			
10		Warranty - As per SCC warranty is 12 months from the date of successful completion of trial operation of the system. For better clarity we kindly request you to provide cut out dates for trial operation of stacker and reclaimers as incoming belt conveyor system is not in our scope. We understand successful completion of trial operation of stacker and reclaimers means it may be no-load running trial at site.	The word "Warranty" mentioned in clause 15 of SCC shall be read as "Guarantee Period". Bidders to quote as per tender requirement. Please refer document (Commissioning and Trial Operation, Rev-01) uploaded in the website as addendum for the meaning of trial run .

11	Note No 10 of PRICE FORMAT Stacker and Reclaimer Package Indigenous Supplier - ** Bidder to indicate item wise unit price (no flower brackets and common price allowed) for each mandatory spares in their price offer failing which bidder's offer will not be considered for evaluation.	There is no Item wise Price format for Mandatory spare.	Price of Mandatory spare shall be furnished in the annexure A1, A2 & A3 against each of Mandatory spares, and sum total of this amount to be indicated in the main price format. However, bidder to note that sheets of annexure A1, A2 & A3 with price of individual items shall necessarily be enclosed in the sealed bid along with main price format.
12	14 of SCC - In case of Turnkey packages (refer clause 9.3.3 & 9.4.3) , if the PG test is not conducted up to 24 months from the date of last dispatch for reasons not attributable to vendor, the last 10% payment will be released against Bank Guarantee of an equivalent amount, valid initially for 12 months and extendable till completion of PG test. This BG will be in addition to contract Performance Bank Guarantee for 10% of the contract value (Ex-Works / F.O.B.). (page no. 3 of 13).	There is no time frame till which additional BG should be extended. There should be a time limit for extending this additional BG as PG test is in not in our control.	Bidders to quote as per tender requirement. The validity of additional Bank Guarantee is required to be extended upto completion of PG test of Stacker & Reclaimer machines which is in the scope of the vendor.
13	15 of SCC - Warranty (page no. 3 of 13).	As trial operation of system or commercial operation is not solely in our control, the warranty should be linked with dispatches.	Bidders to quote as per tender requirement. Refer above sl. No. 10 for Guarantee period.
14	17 of SCC - Submission of PBG (page no. 4 of 13).	PBG validity is linked with warranty period. As warranty time is open ended, the PBG will result in extending the BG. Thus, a time frame for extending the BG should be there.	Bidders to quote as per tender requirement. Refer above sl. No. 10 for Guarantee period.
15	38.8 of GCC - Round-the-clock security for the temporary stores, at temporary storage place & for the erected equipments till handing over to customer (by a reputed agency) is in the scope of the bidder. (page no. 26 of 28).	There is no time frame for handing over to customer, so this clause of security should be linked with commissioning of machines.	Bidders to quote as per tender requirement. Please refer document (Commissioning and Trial Operation, Rev-01) uploaded in the website as addendum for the meaning of trial run .