

Enquiry No. : 77/15/6201/RCD

Crusher Package for 5X800 MW Yadadri TPS

Sl. No.	Bidder's Query	BHEL Reply
Technical		
1	As per clause no. 9D and 13D of doc. no. TSY/YTPS/CRUSHERS, it is asking for VVVF panels. It is not clear VVVF drive is required or not. Please clarify.	VVVF not applicable for Crusher's package.
2	As per clause no.14D of doc. no. TSY/YTPS/CRUSHERS, is asking for Colored Mimic and Hard wired annunciation. As PLC / MCC is in BHEL's scope so it not clear where colored mimic and hard wired annunciation is required. We have not considered the same in our scope. Please confirm.	Noted. Coloured mimic not required for Crusher package. However, annunciation shall be provided in scoop coupling panel as per requirement (which shall be decided during detailed engg.)
	As per clause no.12D, of doc. no. TSY/YTPS/CRUSHERS,is asking for Air conditioning. The design of Crusher are for dusty atmosphere i.e. for crusher/ screen building etc. We reconfirm our Crusher does not require any air conditioned atmosphere. The drives (excluding motor in BHEL's scope) are mounted with crusher and are dust proof type. The panels if required for crushers are in central place i.e MCC room. The MCC rooms are beyond the scope of bidder. AC required for MCC rooms are excluded from bidder scope of supply. So, any air conditioning is excluded. Please confirm.	Noted. AC is not required for Crusher package.
	As per clause no.12D, sr. no. 1 &2 of Miscellaneous of doc. no. TSY/YTPS/CRUSHERS, it is asking for Erection work of Field instruments, safety switches, solenoid valves, tools and tackles, mandatory spares etc. in vendors's scope. As per NIT the enquiry calls for supervision services. So, erection work has to be excluded from vendor's scope. Please confirm. Also, it is not clear how erection, testing and commissioning of tools and tackles, mandatory spares to be done. please clarify.	Erectioning and commissioning of field devices, safety switches and solenoid valves shall be excluded from Bidder's scope. E&C not applicable for tools and tackles, mandatory spare.
3		E&C of all electrical items shall be excluded from bidder's scope.
Commercial Terms and Conditions		
4	<p>Warranty - As per SCC warranty is 12 months from the date of successful completion of trial operation of the system. For better clarity we kindly request you to provide cut out dates for trial operation of screen as incoming belt conveyor system is not in our scope.</p> <p>We understand successful completion of trial operation of the screen means it may be no-load running trail at site.</p>	<p>The word "Warranty" mentioned in clause 15 of SCC shall be read as "Guarantee Period".</p> <p>Bidders to quote as per tender requirement. Please refer document put in the website as addendum for the meaning of trial run .</p>