

ODISHA POWER GENERATION COMPANY LIMITED
2 X 660 MW IB TPP BANHARPALLI UNITS 3&4
LT XLPE FIRE SURVIVAL CABLES
TECHNICAL SPECIFICATION NO. - PE-TS-391-507-E005 R0

S. No.	Reference Section	Clause No. of	Specific Requirement/ Change
1	Annexure to QP	4.0 (e), (f), (g), (h)	Reference Standard: Shall be read as- BS-7655-1.3:2000
		4.0 (c) & 6.0 Spark Test	"Classification of Test" : Shall be conducted as Process Test- Internal in process test report to be furnished for verification during inspection.
		4.0 (k)	Reference Standard: Shall be read as- BS-7655-0:2006/ BS-6469-99.2:1992
		10.0	"Classification of Test" : Test Conduction required as: T, A