

Ref No. : PE/PG/YE1/E-5323/2016/CORRIGENDA/02

Date: 01.09.2016

CORRIGENDA / ADDENDUM-02

**SUBJECT: 1 X 370 MW KPCL YELAHANKA CCPP
TENDER ENQUIRY FOR DC BATTERY
OUR REF: TENDER ENQUIRY NO: PE/PG/YE1/E-5323/2016, DATED- 12.08.2016**

DUE DATE
16.09.2016
BY 14.00PM

1. The tabular form of Battery Load duty cycle is as below

DUTY CYCLE TIME (MIN)	LOAD CURRENT ON BATTERY (A)
0-1	159
1-2	326
2-15	197
15-16	712
16-119	431
119-120	442


2. The last date of submission of offer against tender for DC Battery invited vide Enquiry No PE/PG/YE1/E-5323/2016, Dtd-12.08.2016 is extended up to 16.09.2016, 14.00PM. All bidders are requested to visit the website www.bhel.com (Tender Notifications Section) OR www.bhelpem.com. All future corrigenda/ amendment and due date extension, if any, for this tender shall be hosted only on above websites.

All future amendment and due date extension, if any, for this tender shall be hosted only on above website.

Thanking You,

With Regards,

For & on behalf of BHEL


Sumeet Sahay
Sr Engineer/PG-I-2

सुमीत सहाय / SUMEET SAHAY
वरिष्ठ अभियन्ता (पी.जी.-I-2)/Sr. Engineer (PG-I-2)
भारत हेवी इलेक्ट्रिकल्स लिमिटेड/Bharat Heavy Electricals Ltd.
पावर सेक्टर-परियोजना इंजीनियरिंग प्रबंधन
Power Sector-Project Engineering Management
प्लॉट नं.-25, सेक्टर-16ए, नोएडा-201 301
Plot No. 25, Sector-16A, Noida-201 301

Please reply to:

**Sh Sumeet Sahay, Sr. Engineer
PG-I-2**

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No.0120-4213532, 09999498202