



OPEN TENDER FOR HT XLPE POWER CABLES OF 2X660 MW ENNORE SEZ STPP

Ref No. : PE/PG/EN1/E-4839/2015/02

Date: 17.06.2015

CORRIGENDUM/ ADDENDUM-2

Subject: Corrigenda to Technical specification no. PE-TS-412-507-E001


Ref: Our Tender Enquiry No. E-4839/2015 dated 27.05.2015 for HT XLPE POWER CABLES for 2X660MW ENNORE SEZ STPP

This is in reference to the subject Tender Enquiry please note following:

1. *Corrigenda to Technical specification no. PE-TS-412-507-E001*
2. *Revised Price Schedule Format*

Thanking You,

With Regards,
For & on behalf of BHEL


Rajeev Kumar
Engineer/PG-II-2

Enclosure:-

1. *Corrigenda to Technical specification no. PE-TS-412-507-E001*
2. *Revised Price Schedule Format*

Please reply to:
Rajeev Kumar (Engr/PG-II-2)
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)
Tel No. 0120-4213582

2X660 MW ENNORE TPS
CORRIGENDA TO TECHNICAL SPECIFICATION FOR HT XLPE POWER CABLES

PE-TS-412-507-E001

Sr. No.	Ref. Section	Clause No.	Specific requirement/ Change
1.0	DATA SHEET -A	7.0 (a) (ii)	Insulation screen minimum thickness shall be 0.3 mm
2.0	DATA SHEET -A	13.0 (e)	Apart from printing requirement as indicated in Technical Specification, ISI mark shall also be printed on cable @1m.
3.0	BOQ CUM PRICE SCHEDULE	1.1	LOT 1 QTY OF 1C-300 CABLE SHALL BE 70 drums of 700 Metre & 3 drums of 500 M.