



**TENDER ENQUIRY FOR LT PVC CONTROL CABLE FOR 2X660MW SURATGRAH STPS ,
STAGE-V**

Date: 05.06.2014

CORRIGENDA-1

Tender Enquiry no.: PE/PG/SG5/E-4420/14 Dated 19.05.14


DUE DATE
11-JUNE-2014
10.00 AM

- 1) Kindly note that order quantity for item no. 2 (i.e. 5C X 2.5 Sq mm) of **BOQ cum price schedule-Annexure A** of subject tender enquiry should be read as 25000 mtrs instead of 35000 mtrs. There has been typographical error in BOQ - Annexure A so BOQ with corrected quantity of item no. 2 has been enclosed herewith.
- 2) The integrity pact, shall be returned by the bidder, along with their Techno-Commercial Bid, duly filled and signed by the authorized signatory who signs the bid and will form part of the order. Only those vendors who have entered into such an integrity pact with BHEL would be competent to participate in the bidding. In other words, entering into this Integrity Pact would be a preliminary qualification.

Details of Independent External Monitor (IEM): -"Being appointed will be advised separately".

All other terms & conditions of subject tender remain unchanged.

This is for your information & necessary action.

With Regards,
For & on behalf of BHEL

(ISHA RAWAT)
Sr.Engr/PG-II-1
BHEL-PEM

Please reply to:

Isha Rawat, Sr Engineer
PG-II-1

Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM,Noida-201301 (U.P.)

Tel No. 0120-4213577/4368774, Fax: 0120-4329106

ANNEXURE-A : BOQ CUM PRICE FORMAT
Tender enquiry No. PE/PG/SG5/P-4420/14 Dated 19.05.14

LT PVC CONTROL CABLE FOR 2 X 660 MW SURATGARH STPS STAGE-V

(A) MAIN ITEM

1.1 kV Copper conductor Armoured cables

1.1 kV control cables with stranded plain annealed copper conductor, PVC Type-A insulation, core identification by colour coding (upto five cores)/ number marking (more than five cores), distinct extruded inner sheath of PVC type ST1 material, GS round/formed wire armour as per IS:3975 and extruded PVC Type ST1 outer sheath with FRLS properties, generally conforming to IS:1554 (Part-1) and BHEL specification.

S.NO.	Cable Size (No. of cores x Cross section Area (sq.mm))	Order Quantity (Mtrs)	Lot-1 (Mtrs)	Drum Length (Mtrs)	UNIT EX WORKS	TOTAL EX-WORKS	ED@.....% INCLUDING CESS	CST@% AGAINST FORM-C/E1 or VAT@.....% whichever is applicable	FREIGHT @% OF EX_WORKS INCLUDING SERVICE TAX	TOTAL FOR PRICE
1	5C X 1.5	32000	23000	1000			Nil against PAC			
2	5C X 2.5	25000	18000	1000			Nil against PAC			
3	7C X 1.5	124000	87000	1000			Nil against PAC			
4	10C X 1.5	52000	36000	1000			Nil against PAC			
5	12C X 1.5	25000	18000	1000			Nil against PAC			
6	12C X 2.5	10000	7000	1000			Nil against PAC			
7	5C X 4	7000	5000	1000			Nil against PAC			
TOTAL:										

NOTES:

- Ordered quantities, which are indicated above, shall be known as order quantities. The variation in quantities for main item shall be limited from -30% to +30% of the total contract value derived on the basis of order quantities.
- The bidder shall indicate the unit price of each type and size of cables listed as per the BOQ cum price schedule . The unit price shall apply for adjustment of variation in quantity as stipulated above.
- Lot-1 quantity indicated above shall be cleared for manufacturing along with LOI. However, manufacturing of the cables shall be taken up by the successful bidder only after approval of technical and quality documentation. Subsequent lots if required shall be cleared for manufacturing based on progress of engineering and site requirements.
- Overall tolerance on total dispatched quantity of each size for main item shall be (-) 2% and (+) 0% . Cables consumed for testing and inspection shall be to bidder's account.
- The drum length shall be 1000 m (+/- 5%) (as specified in the BOQ). For each individual cable size, one short length of not less than 200m may be accepted only in the final drum length to complete the supply. The overall tolerance limits stipulated above shall continue to apply (in case short lengths are accepted).
- In case of the quantities of any one lot cleared by BHEL for manufacturing are manufactured and offered for inspection by successful bidder in more than one batch, BHEL reserves the right to witness type testing on all batches without any price implications.
- Bidder shall indicate unit price of cables inclusive of type test charges and UV radiation test. No separate type test and UV radiation test charges are to be quoted by bidder.
- The charges of Hydrolytic Stability test, if asked to perform shall be reimbursed extra at actual against original money receipt of Govt. Lab. (CPRI/ERDA).

Bidder's signature, date, designation & company seal