



**CORRIGENDUM 01**

Ref: E-6354/2019 /01

Date:27/01/2020

**Corrigendum to OPEN Tender Enquiry of FRP CABLE TRAYS & ACCESSORIES” FOR  
2X800MW TANGEDCO UPPUR BTG**

Ref No: - PE/PG/UPP/E-6354/2019 Dated: 17.01.2020

1. **Due date Extension:** Bidder to note that bid submission of subject tender enquiry has been extended upto 03.2.2020,14:00 hrs. Part 1 opening will be done on same day at 15:00 hrs.
2. **Technical clarification:** Cable tray cover details shall be as per datasheet- A & typical details FRP type cable trays and accessories attached as part of technical specification. As per datasheet- A & typical details FRP type cable trays and accessories, thickness of cable tray cover shall be 3mm. Bidder to read thickness of FRP cable tray cover (507-25060-A, 507-25061-A 507-25062-A) as 3mm instead of 1.7 mm.
3. Existing supplier\* (M/s GENERAL COMPOSITES PVT. LTD, Mumbai), is not eligible to quote in this tender enquiry.

\*Existing Supplier will include:

- i). In case existing supplier is The Sole Proprietorship Firm, any Sole Proprietorship Firm owned by same Sole Proprietor.
- ii). In case existing supplier is The Partnership Firm, any firm comprising of same partners/ some of the same partners (but not including any new partner); or sole proprietorship firm owned by any partner(s) as a sole proprietor.

With regards  
For & on behalf of BHEL

(AKASH VERMA)  
Sr Engineer/ PG-I  
PEM, BHEL, Noida