

परियोजना
इंजीनियरिंग
प्रबंधन
Project Engineering
Management

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
(भारत सरकार का उपक्रम)
Bharat Heavy Electricals Limited
(A Govt. of India Undertaking)



Ref: PE/PG/KG1/E-4836/2015/Corrigendum/01

Date: 12/JUN/2015

DUE DATE
07-JULY-2015
BY 03.30 PM (IST)

Subject: Extension of due date of submission, Reply for Pre bid clarifications & amendment in NIT conditions for tender of GENERATOR CIRCUIT BREAKER of 1X800 MW KOTHAGUDEM TPS.

Our Ref: TENDER ENQUIRY NO: **PE/PG/KG1/E-4836/2015** dated **13.05.2015** OF **GENERATOR CIRCUIT BREAKER of 1X800 MW KOTHAGUDEM TPS** project.

1. With reference to the above enquiry, the due date of submission of tender is extended from existing date **12/06/2015, 10:00 AM (IST) to 07/07/2015, 03:30 PM (IST)**. Part-I bids shall be opened on **07/07/2015, 04:30 PM (IST)**.
2. Bidders to refer Pre-bid clarifications-01 (attached herewith).
3. Sl. No. 11 of NIT conditions, mentioned in Enquiry Letter to be replaced as:

'Online Registration Portal is operational in BHEL. Non-registered Vendors, who wish to apply for registration with BHEL-PEM, have to apply through Online Registration Portal available at www.bhelpem.com → vendor section → Online Supplier Registration. All credentials and/or documents duly signed and stamped related to registration has to be uploaded on the website and submit the application for registration. One set of hard copy of the filled-up SRF downloaded from Online Registration Portal duly signed and stamped has to be submitted'.

Kindly submit your offer/revised offer (if submitted) considering above point before the due date & time.

Thanking You

With regards
For & on behalf of BHEL

Sanjeev Kumar
12/06/15

SANJEEV KUMAR

Engineer | PG II-2, BHEL PEM | Noida
E-MAIL: sanjeev_kumar@bhelpem.co.in
Ph. No. +91-120-4368741, +91 9810917516

कृपया प्रेषित करें : Please reply to : फ़ोन Phone No:
बीएचइएल, पीएस-पीइएम् BHEL, PS-PEM, 91-120 – 436 8741
पीपीइआई भवन PPEI Building,
प्लॉट नं २५, सेक्टर १६ ए Plot No.25, Sector 16A,
नोएडा - २०१ ३०१ उ प्र Noida-201301 (U.P.)
भारत INDIA

पंजीकृत कार्यालय Registered Office :
बीएचइएल हाउस BHEL House,
सीरी फोर्ट Siri Fort,
नयी दिल्ली – ११० ०४९ New Delhi-110049
भारत INDIA

Pre Bid Clarifications-01

Project: 1X800 MW KOTHAGUDEM TPS

PACKAGE: GENERATOR CIRCUIT BREAKER

REF ENQUIRY NO: PE/PG/KG1/E-4836/2015 dated 13.05.2015

Sl. No.	Bidder's query	BHEL's reply
1	<p>Technical Specification: Clause No. 4.06.06 -> Pole discrepancy feature shall not be provided as our mechanism is gang operated one. The same has been accepted by BHEL in all their Projects executed with GCB schemes. Hence request you to accept the same and confirm.</p>	<p>Noted for gang operated breakers.</p>
2	<p>Technical Specification: Clause No. 4.15.02 -> Our operation analyzer will not be able to monitor synchronization of contacts in one pole or all poles as our breaker is Gang operated. Hence we do not have this facility in our operation analyzer/ CB watch -2. Kindly Confirm.</p>	<p>Noted for gang operated breakers.</p>