



परियोजना
इंजीनियरिंग
प्रबंधन
Project Engineering
Management

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
(भारत सरकार का उपक्रम)
Bharat Heavy Electricals Limited
(A Govt. of India Undertaking)

Ref: PE/PG/KG1/E-5242/CORRIGENDUM-02

Date: 23/06/2016

Project : 1X800 MW KOTHAGUDAM TPP
Package : CONDENSATE POLISHING UNIT
Enquiry No.:-PE/PG/KG1/ E-5242/2016 dated 27.05.2016

This is in reference to the above Tender Enquiry No: **E-5242/2016,dtd-27.05.2016**,please note the followings:

1. Following document is enclosed with Corrigendum-02:

- **PREBID CLARIFICATION(TECHANICAL&COMMERCIAL)**

Bidder to submit their offer accordingly

Thanking You

With regards

For & on behalf of BHEL

AK PANDEY

DY.MGR | PG II-2, BHEL PEM | Noida

E-MAIL: apandey@bhelpem.co.in

Ph. No. +91-120-4213528, 09406903445

कृपया प्रेषित करे :	Please reply to :	फोन Phone No:
बीएचइएल, पीएस-पीइएम पीपीआई भवन	BHEL, PS-PEM, PPEI Building,	91-120 - 436 8624
प्लॉट नं २५, सेक्टर १६ ए	Plot No.25, Sector 16A,	
नोएडा - २०१ ३०१ उ प्र	Noida-201301 (U.P.)	
भारत	INDIA	

पंजीकृत कार्यालय	Registered Office :
बीएचइएल हाउस	BHEL House,
सीरी फोर्ट	Siri Fort,
नयी दिल्ली - ११० ०४९	New Delhi-110049
भारत	INDIA

Pre-Bid clarification for Condensate polishing Unit Package								
Tender: PE/PG/KOT/E-5242/2016								
Design, engineering, manufacturing, supply, erection, testing, commissioning, etc of Condensate Polishing Unit system for 1x 800 MW TSGENCO								
Project: KOTHAGUDEM TPS, STAGE VII - PALONCHA.								
S.No	Volume	Section	Clause	Page No	Specification requirement	Clarification	Reasons for clarification	BHEL Replies
1	IIB PE-TS-410-155A-A001	C1	DATASHEET - A, 3.2	76 of 592	BULK ACID AND ALKALI STORAGE TANKS (v) Useful capacity - Adequate to hold the quantity of acid /alkali required for 30 days of operation .	We understood that the capacity of the bulk tanks for 30 days of operation shall be considered only for working vessels.Kindly confirm.	Capacity of the storage tank is not clear.	Please Follow Tender Specification.
2	IIB PE-TS-410-155A-A001	D1	2..04.00, ix)	271of 592	The resin shall be suitable for the condensate temperature that may be achieved in all operating regimes of TG cycle.However , the anion resin shall be suitable for a minimum temperature of 60 Deg.C	Resin operating temperature shall be as recommended by Resin manufacturer.		Please Follow Tender Specification.
3	IIB PE-TS-410-155A-A001	D1	2.07.01, i)	272 of 592	Minimum freeboards to be are as follows: i)Condensate Polisher /Mixed bed Polisher - 100%	Since , we are offering Spherical Vessels ,Freeboard is not applicable in this case.Kindly confirm.		Noted.
4	NIT		S.NO-31		No CIF content is available.	Both the clauses are contradictory.Kindly confirm whether CIF content is available or not to avail the Concessional Customs duty benefit? Also confirm whether High sea sales can be done for imported items.		Refer SCC Rev01 clause no-18.A,wherein it is indicated that availability of CIF for the package,if any, shall be intimated in NIT".Kindly refer Sl.No 31 of NIT wherein it is clearly mentioned that NO CIF is available.
	SCC - Rev-01		S:NO-18 A		All bidders/vendors to note that this project is a non-mega power project .However, Essentiality certificate shall be issued by TSGENCO (Customer)			

(Handwritten signature)