



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT

PROJECT : 1X800 MW TSGENCO KOTHAGUDAM TPP
PACKAGE : FIRE TENDERS

DATE: - 14.09.2015

PE/PG/KG1/ E-5017/15/CORRIGENDUM/02

Reference:

ENQUIRY NO.: E-5017/15 Dtd. 19.08.2015
PE/PG/KG1/ E-5017/15/CORRIGENDUM/01

DUE DATE
01.10.2015
BY 03.30 PM (IST)

Subject: Addenda to Technical specification & due date of subject tender.

Our Ref: TENDER ENQUIRY NO: PE/PG/KG1/ E-5017/15 dated 19.08.2015 of FIRE TENDERS of 1 X 800 MW KOTHAGUDAM TPP project.

With reference to the above enquiry, the due date for submission of tender is extended to 01/10/2015, 03.30 PM (IST). Part-I bids shall be opened on the same at 04:30 PM (IST).

Please ensure submission of offer on or before the due date by 03.30 PM (IST).

Technical amendment # 1 is uploaded along with this corrigendum.

Regards

Anil Kumar Pal
Sr. Manager
PG-II-2
BHEL PEM Noida



**AMENDMENT ON TECHNICAL SPECIFICATION FOR FIRE TENDERS
1X800 MW KOTHAGUDEM TPP**

SPECIFICATION NO.: PE-TS-410-550-A001
AMENDMENT NO # 1
REV. NO. 00 DATE: 14/09/2015
Page 1 of 1

The following modifications with respect to Technical Specification for **FIRE TENDERS BHEL's** Technical specification no **PE-TS-410-550-A001** shall apply.
Bidder to note that existing clauses/details as appearing in the specification stands deleted and clauses/details as mentioned in "Modified to or Read as" column shall be applicable and compiled by the bidder.

MODIFIED CLAUSES/PAGE NUMBERS.

Sl no.	Vol. No.	Section/ Description	Clause no	Page no	Existing clause/details	Modified to or Read as
1.	IIB	Section D/ ANNEXURE - I	Item no. 41	109 of 131	Hydraulic Rescue Tools	Heavy-Duty Electro-Hydraulic Rescue Cutter (at least 150 mm Blade Opening) - 1 set
2.	IIB	Section D/ ANNEXURE - II	Item no. 53	113 of 131	Hydraulic Rescue Tools	Heavy-Duty Electro-Hydraulic Rescue Cutter (at least 150 mm Blade Opening) - 1 set

Additional Point:

1. Brief description of the Heavy-Duty Electro-Hydraulic Rescue Cutter (at least 150 mm Blade Opening):

The cutter shall be operated by an electrical cable with back up of incorporated rechargeable battery only. No separate hoses or external hydraulic power units are acceptable. Tools with outside (external) separate batteries are not accepted.

Handwritten signature/initials