



BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-18-Dec-20

CORRIGENDUM- 02

<b>PROJECT</b>	:	<b>3x40 MW RAMMAM STAGE-III HEP</b>
<b>PACKAGE</b>	:	<b>D/G EOT CRANES UP TO 100T</b>
<b>ENQUIRY NO</b>	:	E-6565/2020
<b>SUBJECT</b>	:	<b>PRE- BID CLARIFICATION</b>

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input type="checkbox"/>

In reference to the above mentioned tender enquiry please note the following.

S I · N o ·	Clau se	Page No.	Statement of the referred clause	Clarification Required by Bidder(s)	BHEL's Clarification
1	1.4.2	129 of 207	Data Sheet–A. Auxiliary Hoist Rated SWL (Tonnes) – 15 Ton.	Auxiliary hoist capacity mentioned is 15 Tonnes whereas in provided Clearance drawing and elsewhere in the specification, the capacity mentioned is 10 T.  We request you to kindly confirm the correct capacity for Aux Hoist.	The auxiliary hoist capacity shall be 10T as indicated in the crane clearance diagram and elsewhere in the technical specification.
2	3.03. 02.0 5	175 of 207	Brakes for Various Drives/Motors	As per clause no. 3.03.02.05, the type of brakes for the Electric hoist is not mentioned in the specification. Please inform the type of brakes for 5T Electric wire rope Hoist.	Specification requirement is clear. Refer clause no. 3.03.02.05 ( A to K) at Page 177 of 207

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.