

Project Engineering  
Management

**Bharat Heavy Electricals Limited**  
(A Govt. Of India Undertaking)



Ref: E-5086/2015

Date: 16/11/2015

**Subject: Approval for TECHNICAL CLARIFICATION THERMAL INSULATION-R-MATTRESSES of 4X270 MW BHADRADRI TPS**

Bidders to note that stitching wire of 0.4 mm dia is to be used instead of 0.911mm dia as mentioned inadvertently in Data Sheet-A. As per standard practice, 0.4mm is used for all mattress densities and thicknesses.

Please submit your offer/revised offer (if submitted) considering the above.

Thanking You

With regards  
For & on behalf of BHEL

Sujeet Kumar  
Sr. Engineer | PG II-2, BHEL PEM | Noida  
E-MAIL: [sujeetkumar@bhhelpem.co.in](mailto:sujeetkumar@bhhelpem.co.in)  
Ph. No. +91-120-4368740

कृपया प्रेषित करे :	Please reply to :	फ़ोन Phone No:
बीएचईएल, पीएस-पीइएम	BHEL, PS-PEM,	91-120 - 436 8960
पीपीइआई भवन	PPEI Building,	
प्लॉट नं २५, सेक्टर १६ ए	Plot No.25, Sector 16A,	
नोएडा - २०१ ३०१ उ प्र	Noida-201301 (U.P.)	
भारत	INDIA	

पंजीकृत कार्यालय	Registered Office :
बीएचईएल हाउस	BHEL House,
सीरी फोर्ट	Siri Fort,
नयी दिल्ली - ११० ०४९	New Delhi-110049
भारत	INDIA