



Ref: PE/PG/EN1/E-5573/2017/Corrigendum/02

Date: 09/05/2017

DUE DATE
20.05.17
BY 02.00 PM (IST)

Subject: Pre-bid technical clarification for tender of Electric Hoist of 2X660 MW ENNORE SEZ STPP

Our Tender Enquiry No. E-5573/2017 dated 10.04.17 for ELECTRIC HOIST OF 2X660 MW ENNORE SEZ STPP

This is in reference to the subject Tender Enquiry please find and consider the following:

- (1) As asked by bidder, pre-bid technical clarification has been uploaded on BHEL PEM and BHEL website.**

Thanking You

With regards
For & on behalf of BHEL

SUJEET KUMAR

Sr Engineer | PG II-2, BHEL PEM | Noida
E-MAIL: sujeetkumar@bhelpem.co.in
Ph. No. +91-120-4368742, +91 9717124683

Please reply to:
Sujeet Kumar (Sr. Engr/PG-II-2)
Power Project Engineering Institute Building
HRD & ESI Complex Plot No. 25, Sector -16 A,
BHEL-PEM, Noida-201301 (U.P.)
Tel No. 0120-4368742



**TECHNICAL SPECIFICATION FOR
2X660 MW SEZ ENNORE STPP
ELECTRIC WIRE ROPE HOISTS**

SPECIFICATION No: PE-TS-412-563-A002

SECTION-III

SUB-SECTION-IIID

REV 00

DATE 04.05.17

**SUB SECTION-IIID
PRE BID CLARIFICATIONS- 1**



TECHNICAL SPECIFICATION FOR
2X660 MW SEZ ENNORE STPP
ELECTRIC WIRE ROPE HOISTS

SPECIFICATION No: PE-TS-412-563-A002

SECTION-III

SUB-SECTION-IIID

REV 00

DATE 04.05.17

PRE-BID CLARIFICATIONS-1

S. no	Section/Clause/Page No.	Statement of the referred clause	Clarification Required	BHEL's clarification
1	SECTION I-SUB SECTION IC /TECHNICAL DATA SHEET, CLAUSE NO 14.1 Page no. 71 of 124	Brake Type: DC EM (disc/shoe type- fail to safety)	Price difference of DC Disc Brake v/s DC Shoe Brake is significant and tender not clearly specify the choice between DC Disc Brake and DC Shoe Brake.	Both types of brakes (Disc and shoe type) are acceptable as per tender specification. This clarification may also be noted for clause no 15.1 of technical data sheet.